

*Model: Defiant
Monessen Hearth Systems
P.O. Box 501
Bethel, VT 05032*

Section 4

Test Data by Run

EPA Weighted Average

Monesson Defiant

227-5-39-3

i	Run #	Burn Rate	P _i	E _i	K _i
①	2	.69	.1442	1.06	.2724
②	3	2.78	.9796	2.04	.2244
⑥	5	1.44	.7166	1.65	.1556
④	8	.95	.3280	4.49	.3100
③	11	.89	.2908	5.91	.0556
⑨	12	2.81	.9802	6.49	.0204
⑦	14	1.51	.7558	0.75	.2630
②	15	.87	.2724	2.29	.1466
⑤	16	1.28	.6008	2.06	.3886

$$\begin{aligned}
 K_1 &= P_2 - P_0 = .2724 - 0 = .2724 \\
 K_2 &= P_3 - P_1 = .2908 - .1442 = .1466 \\
 K_3 &= P_4 - P_2 = .3280 - .2724 = .0556 \\
 K_4 &= P_5 - P_3 = .2908 - .2908 = .3100 \\
 K_5 &= P_6 - P_4 = .7166 - .3280 = .3886 \\
 K_6 &= P_7 - P_5 = .7558 - .6008 = .1556 \\
 K_7 &= P_8 - P_6 = .9796 - .7166 = .2630 \\
 K_8 &= P_9 - P_7 = .9802 - .7558 = .2244 \\
 K_9 &= P_{10} - P_8 = 1 - .9796 = .0204
 \end{aligned}$$

$$\begin{aligned}
 E_w &= \frac{(1.06 \times .2724) + (2.04 \times .2244) + (1.65 \times .1556) + (4.49 \times .3100)}{.2724 + .2244 + .1556 + .3100 + .0556 + .0204 + .2630 + .1466 + .3886} \\
 &\quad + (4.49 \times .3100) + (5.91 \times .0556) + (6.49 \times .0204) + (0.75 \times .2630) \\
 &\quad + (2.29 \times .1466) + (2.06 \times .3886)
 \end{aligned}$$

$$\Rightarrow \frac{4.18864}{1.836} \Rightarrow 2.289/\text{hr}$$

 6/3/10

Checked by:  06/03/10

Run Summary

Run #	Date	Burn Rate Category	Status	Reason for Omission from Weighted Average
1	4/19/2010	Category 1	Unacceptable	Delta T
2	4/20/2010	Category 1	Acceptable	
3	4/21/2010	Category 4	Acceptable	
4	4/21/2010	Category 2	Unacceptable	Data discrepancy
5	4/22/2010	Category 3	Acceptable	
6	4/23/2010	Category 2	Unacceptable	Delta T
7	4/24/2010	Category 2	Unacceptable	Delta T
8	4/25/2010	Category 2	Acceptable	
9	4/26/2010	Fan Confirmation, Category 2	Unacceptable	Delta T
10	4/27/2010	Fan Confirmation, Category 2	Unacceptable	DGMs lost power
11	4/27/2010	Fan Confirmation, Category 2	Acceptable	
12	4/28/2010	Fan Confirmation, Category 4	Acceptable	
13	4/29/2010	Fan Confirmation, Category 1	Unacceptable	Fire went out
14	4/30/2010	Fan Confirmation, Category 3	Acceptable	
15	5/4/2010	Fan Confirmation, Category 1	Acceptable	
16	5/9/2010	Category 3	Acceptable	

Model: Defiant
Monessen Hearth Systems
P.O. Box 501
Bethel, VT 05032

Run 1

Wood Heater Test Data - EPA Method 5G

Manufacturer: Monessen
 Model: Defiant 2N1 (NC)
 Project No.: 227-S-39-3
 Tracking No.: 1534
 Run: 1
 Test Date: 04/19/10-04/20/10

Burn Rate	0.66 kg/hr dry
Average Tunnel Temperature	88 degrees Fahrenheit
Average Gas Velocity In Dilution Tunnel - vs	13.0 feet/second
Average Gas Flow Rate in Dilution Tunnel - Qsd	8439.5 dscf/hour
Average Delta p	0.037 inches H2O
Average Delta H	0.00 inches H2O
Total Time of Test	810 minutes

	AVERAGE	SAMPLE TRAIN 1	SAMPLE TRAIN 2
Total Sample Volume - Vm	127.26 cubic feet	129.92 cubic feet	124.81 cubic feet
Average Gas Meter Temperature	78 degrees Fahrenheit	77 degrees Fahrenheit	78 degrees Fahrenheit
Total Sample Volume (Standard Conditions) - Vmsld	123.1 dscf	125.7 dscf	120.5 dscf
Total Particulates - mn			
Particulate Concentration (dry-standard)	0.00022 grams/dscf	25.4 mg	29.8 mg
Particulate Emission Rate	1.90 grams/hour	0.00020 grams/dscf	0.00025 grams/dscf
Adjusted Emissions	3.09 grams/hour	1.71 grams/hour	2.08 grams/hour
Difference from Average			
7.5% of the average emission rate	0.23	0.26 grams/hour	0.26 grams/hour
Weighted Average Emission Rate Limit	4.10 grams/hour		
7.5% of the weighted average emission rate limit	0.31		
Results Are Acceptable			

Wood Heater Test Data - EPA Method 5G

Run:	1
Manufacturer:	Monesen
Model:	Defiant 2N1 (NC)
Tracking No.:	1534
Project No.:	227-S-39-3
Test Date:	04/19/10-04/20/10
Beginning Clock Time:	01:27
Recording Interval:	10 min.
Total Sampling Time:	810 min.

Velocity Traverse Data							
	Pt.1	Pt.2	Pt.3	Pt.4	Pt.5	Pt.6	Pt.8
Initial dP	0.028	0.038	0.040	0.034	0.026	0.038	0.036
Initial Temp.	93	93	93	93	93	93	93

OMNI Equipment Numbers: _____

PM Control Module:			
Dilution Tunnel MW(dry):	29.00 lb/lb-mole		
Dilution Tunnel MW(wet):	28.56 lb/lb-mole		
Dilution Tunnel H2O:	4.00 percent		
Dilution Tunnel Static:	-0.136 "H2O		
Pitot Tube Cp:	0.99		
Meter Box Y Factor:	0.994 (1) 0.996 (2)		
Barometric Pressure:	Begin Middle End		
	Average	Total Particulate (1):	25.4
	29.60	29.62	29.61 "Hg
		Total Particulate (2):	29.8

Signature/Date: *JL* 6/14/10
Tunnel Velocity: 13.04 ft/sec.
Initial Tunnel Flow: 135.9 scfm
Average Tunnel Flow: 140.7 scfm
Tunnel Area: 0.1963 ft²
Post-Test Leak Check (1): 0.001 cfm@Hg
Post-Test Leak Check (2): 0.001 cfm@Hg
Fuel Moisture (dry basis %): 20.35
Total Particulate (1): 25.4
Total Particulate (2): 29.8

Elapsed Time	Particulate Sampling Data												Wood Heater Temperature Data, °F												Stack				
	Gas Meter Cubic Feet (1)	Gas Meter Cubic Feet (2)	Sample Rate, cfm (1)	Sample Rate, cfm (2)	Orifice dH (1)	Orifice dH (2)	Meter of (1)	Meter of (2)	Meter Vac. In. Hg. (1)	Meter Vac. In. Hg. (2)	Dilution Tunnel Temp.	Dilution Tunnel dP	Pro. Rate (10%) (1)	Pro. Rate (10%) (2)	Scale Reading	Weight Change	Firebox Top	Firebox Bottom	Firebox Back	Firebox Left	Firebox Right	Catalyst Exit	Average Surface	Stack	Filter (1)	Filter (2)	Impinger exit (1)	Impinger exit (2)	Ambient
0	433.516	873.615			0.00	0.00	.78	.79	1.5	3.5	93	0.035			23.6		410	256	280	271	275		298.4	292	75	74		75	0.050
10	435.033	875.233	0.15	0.16	0.00	0.00	.78	.78	1.5	3.5	93	0.037	95	106	23.0	-0.6	348	253	270	264	264		279.8	294	74	73		75	0.048
20	436.549	876.850	0.15	0.16	0.00	0.00	.78	.78	1.5	3.5	94	0.038	94	105	22.4	-0.6	298	244	274	240	240		259.2	326	73	73		75	0.049
30	438.066	878.468	0.15	0.16	0.00	0.00	.77	.78	1.5	3.5	95	0.038	94	105	21.8	-0.6	272	231	289	220	224		247.2	343	73	73		72	0.051
40	439.582	880.085	0.15	0.16	0.00	0.00	.77	.78	1.5	3.5	95	0.036	97	108	21.0	-0.8	256	226	299	211	217		241.8	356	73	73		76	0.050
50	441.099	881.703	0.15	0.16	0.00	0.00	.77	.78	1.5	3.5	96	0.038	94	105	20.2	-0.8	254	217	310	202	213		239.2	367	74	74		76	0.051
60	442.615	883.320	0.15	0.16	0.00	0.00	.78	.79	1.5	3.5	97	0.038	94	105	19.5	-0.75	263	211	321	198	211		240.8	380	74	74		74	0.050
70	444.225	884.870	0.16	0.15	0.00	0.00	.77	.79	1.5	3.5	98	0.039	99	99	18.6	-0.85	275	208	330	195	208		243.2	380	73	74		71	0.051
80	445.840	886.405	0.16	0.15	0.00	0.00	.78	.79	1.5	3.5	99	0.037	102	101	17.8	-0.85	293	200	334	195	212		246.8	388	74	74		75	0.052
90	447.449	887.936	0.16	0.15	0.00	0.00	.77	.79	1.5	3.5	98	0.038	100	99	16.8	-0.95	308	193	340	193	213		249.4	384	73	74		74	0.053
100	449.065	889.458	0.16	0.15	0.00	0.00	.77	.79	1.5	3.5	99	0.038	101	99	15.9	-0.95	327	191	342	193	217		254.0	390	73	74		73	0.052
110	450.675	890.988	0.16	0.15	0.00	0.00	.77	.79	1.5	3.5	102	0.039	99	98	15.0	-0.85	353	188	342	195	221		259.8	401	74	74		73	0.052
120	452.288	892.511	0.16	0.15	0.00	0.00	.78	.79	1.5	3.5	104	0.038	101	99	14.1	-0.95	375	189	355	199	227		269.0	410	74	75		71	0.055
130	453.895	894.036	0.16	0.15	0.00	0.00	.78	.79	1.5	3.5	102	0.038	100	99	13.2	-0.9	394	191	364	206	234		277.8	409	75	75		75	0.055
140	455.512	895.559	0.16	0.15	0.00	0.00	.78	.79	1.5	3.5	104	0.039	100	98	12.2	-1	410	195	368	212	245		286.0	420	75	76		75	0.055
150	457.128	897.087	0.16	0.15	0.00	0.00	.78	.79	1.5	3.5	105	0.038	101	100	11.1	-1.1	434	191	377	215	245		292.4	421	75	76		73	0.055
160	458.743	898.615	0.16	0.15	0.00	0.00	.78	.79	1.5	3.5	105	0.038	101	100	10.4	-0.7	447	193	373	223	256		298.4	421	75	76		74	0.054
170	460.363	900.146	0.16	0.15	0.00	0.00	.78	.79	1.5	3.5	104	0.038	101	100	9.6	-0.75	447	193	364	232	267		300.6	388	76	76		75	0.050
180	461.980	901.675	0.16	0.15	0.00	0.00	.78	.80	1.5	3.5	102	0.038	101	99	9.0	-0.65	443	192	339	237	276		297.4	365	76	77		76	0.050
190	463.600	903.205	0.16	0.15	0.00	0.00	.78	.80	1.5	3.5	101																		

Wood Heater Test Data - EPA Method 5G

Run:	1
Manufacturer:	Monessen
Model:	Defiant 2NI (NC)
Tracking No.:	1534
Project No.:	227-S-39-3
Test Date:	04/19/10-04/20/10
Beginning Clock Time:	01:27
Recording Interval:	10 min
Total Sampling Time:	810 min

Velocity Traverse Data							
	Pt.1	Pt.2	Pt.3	Pt.4	Pt.5	Pt.6	Pt.7
Initial dP	0.028	0.038	0.040	0.034	0.026	0.038	0.038
Initial Temp.	93	93	93	93	93	93	93

OMNI Equipment Numbers: _____

PM Control Module:	
Dilution Tunnel MW(dry):	29.00 lb/lb-mole
Dilution Tunnel MW(wet):	28.56 lb/lb-mole
Dilution Tunnel H2O:	4.00 percent
Dilution Tunnel Static:	-0.136 "H2O
Pitot Tube Cp:	0.99
Meter Box Y Factor:	0.994 (1) 0.996 (2)
Barometric Pressure:	Begin Middle End Average Total Particulate (1): 25.4
	29.60 29.62 29.62 29.61 "Hg Total Particulate (2): 29.8

Elapsed Time	Particulate Sampling Data												Wood Heater Temperature Data, °F												Stack				
	Gas Meter Cubic Feet (1)	Gas Meter Cubic Feet (2)	Sample Rate, cfm (1)	Sample Rate, cfm (2)	Orifice dH (1)	Orifice dH (2)	Meter of (1)	Meter of (2)	Meter Vac. In. Hg. (1)	Meter Vac. In. Hg. (2)	Dilution Tunnel dP	Dilution Tunnel Temp.	Pro. Rate (10%) (1)	Pro. Rate (10%) (2)	Scale Reading	Weight Change	Firebox Top	Firebox Bottom	Firebox Back	Firebox Left	Firebox Right	Catalyst Exit	Average Surface	Stack	Filter (1)	Filter (2)	Impinger exit (1)	Impinger exit (2)	Ambient
430	502.291	940.142	0.16	0.15	0.00	0.00	75	76	1.5	3.5	83	0.037	101	100	3.8	-0.2	274	134	186	167	175		187.2	190	70	71		73	0.020
440	503.901	941.685	0.16	0.15	0.00	0.00	75	76	1.5	3.5	83	0.037	101	101	3.6	-0.2	287	132	194	169	179		192.2	194	70	71		73	0.020
450	505.518	943.222	0.16	0.15	0.00	0.00	75	76	1.5	3.5	83	0.037	101	100	3.4	-0.2	300	141	201	173	184		199.8	199	70	71		72	0.021
460	507.145	944.775	0.16	0.16	0.00	0.00	75	76	1.5	3.5	83	0.037	102	101	3.2	-0.15	308	144	183	177	185		199.4	194	70	71		72	0.021
470	508.743	946.292	0.16	0.15	0.00	0.00	75	76	1.5	3.5	82	0.036	101	100	3.1	-0.15	313	147	159	177	185		196.2	194	70	70		72	0.021
480	510.360	947.827	0.16	0.15	0.00	0.00	75	76	1.5	3.5	82	0.036	102	101	2.9	-0.15	317	144	152	178	185		195.2	189	70	70		71	0.021
490	511.978	949.368	0.16	0.15	0.00	0.00	74	76	1.5	3.5	82	0.035	104	103	2.8	-0.1	323	148	146	178	182		195.4	187	70	70		71	0.021
500	513.589	950.878	0.16	0.15	0.00	0.00	74	75	1.5	3.5	81	0.037	101	98	2.7	-0.15	327	148	144	178	184		196.2	184	69	70		71	0.020
510	515.200	952.406	0.16	0.15	0.00	0.00	74	75	1.5	3.5	82	0.036	102	101	2.5	-0.2	323	145	143	180	186		195.4	182	69	69		71	0.020
520	516.815	953.931	0.16	0.15	0.00	0.00	74	75	1.5	3.5	82	0.036	102	101	2.4	-0.1	320	143	143	180	186		194.4	180	69	69		71	0.020
530	518.429	955.461	0.16	0.15	0.00	0.00	74	75	1.5	3.5	82	0.035	104	103	2.2	-0.15	323	143	141	182	186		195.0	178	69	69		71	0.020
540	520.046	956.984	0.16	0.15	0.00	0.00	74	75	1.5	3.5	81	0.036	102	101	2.1	-0.15	321	146	139	182	186		194.8	176	69	69		71	0.020
550	521.651	958.509	0.16	0.15	0.00	0.00	73	75	1.5	3.5	81	0.034	105	104	1.9	-0.15	318	143	137	184	186		193.6	169	69	69		71	0.020
560	523.268	960.034	0.16	0.15	0.00	0.00	74	75	1.5	3.5	81	0.037	101	99	1.8	-0.15	316	143	135	184	184		192.4	167	69	69		71	0.019
570	524.880	961.570	0.16	0.15	0.00	0.00	74	75	1.5	3.5	81	0.036	102	101	1.7	-0.1	316	145	130	186	184		192.2	160	69	69		71	0.019
580	526.490	963.095	0.16	0.15	0.00	0.00	73	75	1.5	3.5	80	0.035	104	102	1.5	-0.15	316	141	132	186	182		191.4	156	69	69		68	0.018
590	528.110	964.645	0.16	0.15	0.00	0.00	74	75	1.5	3.5	81	0.035	104	104	1.5	-0.05	307	143	123	183	177		186.6	149	69	69		66	0.018
600	529.703	966.172	0.16	0.15	0.00	0.00	74	75	1.5	3.5	81	0.035	103	103	1.4	-0.1	296	143	141	186	179		189.0	147	70	70		66	0.017
610	531.301	967.712	0.16	0.15	0.00	0.00	74	75	1.5	3.5	82	0.036	101	102	1.3	-0.1	286	145	150	188	180		189.8	143	70	70		71	0.016
620	532.910	969.247	0.16	0.15	0.00	0.00	75	76	1.5	3.5	83	0.036	102	101	1.2	-0.05	279	148	152	191	182		190.4	141	71	71		75	0.016
630	53																												

PRINT

**Final Laboratory Report - Method 5G Dual Train
Dilution Tunnel Particulate Calculations**

Client Name: Monessen
 Model: Defiant 2NI (NC)
 Project No.: 227-S-39-3
 Tracking No.: 1534

Equipment Numbers:

Run #: 1Train #: ADate: 04/19/10

Sample Component	Reagent	Filter # or Probe #	Weights		
			Final, mg	Tare, mg	Particulate, mg
A. Front filter catch	Filter	F533	141.3	117.0	24.3
B. Rear filter catch	Filter	F534	121.1	120.7	0.4
C. Probe catch	Probe	15	114335.2	114334.5	0.7

Total Particulate, mg :	<u>25.4</u>
-------------------------	-------------

Component	Equations:
A. Front filter catch	Final (mg) - Tare (mg) = Particulate, mg
B. Rear filter catch	Final (mg) - Tare (mg) = Particulate, mg
C. Probe catch	Final (mg) - Tare (mg) = Particulate, mg

Analyst: J. H. H.Date: 05/28/10

PRINT

**Final Laboratory Report - Method 5G Dual Train
Dilution Tunnel Particulate Calculations**

Client Name: Monessen
 Model: Defiant 2NI (NC)
 Project No.: 227-S-39-3
 Tracking No.: 1534

Equipment Numbers:

Run #: 1
 Train #: B
 Date: 04/19/10

Sample Component	Reagent	Filter # or Probe #	Weights		
			Final, mg	Tare, mg	Particulate, mg
A. Front filter catch	Filter	F535	152.2	125.3	26.9
B. Rear filter catch	Filter	F536	118.7	117.8	0.9
C. Probe catch	Probe	28	114743.0	114741.0	2.0

Total Particulate, mg :	<u>29.8</u>
-------------------------	-------------

Component	Equations:
A. Front filter catch	Final (mg) - Tare (mg) = Particulate, mg
B. Rear filter catch	Final (mg) - Tare (mg) = Particulate, mg
C. Probe catch	Final (mg) - Tare (mg) = Particulate, mg

Analyst: J. C. H.Date: 05/28/10

STOVE TEMPERATURE TEST DATA - METHOD 5G

Page 1 of 1

Client/Model: Monessen Defiant ZN1(N) Project #: 227-5-39-3 Tracking #: 15-34

Date: 04/19/10 Test Crew: TR

OMNI Equipment ID #:

Preburn Test	Fuel	Coal Bed: <u>5.9 - 4.7 lbs</u>			Actual: <u>5.8 lbs</u>						
		Weight Data: 0 =	Delta Weight	Stack Draft	Ambient	Bottom	Back	Left	Right	Flue	Catalyst
0	16.00	0	0.063	83	611	417	172	337	289	328	
10	14.6	-0.14	0.053	82	518	403	185	315	278	281	
20	13.4	-0.2	0.045	82	433	381	202	301	269	269	
30	12.4	-0.3	0.04	82	420	359	203	287	259	259	
40	11.75	-0.45	0.04	82	410	347	204	275	254	256	
50	10.45	-1.3	0.055	78	384	321	282	269	245	421	
60	9.10	-1.35	0.055	78	388	304	356	267	241	442	
70	8.00	-1.10	0.058	75	407	294	387	265	244	417	
80	7.30	-0.7	0.054	75	415	290	362	265	254	373	
90	6.95	-0.35	0.05	75	438	288	353	266	260	344	
00	6.35	-0.6	0.05	72	432	240	326	270	274	4836	
10	5.90	-0.45	0.048	74	414	256	288	271	275	292	
20											
30											
40											
50											
60											
70											
80											
90											
Avg											

Technician signature: LDate: 05/14/10

FUEL DATA

Client: MonessenModel: Defiant 2N1Project #2275-39-3 Tracking #: 1534Date: 04/19/10 Test Crew: TC Run #: 1

OMNI Equipment ID #:

FUEL LOAD PREPARED BY: Cut, assembled by Ralph G - Measured / Moisture taken by TCFUEL: DOUGLAS-FIR SPECIES, UNTREATED, AIR-DRIED, STANDARD GRADE OR BETTER,
DIMENSIONAL LUMBER.

PRE-BURN FUEL

MOISTURE CONTENT (METER -- DRY BASIS)

CALIBRATION: Cal Value (1) = 12% Actual Reading 12.0
 Cal Value (2) = 22% Actual Reading 22.3

Piece	Length	Readings	Type
1	2 7/8 ft	19.8	2x4
2	ft	20.2	19.2
3	ft		19.3

Length of cut pieces: 8 inches Pre-Burn Fuel Average Moisture: 19.6Time (clock): 10:30 Room Temperature (F): 80 Initials: TC

TEST FUEL

FUEL TYPE AND AMOUNT: 2 x 4 4 x 4 4CALCULATED LOAD WEIGHT: 20.34 - 24.87 ACTUAL LOAD WEIGHT: 23.6

(2 x 4)

(4 x 4)

FUEL PIECE LENGTH: 2 1/423.6

Total

MOISTURE CONTENT (METER -- DRY BASIS)

PIECE	READINGS	TYPE
1	19.6	2x4
2	20.1	2x4
3	21.1	2x4
4	19.8	2x4
5		
6		
7		
8		
9		
10		

OVERALL TEST FUEL LOAD MOISTURE AVERAGE: 20.35Time (clock): 10:30 Room Temperature (F): 80 Initials: TCTechnician signature: TGDate: 04/19/10

Run Notes


Client: Moreson
 Model: Defiant 2N1 (NC)

Project #: 227-S-37-3Tracking #: 1534Run #: 1Date: Tu 04/19/10
03 04/19/10Test Crew: TZ

OMNI Equipment ID #(s): _____

PREBURN

DESCRIBE OR SKETCH AIR OR THERMOMSTAT SETTINGS BELOW:
 (SETTINGS MUST BE ACCURATE AND REPRODUCIBLE)

PRIMARY: See test setting sketch

SECONDARY: _____

2/4

TERTIARY: _____

Tu 04/19/10

FAN: _____


low

PREBURN SETTINGS AND ACTIVITIES

TIME	AIR (THERMO) CHANGES PRIMARY/SECONDARY/TERTIARY	FAN SETTING CHANGE	ADD FUEL + WT.	ADD FUEL - WT.	RAKE COAL	COMMENT
0	<u>-load = test setting</u>					
40	_____				X	_____
95	_____				X	_____


TEST

TEST FUEL CONFIGURATION SKETCH
 (INDICATE VIEW ANGLE)



DESCRIBE OR SKETCH TEST SETTINGS BELOW:
 (SETTINGS MUST BE ACCURATE AND REPRODUCIBLE)

PRIMARY:



START UP PROCEDURES

BYPASS: Open 1 minFUEL LOADING: 1 minDOOR: 1 minPRIMARY AIR: Test setting@ 0 min
 (no change)OTHER: - Test fuel staged @ 367 min
after 10 min w/ <0.1 lb change

SECONDARY: _____

N/A

TERTIARY: _____

N/A

FAN: _____

lowTechnician signature: TimDate: 04/20/10

4-12 OF 4-156

Supplemental Data EPA 5G/5H

Client: MouessenModel: Definiti 2 N1 (non-cat)Project #: 227-5-37 Tracking #: 1534Date: 04/19/10 Run #: 1 Booth: S/ATest Crew: R Start Time: 1:27 PM Stop Time: 2:57 AM 04/20/10
(run)OMNI Equipment #(s): _____Gas Analyzer Train Leak Check:

Stack:

Dilution Tunnel (Method 5G Only):

Initial: _____

Initial: _____

Final: _____

Final: _____

Calibrations: Span Gas CO₂: _____ O₂: _____ CO: _____ CO₂(DT): _____

Time	N ₂ Span						
O ₂							
CO ₂							
CO							
CO ₂ (DT)							

Stack Diameter (inches): 6Air Velocity (ft/min): Initial: < 50 ft/min Final: < 50 ft/minScale Audit (lbs): Pretest: 10.00 lbs Post Test: 10.00Induced Draft: 0 %Smoke Capture: 100Pitot Tube Leak Test: Pre: 0.0 @ 3.0 Post: 0.0 @ 3.1Flue Pipe Cleaned Prior to First Test in Series: Date: 04/18/10 Initials: TC

	Initial	Middle	Ending
Pb (in/Hg)	<u>29.58</u>	<u>29.60</u>	<u>29.62</u>
Room Temp (°F)	<u>78.0</u>	<u>76.0</u>	<u>60</u>

Technician signature: T. C. Chard Date: 04/20/10

4-13 OF 4-155

*Model: Defiant
Monessen Hearth Systems
P.O. Box 501
Bethel, VT 05032*

Run 2

Wood Heater Test Data - EPA Method 5G

Manufacturer: Monessen
 Model: Defiant 2N1 (NC)
 Project No.: 227-S-39-3
 Tracking No.: 1534
 Run: 2
 Test Date: 04/20/10

Burn Rate	0.69 kg/hr dry
Average Tunnel Temperature	91 degrees Fahrenheit
Average Gas Velocity In Dilution Tunnel - vs	12.1 feet/second
Average Gas Flow Rate In Dilution Tunnel - Qsd	7792.2 dscf/hour
Average Delta p	0.032 inches H2O
Average Delta H	0.00 inches H2O
Total Time of Test	730 minutes

	AVERAGE	SAMPLE TRAIN 1	SAMPLE TRAIN 2
Total Sample Volume - Vm	113.61 cubic feet	117.31 cubic feet	109.91 cubic feet
Average Gas Meter Temperature	79 degrees Fahrenheit	78 degrees Fahrenheit	79 degrees Fahrenheit
Total Sample Volume (Standard Conditions) - Vmsid	109.5 dscf	113.1 dscf	105.9 dscf
Total Particulates - mn		7.2 mg	7.5 mg
Particulate Concentration (dry-standard)	0.00007 grams/dscf	0.00006 grams/dscf	0.00007 grams/dscf
Particulate Emission Rate	0.52 grams/hour	0.50 grams/hour	0.55 grams/hour
Adjusted Emissions	1.06 grams/hour	1.02 grams/hour	1.11 grams/hour
Difference from Average		0.05 grams/hour	0.05 grams/hour
7.5% of the average emission rate	0.08		
Weighted Average Emission Rate Limit	4.10 grams/hour		
7.5% of the weighted average emission rate limit	0.31		

Results Are Acceptable

Wood Heater Test Data - EPA Method 5G

Run:	2
Manufacturer:	Monessen
Model:	Defiant 2N1 (NC)
Tracking No.:	1534
Project No.:	227-S-39-3
Test Date:	20-Apr-10
Beginning Clock Time:	12:03
Recording Interval:	10 min.
Total Sampling Time:	730 min.

Velocity Traverse Data							
	Pt.1	Pt.2	Pt.3	Pt.4	Pt.5	Pt.6	Pt.7
Initial dP	0.020	0.034	0.039	0.037	0.028	0.036	0.038
Initial Temp.	94	94	94	94	94	94	94

°H₂O

OMNI Equipment Numbers:

PM Control Module:			
Dilution Tunnel MW(dry):	29.00	lb/lb-mole	
Dilution Tunnel MW(wet):	28.56	lb/lb-mole	
Dilution Tunnel H ₂ O:	4.00	percent	
Dilution Tunnel Static:	-0.10	"H ₂ O	
Pilot Tube Cp:	0.99		
Meter Box Y Factor:	0.994	(1) 0.996	(2)
Barometric Pressure:	Begin	Middle	End
	29.60	29.55	29.55
Average	29.57	"Hg	
Total Particulate (1):	7.2		
Total Particulate (2):	7.5		

Signature/Date: *JL* 6/4/10
Tunnel Velocity: 12.14 ft/sec.
Initial Tunnel Flow: 132.2 scfm
Average Tunnel Flow: 129.9 scfm
Tunnel Area: 0.1963 ft²
Post-Test Leak Check (1): 0.000@5 cfm@1" Hg
Post-Test Leak Check (2): 0.000@9 cfm@1" Hg
Fuel Moisture (dry basis %): 20.2

Elapsed Time	Particulate Sampling Data												Wood Heater Temperature Data, °F												Stack				
	Gas Meter Cubic Feet (1)	Gas Meter Cubic Feet (2)	Sample Rate, cfm (1)	Sample Rate, cfm (2)	Orifice dH (1)	Orifice dH (2)	Meter oF (1)	Meter oF (2)	Meter Vac. In. Hg. (1)	Meter Vac. In. Hg. (2)	Dilution Tunnel dP	Dilution Tunnel Temp.	Pro. Rate (10%) (1)	Pro. Rate (10%) (2)	Scale Reading	Weight Change	Firebox Top	Firebox Bottom	Firebox Back	Firebox Left	Firebox Right	Catalyst Exit	Average Surface	Stack	Filter (1)	Filter (2)	Impinger exit (1)	Impinger exit (2)	Ambient
0	563.496	998.312			0.00	0.00	78	79			94	0.033			22.2		409	246	266	266	268		291.0	318	74	75		75	0.052
10	565.150	999.885	0.17	0.16	0.00	0.00	78	79			98	0.033	102	103	21.8	-0.45	328	240	263	250	248		265.8	298	74	73		72	0.052
20	566.782	1001.435	0.16	0.15	0.00	0.00	78	78			94	0.033	100	102	21.3	-0.45	289	226	263	226	226		246.0	306	72	72		72	0.045
30	568.406	1002.955	0.16	0.15	0.00	0.00	78	78			94	0.034	98	98	20.8	-0.5	269	217	267	211	211		235.0	324	73	73		74	0.045
40	570.018	1004.466	0.16	0.15	0.00	0.00	78	79			95	0.034	98	98	20.3	-0.55	258	206	277	200	200		228.2	334	72	72		73	0.045
50	571.617	1005.962	0.16	0.15	0.00	0.00	78	79			96	0.034	97	97	19.6	-0.7	258	202	288	193	193		226.8	340	72	72		73	0.045
60	573.215	1007.462	0.16	0.15	0.00	0.00	77	79			96	0.035	96	96	19.0	-0.6	258	197	292	191	191		225.8	340	72	73		73	0.046
70	574.823	1008.979	0.16	0.15	0.00	0.00	77	79			97	0.034	98	98	18.2	-0.8	264	191	297	189	189		226.0	344	73	73		73	0.046
80	576.430	1010.495	0.16	0.15	0.00	0.00	78	79			98	0.033	99	100	17.5	-0.7	275	184	297	189	189		226.8	345	73	73		73	0.046
90	578.038	1012.000	0.16	0.15	0.00	0.00	78	79			98	0.034	98	98	16.7	-0.8	288	180	299	191	189		229.4	349	73	73		73	0.047
100	579.638	1013.515	0.16	0.15	0.00	0.00	78	79			98	0.034	97	98	15.9	-0.75	306	176	297	193	189		232.2	349	73	73		73	0.047
110	581.238	1015.023	0.16	0.15	0.00	0.00	78	79			98	0.034	97	98	15.1	-0.85	325	174	301	195	189		236.8	364	73	73		73	0.047
120	582.843	1016.530	0.16	0.15	0.00	0.00	78	79			101	0.033	99	99	14.1	-0.95	357	171	316	201	191		247.2	390	73	73		75	0.050
130	584.438	1018.040	0.16	0.15	0.00	0.00	78	79			99	0.032	100	101	13.2	-0.95	383	166	326	209	199		256.6	381	73	74		72	0.050
140	586.070	1019.570	0.16	0.15	0.00	0.00	77	79			100	0.035	98	98	12.2	-0.95	405	167	325	216	206		263.8	377	73	74		73	0.051
150	587.640	1021.058	0.16	0.15	0.00	0.00	78	79			101	0.033	97	98	11.4	-0.8	415	166	324	222	211		267.6	378	74	74		74	0.050
160	589.244	1022.565	0.16	0.15	0.00	0.00	78	79			101	0.034	98	98	10.5	-0.9	430	166	328	226	218		273.6	393	74	74		72	0.051
170	590.848	1024.073	0.16	0.15	0.00	0.00	78	79			102	0.033	99	100	9.7	-0.85	445	168	339	233	230		283.0	397	74	74		72	0.052
180	592.448	1025.582	0.16	0.15	0.00	0.00	78	79			102	0.032	101	101	8.8	-0.85	456	168	339	239	237		287.8	380	73	74		74	0.053
190	594.049	1027.081	0.16	0.15	0.00	0.00	77</td																						

Wood Heater Test Data - EPA Method 5G

Run:	2
Manufacturer:	Monessen
Model:	Defiant 2N1 (NC)
Tracking No.:	1534
Project No.:	227-S-39-3
Test Date:	20-Apr-10
Beginning Clock Time:	12:03
Recording Interval:	10 min.
Total Sampling Time:	730 min.

Velocity Traverse Data							
	Pt.1	Pt.2	Pt.3	Pt.4	Pt.5	Pt.6	Pt.7
Initial dP	0.020	0.034	0.039	0.037	0.028	0.036	0.038
Initial Temp.	94	94	94	94	94	94	94

OMNI Equipment Numbers: _____

PM Control Module:	
Dilution Tunnel MW(dry):	29.00 lb/lb-mole
Dilution Tunnel MW(wet):	28.56 lb/lb-mole
Dilution Tunnel H2O:	4.00 percent
Dilution Tunnel Static:	-0.130 "H2O
Pitot Tube Cp:	0.99
Meter Box Y Factor:	0.994 (1) 0.996 (2)
Barometric Pressure:	Begin Middle End Average
	29.60 29.55 29.55 29.57 "Hg

Signature/Date: *JL* 6/4/10

Tunnel Velocity:	12.14 ft/sec.
Initial Tunnel Flow:	132.2 scfm
Average Tunnel Flow:	129.9 scfm
Tunnel Area:	0.1963 ft ²
Post-Test Leak Check (1):	0.000@5 cfm@"Hg
Post-Test Leak Check (2):	0.000@9 cfm@"Hg
Fuel Moisture (dry basis %):	20.2
Total Particulate (1):	7.2
Total Particulate (2):	7.5

Elapsed Time	Particulate Sampling Data										Fuel Weight, lb		Wood Heater Temperature Data, °F										Stack					
	Gas Meter Cubic Feet (1)	Gas Meter Cubic Feet (2)	Sample Rate, cfm (1)	Sample Rate, cfm (2)	Orifice dH (1)	Orifice dH (2)	Meter of F (1)	Meter Vac In. Hg (1)	Meter Vac In. Hg (2)	Dilution Tunnel Temp.	Dilution Tunnel dP	Pro. Rate (10%) (1)	Pro. Rate (10%) (2)	Scale Reading	Weight Change	Firebox Top	Firebox Bottom	Firebox Back	Firebox Left	Firebox Right	Catalyst Exit	Average Surface	Stack	Filter (1)	Filter (2)	Impinger exit (1)	Impinger exit (2)	Ambient
430	632.555	1063.110	0.16	0.14	0.00	0.00	79	80		88	0.031	101	96	3.5	-0.1	236	135	146	178	165		172.0	137	74	74		78	0.015
440	634.163	1064.610	0.16	0.15	0.00	0.00	79	80		88	0.031	101	101	3.4	-0.15	240	131	150	176	163		172.0	146	74	74		78	0.015
450	635.770	1066.110	0.16	0.15	0.00	0.00	79	80		87	0.031	101	101	3.3	-0.1	247	128	156	178	161		174.0	156	74	74		77	0.015
460	637.380	1067.725	0.16	0.16	0.00	0.00	79	80		87	0.030	103	110	3.1	-0.2	257	128	167	178	160		178.0	169	74	74		77	0.016
470	638.985	1069.230	0.16	0.15	0.00	0.00	79	80		88	0.030	103	103	2.9	-0.2	272	128	177	180	162		183.8	177	74	75		77	0.017
480	640.600	1070.738	0.16	0.15	0.00	0.00	79	80		88	0.031	102	101	2.7	-0.15	283	128	186	184	165		189.2	184	75	75		77	0.018
490	642.205	1072.248	0.16	0.15	0.00	0.00	78	80		90	0.031	101	102	2.6	-0.15	294	128	197	188	166		194.6	188	75	75		77	0.019
500	643.845	1073.770	0.16	0.15	0.00	0.00	79	80		90	0.030	105	104	2.4	-0.2	305	130	201	192	169		199.4	192	76	76		77	0.019
510	645.420	1075.255	0.16	0.15	0.00	0.00	79	80		91	0.032	98	98	2.3	-0.1	309	132	177	195	171		196.8	192	76	77		77	0.020
520	647.036	1076.761	0.16	0.15	0.00	0.00	79	80		91	0.031	102	101	2.1	-0.15	320	133	165	195	173		197.2	190	77	77		77	0.020
530	648.638	1078.263	0.16	0.15	0.00	0.00	79	80		92	0.031	101	101	2.0	-0.15	325	135	159	197	176		198.4	193	77	77		78	0.020
540	650.252	1079.770	0.16	0.15	0.00	0.00	79	80		92	0.030	104	103	1.8	-0.15	325	137	156	195	178		198.6	188	78	78		77	0.019
550	651.871	1081.268	0.16	0.15	0.00	0.00	79	80		92	0.030	104	103	1.7	-0.1	325	137	152	197	180		198.2	182	78	78		76	0.020
560	653.475	1082.779	0.16	0.15	0.00	0.00	79	80		92	0.030	103	104	1.6	-0.15	327	138	148	198	180		198.2	176	78	78		78	0.019
570	655.078	1084.290	0.16	0.15	0.00	0.00	79	80		92	0.030	103	104	1.5	-0.1	329	137	142	197	180		197.0	172	78	78		76	0.019
580	656.690	1085.794	0.16	0.15	0.00	0.00	79	80		91	0.031	102	101	1.4	-0.1	334	137	139	195	182		197.4	167	78	78		78	0.018
590	658.300	1087.290	0.16	0.15	0.00	0.00	79	80		91	0.031	102	101	1.3	-0.1	329	135	137	195	182		195.6	163	78	78		77	0.018
600	659.910	1088.794	0.16	0.15	0.00	0.00	79	80		90	0.030	103	103	1.2	-0.1	327	137	135	193	184		195.2	159	78	78		75	0.017
610	661.520	1090.298	0.16	0.15	0.00	0.00	79	80		89	0.029	105	105	1.1	-0.1	323	137	129	189	182		192.0	154	78	78		75	0.017
620	663.130	1091.790	0.16	0.15	0.00	0.00	79	80		89	0.029	105	104	1.0	-0.1	314	135	126	186	182		188.6	152	78	78		75	0.017
630																												

Final Laboratory Report - Method 5G Dual Train
Dilution Tunnel Particulate Calculations

Client Name: Monessen
 Model: Defiant 2NI (NC)
 Project No.: 227-S-39-3
 Tracking No.: 1534

Equipment Numbers: _____
 Run #: 2
 Train #: A
 Date: 04/20/10

Sample Component	Reagent	Filter # or Probe #	Weights		
			Final, mg	Tare, mg	Particulate, mg
A. Front filter catch	Filter	F537	126.8	120.4	6.4
B. Rear filter catch	Filter	F538	125.3	124.9	0.4
C. Probe catch	Probe	24	114123.9	114123.5	0.4

Total Particulate, mg :	7.2
-------------------------	-----

Component	Equations:
A. Front filter catch	Final (mg) - Tare (mg) = Particulate, mg
B. Rear filter catch	Final (mg) - Tare (mg) = Particulate, mg
C. Probe catch	Final (mg) - Tare (mg) = Particulate, mg

Analyst: T. J. H. Date: 6/5/2010

Final Laboratory Report - Method 5G Dual Train Dilution Tunnel Particulate Calculations

Client Name:	Menessen
Model:	Defiant 2N1 (NC)
Project No.:	227-S-39-3
Tracking No.:	1534

Equipment Numbers: _____

Run #: 2
Train #: B
Date: 04/20/10

Sample Component	Reagent	Filter # or Probe #	Weights		
			Final, mg	Tare, mg	Particulate, mg
A. Front filter catch	Filter	F539	122.9	116.8	6.1
B. Rear filter catch	Filter	F540	122.1	121.3	0.8
C. Probe catch	Probe	34	115865.5	115864.9	0.6

Total Particulate, mg : 7.5

Component	Equations:
A. Front filter catch	Final (mg) - Tare (mg) = Particulate, mg
B. Rear filter catch	Final (mg) - Tare (mg) = Particulate, mg
C. Probe catch	Final (mg) - Tare (mg) = Particulate, mg

— 6 —

Date: 05/28/10

STOVE TEMPERATURE TEST DATA - METHOD 5G

Page 1 of 1Client/Model: Moreson / Defiant 241 (nd) Project #: 227-5-39-3Date: 04/20/10 Test Crew: T2OMNI Equipment ID #: Tracking #: 15-34
Run #: 74/20/10

Preburn Test	Coal Bed: 4.44 - 5.55 lbs			Actual: Coal Bed: 5.05							
	Fuel Weight	Delta Weight	Stack Draft	Ambient	Top	Bottom	Back	Left	Right	Flue	Catalyst
0	16.00	0	0.055	77	79.8	36.9	19.1	26.4	29.3	38.8	
10	14.55	1.45	0.05	78	60.6	36.0	18.5	28.0	30.4	28.0	
20	13.50	1.05	0.04	79	49.6	34.4	18.2	27.3	29.2	25.1	
30	12.65	0.85	0.035	80	45.1	32.5	17.6	25.9	27.6	23.2	
40	11.20	1.45	0.052	81	40.6	30.4	23.5	25.4	26.1	40.0	
50	9.8	1.40	0.056	77	39.4	27.7	33.3	24.6	24.8	37.4	
60	8.80	1.0	0.055	77	40.0	26.3	36.5	24.4	24.6	42.4	
70	8.05	0.75	0.055	74	41.2	25.6	36.0	24.3	24.3	38.4	
80	7.70	0.35	0.050	73	42.0	25.8	33.3	24.9	24.7	34.4	
90	6.8	0.90	0.05	74	43.0	25.6	31.3	25.7	25.5	38.5	
00	6.40	0.4	0.05	74	42.3	25.0	32.1	26.1	26.5	35.0	
10	5.45	0.45	0.05	73	42.5	24.5	30.3	26.4	26.9	31.0	
20											
30											
40											
50											
60											
70											
80											
90											
Avg											

Technician signature: Date: 05/03/10

FUEL DATA

Client: MonesienModel: Defiant ZN (NC)Project #: 1295-313 Tracking #: 1534Date: 04/20/10 Test Crew: T2 Run #: 2

OMNI Equipment ID #:

FUEL LOAD PREPARED BY: Ralph G. cut & prepped - T2 measured dimensions & moistFUEL: DOUGLAS-FIR SPECIES, UNTREATED, AIR-DRIED, STANDARD GRADE OR BETTER,
DIMENSIONAL LUMBER.

PRE-BURN FUEL

MOISTURE CONTENT (METER -- DRY BASIS)

CALIBRATION: Cal Value (1) = 12% Actual Reading 12.0
 Cal Value (2) = 22% Actual Reading 22.0

Piece	Length	Readings	Type
1	15 ft	19.3	2x4
2	15 ft	19.1	2x4
3	ft		

Length of cut pieces: 8 inches Pre-Burn Fuel Average Moisture: 19.2Time (clock): 8:45 Room Temperature (F): 78 Initials: T2

TEST FUEL

FUEL TYPE AND AMOUNT: 2 x 4 4 x 4 4CALCULATED LOAD WEIGHT: 22.75 %107 ACTUAL LOAD WEIGHT: 22.20 (2 x 4)FUEL PIECE LENGTH: 21" 22.20 (4 x 4) 22.20 Total

MOISTURE CONTENT (METER -- DRY BASIS)

PIECE	READINGS	TYPE
1	22.4	20.4
2	20.4	20.6
3	18.4	18.9
4	20.3	20.4
5		
6		
7		
8		
9		
10		

OVERALL TEST FUEL LOAD MOISTURE AVERAGE: 20.2Time (clock): 0845 Room Temperature (F): 78 Initials: T2Technician signature: T. Chaff Date: 05/03/10

Supplemental Data EPA 5G/5H

Client: MonessenModel: Dofiant 2N1 (NC)Project #: 227-5-39-3 Tracking #: 1534Date: 04/20/10 Run #: 2 Booth: N/ATest Crew: TC Start Time: 12:03 Stop Time: 12:13 (A.M.) 04/21/10
(test)

OMNI Equipment #(s): _____

Gas Analyzer Train Leak Check:

Stack:

Dilution Tunnel (Method 5G Only):

Initial: _____

Initial: _____

Final: _____

Final: _____

Calibrations: Span Gas CO₂: _____ O₂: _____ CO: _____ CO₂(DT): _____

Time	N ₂ Span						
O ₂		A/A					
CO ₂							
CO							
CO ₂ (DT)							

Stack Diameter (inches): 6Air Velocity (ft/min): Initial: < 50 ft/min Final: < 50 ft/minScale Audit (lbs): Pretest: 10.00 Post Test: 10.00Induced Draft: 0" WC %Smoke Capture: 100Pitot Tube Leak Test: Pre: 0.0 @ 3.0 Post: 0.0 @ 3.0Flue Pipe Cleaned Prior to First Test in Series: Date: 04/18/10 Initials: TC

	Initial	Middle	Ending
Pb (in/Hg)	<u>29.60</u>	<u>29.55</u>	<u>29.525 or</u>
Room Temp (°F)	<u>78 75 or</u>	<u>77</u>	<u>82 84 or</u>

Technician signature: T. Hes Date: 04/20/10

*Model: Defiant
Monessen Hearth Systems
P.O. Box 501
Bethel, VT 05032*

Run 3

Wood Heater Test Data - EPA Method 5G

Manufacturer: Monessen
 Model: Defiant 2N1 (NC)
 Project No.: 227-S-39-3
 Tracking No.: 1534
 Run: 3
 Test Date: 04/21/10

Burn Rate	2.78 kg/hr dry
Average Tunnel Temperature Average Gas Velocity in Dilution Tunnel - vs Average Gas Flow Rate in Dilution Tunnel - Qsd	134 degrees Fahrenheit 14.7 feet/second 8742.4 dscf/hour
Average Delta p Average Delta H Total Time of Test	0.043 inches H2O 0.00 inches H2O 190 minutes

	AVERAGE	SAMPLE TRAIN 1	SAMPLE TRAIN 2
Total Sample Volume - Vm	29.51 cubic feet	30.49 cubic feet	28.53 cubic feet
Average Gas Meter Temperature	80 degrees Fahrenheit	80 degrees Fahrenheit	81 degrees Fahrenheit
Total Sample Volume (Standard Conditions) - Vmsld	28.3 dscf	29.2 dscf	27.3 dscf
Total Particulates - mn			
Particulate Concentration (dry-standard)	0.00013 grams/dscf	0.00013 grams/dscf	0.00013 grams/dscf
Particulate Emission Rate	1.14 grams/hour	1.14 grams/hour	1.16 grams/hour
Adjusted Emissions	2.04 grams/hour	2.03 grams/hour	2.05 grams/hour
Difference from Average			
7.5% of the average emission rate	0.15	0.01 grams/hour	0.01 grams/hour
Weighted Average Emission Rate Limit	4.10 grams/hour		
7.5% of the weighted average emission rate limit	0.31		
Results Are Acceptable			

Wood Heater Test Data - EPA Method 5G

Run:	3
Manufacturer:	Monessen
Model:	Defiant 2N1 (NC)
Tracking No.:	1534
Project No.:	227-S-39-3
Test Date:	21-Apr-10
Beginning Clock Time:	12:12
Recording Interval:	10 min.
Total Sampling Time:	190 min.

Velocity Traverse Data							
	Pt.1	Pt.2	Pt.3	Pt.4	Pt.5	Pt.6	Pt.7
Initial dP	0.030	0.038	0.040	0.038	0.020	0.038	0.040
Initial Temp.	154	154	154	154	154	154	154

"H₂O

OMNI Equipment Numbers:

PM Control Module:			
Dilution Tunnel MW(dry):	29.00	lb/lb-mole	ft/sec.
Dilution Tunnel MW(wet):	28.56	lb/lb-mole	scfm
Dilution Tunnel H2O:	4.00	percent	scfm
Dilution Tunnel Static:	-0.144	"H ₂ O	0.1963 ft ²
Pilot Tube Cp:	0.99		
Meter Box Y Factor:	0.994 (1)	0.996 (2)	Fuel Moisture (dry basis %): 21.25
Barometric Pressure:	Begin	Middle	Average
	29.47	29.47	29.47
	"Hg	"Hg	Total Particulate (1): 3.8
			Total Particulate (2): 3.6

Elapsed Time	Particulate Sampling Data												Wood Heater Temperature Data, °F																		
	Gas Meter Cubic Feet (1)	Gas Meter Cubic Feet (2)	Sample Rate, cfm (1)	Sample Rate, cfm (2)	Orifice dH (1)	Orifice dH (2)	Meter oF (1)	Meter oF (2)	Meter Vac. In. Hg. (1)	Meter Vac. In. Hg. (2)	Dilution Tunnel Temp.	Dilution Tunnel dP	Pro. Rate (10%) (1)	Pro. Rate (10%) (2)	Scale Reading	Weight Change	Firebox Top	Firebox Bottom	Firebox Back	Firebox Left	Firebox Right	Catalyst Exit	Average Surface	Stack	Filter (1)	Filter (2)	Impinger exit (1)	Impinger exit (2)	Ambient	Draft In. H ₂ O	
0	680.834	108.225	0.00	0.00	79	80			154	0.035			23.6		669	218	335	357	346			385.0	507	65	71			75	0.060		
10	682.430	109.780	0.16	0.16	0.00	0.00	79	80			132	0.044	99	103	22.0	-1.55	539	216	327	312	314			341.6	524	65	71			73	0.068
20	684.065	111.298	0.16	0.15	0.00	0.00	79	80			140	0.045	101	100	19.9	-2.1	550	212	347	288	281			335.6	606	67	72			75	0.071
30	685.700	112.815	0.16	0.15	0.00	0.00	79	80			148	0.046	100	100	17.8	-2.1	571	206	370	301	264			342.4	633	68	74			73	0.074
40	687.300	114.310	0.16	0.15	0.00	0.00	79	80			148	0.046	98	98	15.4	-2.4	612	204	375	329	264			356.8	625	68	74			75	0.074
50	688.888	115.805	0.16	0.15	0.00	0.00	79	81			152	0.046	98	98	13.0	-2.45	661	197	377	351	267			370.6	653	69	75			73	0.074
60	690.480	117.290	0.16	0.15	0.00	0.00	80	81			155	0.046	98	98	10.7	-2.25	704	189	375	380	278			385.2	666	69	75			74	0.075
70	692.070	118.775	0.16	0.15	0.00	0.00	80	81			152	0.046	98	98	8.6	-2.1	708	195	371	399	291			392.8	642	68	75			74	0.075
80	693.673	120.269	0.16	0.15	0.00	0.00	80	81			148	0.046	98	98	6.8	-1.8	737	197	362	416	310			404.4	619	66	74			73	0.074
90	695.275	121.764	0.16	0.15	0.00	0.00	80	81			143	0.046	98	98	5.5	-1.3	755	192	352	424	311			406.8	583	66	74			74	0.072
100	696.880	123.265	0.16	0.15	0.00	0.00	80	82			137	0.045	99	98	4.3	-1.25	780	192	322	417	330			408.2	525	66	74			74	0.069
110	698.480	124.765	0.16	0.15	0.00	0.00	80	82			129	0.044	99	99	3.4	-0.9	764	188	278	404	350			396.8	495	68	73			75	0.064
120	700.090	126.260	0.16	0.15	0.00	0.00	80	82			125	0.040	104	103	2.6	-0.75	721	191	254	380	351			379.4	466	68	73			74	0.060
130	701.645	127.768	0.16	0.15	0.00	0.00	80	81			123	0.040	100	104	2.1	-0.5	677	190	239	359	352			363.4	456	70	73			75	0.059
140	703.200	129.260	0.16	0.15	0.00	0.00	80	81			120	0.040	100	102	1.7	-0.4	642	187	228	351	340			349.6	438	70	73			71	0.058
150	704.910	130.755	0.17	0.15	0.00	0.00	79	81			118	0.041	108	101	1.3	-0.45	619	193	219	334	332			339.4	425	70	73			74	0.057
160	706.515	132.260	0.16	0.15	0.00	0.00	80	81			116	0.041	101	102	0.8	-0.45	604	189	217	325	327			332.4	419	71	73			73	0.056
170	708.120	133.760	0.16	0.15	0.00	0.00	79	81			114	0.040	103	102	0.5	-0.35	595	188	206	314	327			326.0	412	71	72			73	0.055
180	709.730	135.260	0.16	0.15	0.00	0.00	79	81			113	0.040	103	102	0.1	-0.4	572	191	202	301	318			316.8	394	72	73			75	0.053
190	711.320	136.759	0.16	0.15	0.00	0.00	79	80			111	0.040	101	102	0.0	-0.0															

Final Laboratory Report - Method SG Dual Train
Dilution Tunnel Particulate Calculations

Client Name: Monessen
 Model: Defiant 2NI (NC)
 Project No.: 227-S-39-3
 Tracking No.: 1534

Equipment Numbers: _____

Run #: 3
 Train #: A
 Date: 04/21/10

Sample Component	Reagent	Filter # or Probe #	Weights		
			Final, mg	Tare, mg	Particulate, mg
A. Front filter catch	Filter	F541	118.7	116.5	2.2
B. Rear filter catch	Filter	F543	126.5	125.3	1.2
C. Probe catch	Probe	VC-2	76802.6	76802.2	0.4

Total Particulate, mg :	3.8
-------------------------	-----

Component	Equations:
A. Front filter catch	Final (mg) - Tare (mg) = Particulate, mg
B. Rear filter catch	Final (mg) - Tare (mg) = Particulate, mg
C. Probe catch	Final (mg) - Tare (mg) = Particulate, mg

Analyst: T. H. L. Date: 05/28/10


Final Laboratory Report - Method 5G Dual Train
Dilution Tunnel Particulate Calculations

Client Name:	Monessen	Equipment Numbers:		Run #:	3
Model:	Defiant 2N1 (NC)			Train #:	B
Project No.:	227-S-39-3			Date:	04/21/10
Tracking No.:	1534				

Sample Component	Reagent	Filter # or Probe #	Weights		
			Final, mg	Tare, mg	Particulate, mg
A. Front filter catch	Filter	F544	118.9	117.3	1.6
B. Rear filter catch	Filter	F545	121.3	120.7	0.6
C. Probe catch	Probe	VC-8	78261.0	78259.6	1.4

Total Particulate, mg :	3.6
-------------------------	-----

Component	Equations:
A. Front filter catch	Final (mg) - Tare (mg) = Particulate, mg
B. Rear filter catch	Final (mg) - Tare (mg) = Particulate, mg
C. Probe catch	Final (mg) - Tare (mg) = Particulate, mg

Analyst: Date: 05/28/10

STOVE TEMPERATURE TEST DATA - METHOD 5G

Page 1 of 1Client/Model: Hougen/Defiant 2N1(nc)Project #: 227-S-39-3Tracking #: 1534Date: 04/21/10Test Crew: TCRun #: 3OMNI Equipment ID #:

Preburn [] Test	Fuel	Weight	Delta	Stack	Ambient	Top	Bottom	Back	Left	Right	Flue	Actual: Coal Bed: <u>5.55 lbs</u> Data: <u>0</u> = <u>TEMPERATURES (°F)</u>	Catalyst
0	23.0	0	0.045	71	498	297	129	247	260	249	301		
10	20.65	1.85	0.050	74	414	323	161	234	241	249	306		
20	18.25	2.40	0.053	74	415	341	207	207	226	226	389		
30	16.00	2.25	0.055	74	445	341	209	140	245	245	521		
40	14.30	1.70	0.07	74	517	341	267	190	222	222	596		
50	10.75	3.55	0.08	74	553	339	330	226	242	242	673		
60	8.3	2.45	0.079	73	571	355	357	283	255	255	650		
70	5.85	2.45	0.074	73	610	399	367	351	215	215	650		
80	4.10	1.75	0.062	73	642	384	334	375	317	317	451		
90	17.70	+13.60	0.065	74	514	332	287	324	302	302	475		
00	16.25	1.45	0.071	74	484	295	254	289	280	280	540		
10	14.35	1.90	0.070	74	493	274	289	269	272	272	560		
20	11.50	2.85	0.080	74	613	250	330	270	285	285	658		
30	8.70	2.80	0.078	75	669	235	359	315	300	300	645		
40	6.65	2.05	0.076	75	707	225	372	348	316	316	644		
50	5.55	1.10	0.066	75	686	220	339	367	342	342	496		
60													
70													
80													
90													
AVG													

Technician signature: J. S.Date: 05/13/10

FUEL DATA

Client: MonogramModel: Defiant 2N1 (NC)Project #: 127-5317 Tracking #: 18-34Date: 04/21/10 Test Crew: TC Run #: 3

OMNI Equipment ID #:

FUEL LOAD PREPARED BY: Ralph G. / Measured moisture & dimensionsFUEL: DOUGLAS-FIR SPECIES, UNTREATED/AIR-DRIED, STANDARD GRADE OR BETTER,
DIMENSIONAL LUMBER.

PRE-BURN FUEL

MOISTURE CONTENT (METER -- DRY BASIS)

CALIBRATION: Cal Value (1) = 12% Actual Reading 12.0
 Cal Value (2) = 22% Actual Reading 22.0

Piece	Length	Readings	Type
1	6 ft	19.2	2x4
2	7.3 ft	19.3	2x4
3	ft		

Length of cut pieces: 33 x 8 ^{inches} 04/21/10Pre-Burn Fuel Average Moisture: 19.3Time (clock): 10115 Room Temperature (F): 74 Initials: TC

TEST FUEL

FUEL TYPE AND AMOUNT: 2 x 4 4 x 4 4CALCULATED LOAD WEIGHT: 20.3 - 24.9 ACTUAL LOAD WEIGHT: 23.55

(2 x 4)

(4 x 4)

Total

FUEL PIECE LENGTH: 21"

MOISTURE CONTENT (METER -- DRY BASIS)

PIECE	READINGS	TYPE
1	20.0	2x4
2	20.2	2x4
3	24.7	4x4
4	24.6	4x4
5		
6		
7		
8		
9		
10		

OVERALL TEST FUEL LOAD MOISTURE AVERAGE: 21.25Time (clock): 10115 Room Temperature (F): 74 Initials: TCTechnician signature: TCDate: 04/21/10

Run Notes

Client: Monessen
 Model: Defiant + ZN1 (Wc)

Project #: 227-39-2
 Tracking #: 1534


Run #: 3 Date: 04/21/10

Test Crew: TZ
 OMNI Equipment ID #(s):

PREBURN

DESCRIBE OR SKETCH AIR OR THERMOMSTAT SETTINGS BELOW:
 (SETTINGS MUST BE ACCURATE AND REPRODUCIBLE)

PRIMARY:



SECONDARY:

7

TERTIARY:

1/2 04/21/10


FAN:

highPREBURN SETTINGS AND ACTIVITIES

TIME	AIR (THERMO) CHANGES PRIMARY/SECONDARY/TERTIARY	FAN SETTING CHANGE	ADD FUEL + WT.	ADD FUEL - WT.	RAKE COAL	COMMENT
0	test settings					
45					x	
75					x	
150	start test		14.8		x	


TEST

TEST FUEL CONFIGURATION SKETCH
 (INDICATE VIEW ANGLE)



DESCRIBE OR SKETCH TEST SETTINGS BELOW:
 (SETTINGS MUST BE ACCURATE AND REPRODUCIBLE)

PRIMARY:



START UP PROCEDURES

BYPASS: open 1 minFUEL LOADING 1 minDOOR: open 1 minPRIMARY AIR: fully open

OTHER: _____

SECONDARY:

7

TERTIARY:

1/2

FAN:

highTechnician signature: T - C.R.Date: 05/13/10

4 - 31 OF 4 - 156

OMNI-Test Laboratories, Inc.

Supplemental Data EPA 5G/5H

Client: Monessen

Model: Defiant 2N1

Project #: 227-S-37-3 Tracking #: 1534

Date: 04/21/10 Run #: 3 Booth: 114

Test Crew: T2 Start Time: 12:12 Stop Time: 3:22

OMNI Equipment #(s): 05/13/10

Gas Analyzer Train Leak Check:

Stack:

Dilution Tunnel (Method 5G Only):

Initial: _____

Initial: _____

Final: _____

Final: _____

Calibrations: Span Gas CO₂: _____ O₂: _____ CO: _____ CO₂(DT): _____

Time	N ₂ Span						
O ₂							
CO ₂							
CO							
CO ₂ (DT)							

Stack Diameter (inches): 6

Air Velocity (ft/min): Initial: < 50 ft/min Final: < 50 ft/min

Scale Audit (lbs): Pretest: 10.00 Post Test: 10.00

Induced Draft: 0 %Smoke Capture: 100

Pitot Tube Leak Test: Pre: 0.0 Post: 0.0

Flue Pipe Cleaned Prior to First Test in Series: Date: 04/18/10 Initials: T2

	Initial	Middle	Ending
Pb (in/Hg)	<u>29.47</u>	<u>29.47</u>	<u>29.36</u> <u>29.47 cm</u>
Room Temp (°F)	<u>74.75 cm</u>	<u>77</u>	<u>78.73 cm</u>

Technician signature: T. L. H. Date: 05/13/10

Model: Defiant
Monessen Hearth Systems
P.O. Box 501
Bethel, VT 05032

Run 4

Run 4 – Explanation of Invalidation

Upon reviewing the data from Run 4 the morning following the run, I noticed that the average tunnel flow throughout the run was 125.1 cu.ft./min, although the initial tunnel flow was 137.8 cu.ft./min. These tunnel flows were calculated using data collected with a microtector. The discrepancy in tunnel flow was a red flag, indicating a potential problem with the data. The tunnel has an automatic flow controller which adjusts a damper based on a reading by a digital pressure transducer, so seeing such a large drop in flow over the run was out of the ordinary. Upon investigation of the data, substantial disagreements were found between the data recorded from microtector readings and the data logged from the digital pressure transducer readings. Based upon this data discrepancy the run was thrown out because there was no way to verify which tunnel flow (as read by the microtector, or as logged by the transducer) was more accurate. In all other runs at the Monessen lab on this appliance no such issue was documented.

Tom Christensen

 06/07/10

Wood Heater Test Data - EPA Method 5G

Manufacturer: Monessen
Model: Defiant 2N1 (NC)
Project No.: 227-S-39-3
Tracking No.: 1534
Run: 4
Test Date: 04/21/10

Burn Rate	1.22 kg/hr dry
Average Tunnel Temperature	92 degrees Fahrenheit
Average Gas Velocity in Dilution Tunnel - vs	11.8 feet/second
Average Gas Flow Rate in Dilution Tunnel - Qsd	7505.0 scfhour
Average Delta p	0.029 inches H2O
Average Delta H	0.00 Inches H2O
Total Time of Test	410 minutes

	AVERAGE	SAMPLE TRAIN 1	SAMPLE TRAIN 2
Total Sample Volume - Vm	62.99 cubic feet	64.84 cubic feet	81.13 cubic feet
Average Gas Meter Temperature	74 degrees Fahrenheit	73 degrees Fahrenheit	75 degrees Fahrenheit
Total Sample Volume (Standard Conditions) - Vmstd	80.8 dscf	62.6 dscf	59.0 dscf
Total Particulates - nm			
Particulate Concentration (dry-standard)	0.000088 grams/dscf	54.5 mg	52.2 mg
Particulate Emission Rate	6.59 grams/hour	0.00087 grams/dscf	0.00088 grams/dscf
Adjusted Emissions	8.70 grams/hour	6.53 grams/hour	6.64 grams/hour
Difference from Average		8.84 grams/hour	8.76 grams/hour
7.5% of the average emission rate			
Weighted Average Emission Rate Limit	0.65	0.06 grams/hour	0.06 grams/hour
7.5% of the weighted average emission rate limit	4.10 grams/hour		
	0.31		
Results Are Acceptable			

Wood Heater Test Data - EPA Method 5G

Run:	4
Manufacturer:	Monessen
Model:	Defiant 2N1 (NC)
Tracking No.:	1534
Project No.:	227-S-39-3
Test Date:	21-Apr-10
Beginning Clock Time:	18:36
Recording Interval:	10 min.
Total Sampling Time:	410 min.

Velocity Traverse Data							
	Pt.1	Pt.2	Pt.3	Pt.4	Pt.5	Pt.6	Pt.7
Initial dP	0.025	0.039	0.043	0.040	0.032	0.040	0.042
Initial Temp.	112	112	112	112	112	112	112

"H₂O

OMNI Equipment Numbers: _____

PM Control Module:			
Dilution Tunnel MW(dry):	29.00	lb/lb-mole	Tunnel Velocity: 11.80 ft/sec.
Dilution Tunnel MW(wet):	28.56	lb/lb-mole	Initial Tunnel Flow: 137.7 scfm
Dilution Tunnel H ₂ O:	4.00	percent	Average Tunnel Flow: 125.1 scfm
Dilution Tunnel Static:	-0.140	"H ₂ O	Tunnel Area: 0.1963 ft ²
Pitot Tube Cp:	0.99		Post-Test Leak Check (1): 0.000@5.0 cfm@"Hg
Meter Box Y Factor:	0.994 (1)	0.996 (2)	Post-Test Leak Check (2): 0.000@9.5 cfm@"Hg
Barometric Pressure:	Begin 29.37	Middle 29.36	Average 29.36 "Hg
	End 29.36	Total Particulate (1): 54.5	Total Particulate (2): 52.2

Elapsed Time	Particulate Sampling Data												Wood Heater Temperature Data, °F												Stack					
	Gas Meter Cubic Feet (1)	Gas Meter Cubic Feet (2)	Sample Rate, cfm (1)	Sample Rate, cfm (2)	Orifice dH (1)	Orifice dH (2)	Meter oF (1)	Meter oF (2)	Meter Vac. In. Hg. (1)	Meter Vac. In. Hg. (2)	Dilution Tunnel dP	Dilution Tunnel Temp.	Pro. Rate (10%) (1)	Pro. Rate (10%) (2)	Scale Reading	Weight Change	Firebox Top	Firebox Bottom	Firebox Back	Firebox Left	Firebox Right	Catalyst Exit	Average Surface	Stack	Filter (1)	Filter (2)	Impinger exit (1)	Impinger exit (2)	Ambient	Draft In. H ₂ O
0	711.375	136.790			0.00	0.00	75	75			112	0.037			22.1		456	298	218	263	272		301.4	278	74	73			70	0.045
10	713.035	138.335	0.17	0.15	0.00	0.00	75	75			98	0.032	102	101	21.5	-0.6	359	283	216	238	246		268.4	348	74	72			73	0.045
20	714.670	139.865	0.16	0.15	0.00	0.00	74	75			99	0.032	100	100	20.7	-0.8	309	257	220	207	227		244.0	383	73	72			70	0.049
30	716.295	141.382	0.16	0.15	0.00	0.00	74	75			103	0.032	100	99	19.9	-0.8	291	239	243	191	213		235.4	441	73	72			72	0.054
40	717.905	142.881	0.16	0.15	0.00	0.00	74	75			110	0.032	100	99	18.7	-1.2	332	230	272	185	207		245.2	458	73	72			72	0.059
50	719.515	144.380	0.16	0.15	0.00	0.00	74	75			109	0.032	100	99	17.4	-1.3	364	217	290	178	214		252.6	462	74	73			69	0.061
60	721.115	145.870	0.16	0.15	0.00	0.00	74	75			112	0.033	98	97	16.2	-1.25	408	212	288	184	221		262.6	462	75	74			71	0.061
70	722.718	147.363	0.16	0.15	0.00	0.00	74	75			113	0.032	100	99	14.7	-1.45	455	208	301	182	234		276.0	503	76	74			71	0.063
80	724.320	148.855	0.16	0.15	0.00	0.00	74	76			115	0.032	100	99	13.4	-1.35	468	201	309	193	253		284.8	494	76	74			69	0.065
90	725.915	150.355	0.16	0.15	0.00	0.00	74	76			115	0.032	99	99	12.1	-1.25	473	195	310	202	271		290.2	492	76	75			71	0.063
100	727.525	151.855	0.16	0.15	0.00	0.00	74	76			113	0.031	102	100	11.0	-1.15	489	192	303	203	294		296.2	455	76	75			73	0.060
110	729.125	153.355	0.16	0.15	0.00	0.00	74	76			106	0.031	101	100	9.9	-1.05	496	195	271	206	307		295.0	396	75	74			71	0.058
120	730.730	154.855	0.16	0.15	0.00	0.00	74	76			102	0.031	100	99	9.0	-0.9	498	191	236	212	316		290.6	377	74	73			71	0.055
130	732.324	156.360	0.16	0.15	0.00	0.00	74	76			99	0.031	100	100	8.2	-0.85	492	188	216	214	316		285.2	362	74	73			69	0.053
140	733.925	157.860	0.16	0.15	0.00	0.00	74	76			96	0.030	101	101	7.5	-0.7	498	188	207	210	314		283.4	340	73	72			71	0.049
150	735.520	159.370	0.16	0.15	0.00	0.00	74	76			95	0.030	101	101	6.9	-0.6	494	186	192	216	309		279.4	318	72	71			71	0.043
160	737.115	160.875	0.16	0.15	0.00	0.00	74	75			92	0.029	102	102	6.3	-0.55	484	185	177	218	294		271.6	302	73	72			70	0.045
170	738.710	162.385	0.16	0.15	0.00	0.00	73	75			90	0.029	102	103	5.6	-0.7	467	177	168	216	283		262.2	287	73	72			70	0.040
180	740.278	163.870	0.16	0.15	0.00	0.00	73	75			89	0.028	102	103	5.2	-0.4	456	177	160	214	270		255.4	272	73	72			70	0.038
190	741.846	165.357	0.16	0.15	0.00	0.00	73	75			88	0.028	102	103	4.7	-0.55														

Final Laboratory Report - Method 5G Dual Train
Dilution Tunnel Particulate Calculations

Client Name: Monessen
 Model: Defiant 2N1 (NC)
 Project No.: 227-S-39-3
 Tracking No.: 1534

Equipment Numbers: _____

Run #: 4
 Train #: A
 Date: 04/21/10

Sample Component	Reagent	Filter # or Probe #	Weights		
			Final, mg	Tare, mg	Particulate, mg
A. Front filter catch	Filter	F546	175.0	125.1	49.9
B. Rear filter catch	Filter	F547	118.5	116.5	2.0
C. Probe catch	Probe	VC-3	84566.3	84563.7	2.6

Total Particulate, mg :	54.5
-------------------------	------

Component	Equations:
A. Front filter catch	Final (mg) - Tare (mg) = Particulate, mg
B. Rear filter catch	Final (mg) - Tare (mg) = Particulate, mg
C. Probe catch	Final (mg) - Tare (mg) = Particulate, mg

Analyst: 

Date: 05/28/10

Final Laboratory Report - Method 5G Dual Train
Dilution Tunnel Particulate Calculations

Client Name: Monesson
 Model: Defiant 2N1 (NC)
 Project No.: 227-S-39-3
 Tracking No.: 1534

Equipment Numbers: _____

Run #: 4
 Train #: B
 Date: 04/21/10

Sample Component	Reagent	Filter # or Probe #	Weights		
			Final, mg	Tare, mg	Particulate, mg
A. Front filter catch	Filter	F548	171.6	121.3	50.3
B. Rear filter catch	Filter	F549	128.1	126.3	1.8
C. Probe catch	Probe	VC-6	76256.7	76256.6	0.1

Total Particulate, mg :	52.2
-------------------------	------

Component	Equations:
A. Front filter catch	Final (mg) - Tare (mg) = Particulate, mg
B. Rear filter catch	Final (mg) - Tare (mg) = Particulate, mg
C. Probe catch	Final (mg) - Tare (mg) = Particulate, mg

Analyst: L. H.Date: 05/28/10

STOVE TEMPERATURE TEST DATA - METHOD 5G

Page 1 of 1Client/Model: Moressem / Desert 2N1 (w) Project #: TG-2275.39.3 Tracking #: 1534Date: 04/21/10 Test Crew: TROMNI Equipment ID #:

Preburn Test	Coal Bed: 4.4 - 5.5				Actual: Coal Bed: 5.35							
	Fuel Weight	Delta Weight	Stack Draft	Ambient	Top	Bottom	Back	Left	Right	Flue	Catalyst	
Data:	0 =	TEMPERATURES (oF)									Range:	
Time												
0	15.54	0	0.065	74	807	443	143	307	231	485		
10	14.10	1.44	0.051	74	577	430	164	307	244	326		
20	12.65	1.45	0.048	71	481	412	167	277	236	306		
30	10.55	2.10	0.064	72	462	393	174	258	230	449		
40	8.35	2.20	0.067	71	432	353	266	256	234	501		
50	7.35	1.0	0.061	73	459	349	316	253	243	488		
60	6.45	0.9	0.062	71	479	338	291	267	252	465		
70	5.60	0.85	0.053	71	474	314	270	272	266	487		
80	5.35	0.75	0.049	72	470	305	242	274	270	352		
90												
00												
10												
20												
30												
40												
50												
60												
70												
80												
90												
Avg												

Technician signature: J. C. H.Date: 05/14/10

FUEL DATA

Client: MunessonModel: Defiant 2N1 (Nc)Project #: 222-5393 Tracking #: 1534Date: 04/21/10 Test Crew: TC Run #: 4

OMNI Equipment ID #:

FUEL LOAD PREPARED BY: Ralph G. - Moisture/Dimensions measured by TCFUEL: DOUGLAS-FIR SPECIES, UNTREATED, AIR-DRIED, STANDARD GRADE OR BETTER,
DIMENSIONAL LUMBER.

PRE-BURN FUEL

MOISTURE CONTENT (METER -- DRY BASIS)

CALIBRATION: Cal Value (1) = 12% Actual Reading 12.0
 Cal Value (2) = 22% Actual Reading 22.0

Piece	Length	Readings	Type
1	11 ft	20.3	2x4
2	11 ft	21.2	2x4
3	ft		

Length of cut pieces: 33x8 inchesPre-Burn Fuel Average Moisture: 20.5Time (clock): 4:20 Room Temperature (F): 74 Initials: TC

TEST FUEL

FUEL TYPE AND AMOUNT: 2x4 4x4 4
 CALCULATED LOAD WEIGHT: 22.61 ± 10% ACTUAL LOAD WEIGHT: 22.1 ^{Room 10/10}
 FUEL PIECE LENGTH: 21" 22.1 (2x4)
22.1 (4x4)
22.1 Total

MOISTURE CONTENT (METER -- DRY BASIS)

PIECE	READINGS	TYPE
1	20.2	2x4
2	20.2	2x4
3	20.9	2x4
4	20.2	2x4
5		
6		
7		
8		
9		
10		

OVERALL TEST FUEL LOAD MOISTURE AVERAGE: 20.7Time (clock): 5:10 Room Temperature (F): 76 Initials: TCTechnician signature: T. ChaffeyDate: 05/14/10

Run Notes

Client: Monessen

Model: Defiant 2N1 (NC)

Project #: ~~227-5~~²²⁷⁻⁵ 227-5-39-3

Tracking #: 1534

Run #: 4

Date: 04/21/10


Test Crew: T2

OMNI Equipment ID #(s):


PREBURN

DESCRIBE OR SKETCH AIR OR THERMOMSTAT SETTINGS BELOW:
 (SETTINGS MUST BE ACCURATE AND REPRODUCABLE)

PRIMARY:




SECONDARY:



TERTIARY:



FAN:




PREBURN SETTINGS AND ACTIVITIES

TIME	AIR (THERMO) CHANGES PRIMARY/SECONDARY/TERTIARY	FAN SETTING CHANGE	ADD FUEL + WT.	ADD FUEL - WT.	RAKE COAL	COMMENT
0	— test setting —					
25					X	
55				0.5 lbs	X	
70			0.5 lbs			
95	Start test				✓	

TEST

TEST FUEL CONFIGURATION SKETCH
 (INDICATE VIEW ANGLE)




START UP PROCEDURES

BYPASS: 1 mm
 FUEL LOADING 1 mm
 DOOR: 1 mm
 PRIMARY AIR: test setting @ 0 mm


OTHER: /

DESCRIBE OR SKETCH TEST SETTINGS BELOW:
 (SETTINGS MUST BE ACCURATE AND REPRODUCIBLE)

PRIMARY:




SECONDARY:



TERTIARY:



FAN:



Technician signature:

Date: 05/14/10

4-41 OF 4-156

Supplemental Data EPA 5G/5H

Client: MonessenModel: Defiant 2N1 (Nc)Project #: 227-S-39-3 Tracking #: 1534Date: 04/21/10 Run #: 4 Booth: VC-1ATest Crew: TZ Start Time: 4:09 Stop Time: 1:26 (A.M., 04/22/10)

OMNI Equipment #(s): _____

Gas Analyzer Train Leak Check:

Stack:

Dilution Tunnel (Method 5G Only):

Initial: _____

Initial: _____

Final: _____

Final: _____

Calibrations: Span Gas CO₂: _____ O₂: _____ CO: _____ CO₂(DT): _____

Time	N ₂ Span	N ₂ -Span	N ₂ Span				
O ₂							
CO ₂							
CO							
CO ₂ (DT)							

Stack Diameter (inches): 6Air Velocity (ft/min): Initial: < 50 ft/min Final: < 50 ft/minScale Audit (lbs): Pretest: 10.00 Post Test: 10.00Induced Draft: 0 %Smoke Capture: 100Pilot Tube Leak Test: Pre: 0.0 @ 3.0 Post: 0.0 @ 3.0Flue Pipe Cleaned Prior to First Test in Series: Date: 04/18/10 Initials: TZ

	Initial	Middle	Ending
Pb (in/Hg)	<u>29.37</u>	<u>29.36</u>	<u>29.33</u>
Room Temp (°F)	<u>73</u>	<u>71</u>	<u>73.5</u>

Technician signature: T. Chay Date: 05/14/10

Model: Defiant
Monessen Hearth Systems
P.O. Box 501
Bethel, VT 05032

Run 5

Wood Heater Test Data - EPA Method 5G

Manufacturer: Monessen
 Model: Defiant 2N1 (NC)
 Project No.: 227-S-39-3
 Tracking No.: 1534
 Run: 5
 Test Date: 04/22/10

Burn Rate	1.44 kg/hr dry
Average Tunnel Temperature	101 degrees Fahrenheit
Average Gas Velocity in Dilution Tunnel - vs	13.3 feet/second
Average Gas Flow Rate in Dilution Tunnel - Qsd	8305.3 dscf/hour
Average Delta p	0.037 inches H2O
Average Delta H	0.00 inches H2O
Total Time of Test	350 minutes

	AVERAGE	SAMPLE TRAIN 1	SAMPLE TRAIN 2
Total Sample Volume - Vm	54.11 cubic feet	58.77 cubic feet	51.46 cubic feet
Average Gas Meter Temperature	76 degrees Fahrenheit	75 degrees Fahrenheit	76 degrees Fahrenheit
Total Sample Volume (Standard Conditions) - Vmstd	52.0 dscf	54.6 dscf	49.4 dscf
Total Particulates - mn		5.4 mg	5.7 mg
Particulate Concentration (dry-standard)	0.00011 grams/dscf	0.00010 grams/dscf	0.00012 grams/dscf
Particulate Emission Rate	0.89 grams/hour	0.82 grams/hour	0.96 grams/hour
Adjusted Emissions	1.65 grams/hour	1.55 grams/hour	1.76 grams/hour
Difference from Average		0.10 grams/hour	0.10 grams/hour
7.5% of the average emission rate	0.12		
Weighted Average Emission Rate Limit	4.10 grams/hour		
7.5% of the weighted average emission rate limit	0.31		
Results Are Acceptable			

Wood Heater Test Data - EPA Method 5G

Run:	5
Manufacturer:	Monessen
Model:	Defiant 2N1 (NC)
Tracking No.:	1534
Project No.:	227-S-39-3
Test Date:	22-Apr-10
Beginning Clock Time:	12:30
Recording Interval:	10 min.
Total Sampling Time:	350 min.

Velocity Traverse Data							
Initial dP	Pt.1	Pt.2	Pt.3	Pt.4	Pt.5	Pt.6	Pt.7
Initial Temp.	106	106	106	106	106	106	106
"H2O							

OMNI Equipment Numbers: _____

PM Control Module:			
Dilution Tunnel MW(dry):	29.00	lb/lb-mole	
Dilution Tunnel MW(wet):	28.56	lb/lb-mole	
Dilution Tunnel H2O:	4.00	percent	
Dilution Tunnel Static:	-0.132	"H2O	
Pitot Tube Cp:	0.99		
Meter Box Y Factor:	0.994 (1)	0.996 (2)	
Barometric Pressure:	Begin	Middle	End
	29.32	29.32	29.32
Average			
Total Particulate (1):	5.4		
Total Particulate (2):	5.7		

Elapsed Time	Particulate Sampling Data												Wood Heater Temperature Data, °F												Stack					
	Gas Meter Cubic Feet (1)	Gas Meter Cubic Feet (2)	Sample Rate, cfm (1)	Sample Rate, cfm (2)	Orifice dH (1)	Orifice dH (2)	Meter oF (1)	Meter oF (2)	Meter Vac. In. Hg. (1)	Meter Vac. In. Hg. (2)	Dilution Tunnel Temp.	Dilution Tunnel dP	Pro. Rate (10%) (1)	Pro. Rate (10%) (2)	Scale Reading	Weight Change	Firebox Top	Firebox Bottom	Firebox Back	Firebox Left	Firebox Right	Catalyst Exit	Average Surface	Stack	Filter (1)	Filter (2)	Impinger exit (1)	Impinger exit (2)	Ambient	Draft In. H2O
0	776.355	198.045	0.00	0.00	76	76			106	0.035			22.2		489	285	229	272	255			306.0	326	72	75		72	0.050		
10	778.050	199.590	0.17	0.15	0.00	0.00	75	76			103	0.039	102	103	21.6	-0.65	372	270	228	241	235			269.2	380	72	72		72	0.051
20	779.700	201.085	0.17	0.15	0.00	0.00	75	76			107	0.038	101	101	20.6	-0.95	339	254	252	213	213			254.2	439	72	74		72	0.053
30	781.358	202.538	0.17	0.15	0.00	0.00	74	76			113	0.038	103	99	19.3	-1.35	378	239	291	202	204			262.8	480	74	74		72	0.057
40	782.965	204.025	0.16	0.15	0.00	0.00	75	76			115	0.038	99	102	17.9	-1.35	416	226	308	193	202			269.0	479	74	74		74	0.060
50	784.588	205.480	0.16	0.15	0.00	0.00	75	77			119	0.038	101	99	16.3	-1.6	458	215	317	193	206			277.8	510	76	76		72	0.064
60	786.200	206.945	0.16	0.15	0.00	0.00	76	76			122	0.040	98	98	14.7	-1.6	484	208	332	195	221			288.0	522	76	76		71	0.066
70	787.820	208.400	0.16	0.15	0.00	0.00	75	76			121	0.038	101	100	13.2	-1.55	494	202	336	200	234			293.2	516	76	76		71	0.066
80	789.430	209.865	0.16	0.15	0.00	0.00	75	77			120	0.038	100	100	11.7	-1.5	509	195	340	206	262			302.4	498	75	75		71	0.065
90	791.045	211.315	0.16	0.14	0.00	0.00	76	77			118	0.038	100	99	10.4	-1.25	546	195	325	210	279			311.0	487	75	75		73	0.064
100	792.658	212.792	0.16	0.15	0.00	0.00	76	77			115	0.037	101	102	9.4	-1.05	552	191	308	215	282			309.6	468	75	75		71	0.062
110	794.270	214.250	0.16	0.15	0.00	0.00	75	77			113	0.037	101	101	8.3	-1.1	563	189	295	219	288			310.8	453	75	75		73	0.060
120	795.880	215.708	0.16	0.15	0.00	0.00	76	77			112	0.038	99	99	7.4	-0.9	570	187	280	223	293			310.6	442	75	73		73	0.059
130	797.500	217.170	0.16	0.15	0.00	0.00	76	77			110	0.037	101	101	6.5	-0.85	572	187	271	226	295			310.2	432	74	76		72	0.058
140	799.110	218.635	0.16	0.15	0.00	0.00	76	78			107	0.037	100	100	5.8	-0.7	568	183	256	228	293			305.6	401	74	74		72	0.054
150	800.732	220.095	0.16	0.15	0.00	0.00	76	78			105	0.037	101	100	5.2	-0.6	523	181	241	230	293			293.6	395	74	74		72	0.053
160	802.350	221.568	0.16	0.15	0.00	0.00	76	78			103	0.037	100	100	4.7	-0.55	499	178	234	228	293			286.4	388	71	74		71	0.053
170	803.975	223.045	0.16	0.15	0.00	0.00	77	77			101	0.036	102	102	4.2	-0.5	488	178	228	230	293			283.4	375	73	73		71	0.052
180	805.585	224.505	0.16	0.15	0.00	0.00	76	77			99	0.037	99	99	3.8	-0.35	484	180	217	232	293			281.2	358	71	74		74	0.050
190	807.210	225.985	0.16	0.15	0.00	0.00	75	77			98	0.036	102	102	3.5	-0.35	479	178	208	232	293			278.0	340	71	71		71	0.050
200	808.825	227.																												

Final Laboratory Report - Method 5G Dual Train
Dilution Tunnel Particulate Calculations

Client Name: Monessen
 Model: Defiant 2N1 (NC)
 Project No.: 227-S-39-3
 Tracking No.: 1534

Equipment Numbers:

Run #: 5
 Train #: A
 Date: 04/22/10

Sample Component	Reagent	Filter # or Probe #	Weights		
			Final, mg	Tare, mg	Particulate, mg
A. Front filter catch	Filter	F550	120.8	116.3	4.5
B. Rear filter catch	Filter	F551	121.4	120.7	0.7
C. Probe catch	Probe	VC-4	79066.1	79065.9	0.2

Total Particulate, mg :	5.4
-------------------------	-----

Component	Equations:
A. Front filter catch	Final (mg) - Tare (mg) = Particulate, mg
B. Rear filter catch	Final (mg) - Tare (mg) = Particulate, mg
C. Probe catch	Final (mg) - Tare (mg) = Particulate, mg

Analyst: Date: 05/28/10

Final Laboratory Report - Method 5G Dual Train
Dilution Tunnel Particulate Calculations

Client Name: Monessen
 Model: Defiant 2N1 (NC)
 Project No.: 227-S-39-3
 Tracking No.: 1534

Equipment Numbers: _____
 Run #: 5
 Train #: B
 Date: 04/22/10

Sample Component	Reagent	Filter # or Probe #	Weights		
			Final, mg	Tare, mg	Particulate, mg
A. Front filter catch	Filter	F552	128.7	124.4	4.3
B. Rear filter catch	Filter	F553	120.2	119.7	0.5
C. Probe catch	Probe	VC-9	83354.0	83353.1	0.9

Total Particulate, mg :	<u>5.7</u>
-------------------------	------------

Component	Equations:
A. Front filter catch	Final (mg) - Tare (mg) = Particulate, mg
B. Rear filter catch	Final (mg) - Tare (mg) = Particulate, mg
C. Probe catch	Final (mg) - Tare (mg) = Particulate, mg

Analyst: Date: 05/28/10

STOVE TEMPERATURE TEST DATA - METHOD 5G

Page 1 of 1Client/Model: Monessen / Defiant ZN1 (PC) Project #: 227-S-34-3 Tracking #: 1534Date: 04/22/10 Test Crew: T Run #: 5

OMNI Equipment ID #:

Preburn Test Time	Fuel Weight [1]	Delta Weight	Stack Draft	Coal Bed: Data: 0 =				Range: 4.44 - 5.55			Actual: Coal Bed: 5.50
				Ambient	Top	Bottom	Back	Left	Right	Flue	
0	13.3 15.5	.8	0.045	79	458	376	158	313	226	320	
10	13.85	1.60	0.048	78	535	386	150	353	236	317	
20	12.15	1.70	0.045	78	458	378	157	311	226	302	
30	7.8 10.0	2.05	0.063	72	438	304	269	276	217	501	
40	8.16	1.94	0.065	72	447	319	207	280	218	472	
50	6.76	1.30	0.066	73	479	297	283	275	219	488	
60	6.31	0.55	0.057	71	485	286	273	275	230	414	
70	5.80	0.51	0.055	71	488	281	246	272	240	388	
80											
90											
00											
10											
20											
30											
40											
50											
60											
70											
80											
90											
Avg											

Technician signature: 1 - 125Date: 05/14/10

FUEL DATA

Client: MorescoModel: Defiant 2N1 (No)Project #: 22753 Tracking #: 1634Date: 04/22/10 Test Crew: TZ Run #: 5

OMNI Equipment ID #:

FUEL LOAD PREPARED BY: Ralph G. / Moisture / Dimensions measured by TZFUEL: DOUGLAS-FIR SPECIES, UNTREATED, AIR-DRIED, STANDARD GRADE OR BETTER,
DIMENSIONAL LUMBER.

PRE-BURN FUEL

MOISTURE CONTENT (METER -- DRY BASIS)

CALIBRATION: Cal Value (1) = 12% Actual Reading 12.0
 Cal Value (2) = 22% Actual Reading 22.0

Piece	Length	Readings	Type
1	10 ft	19.2	2x4
2	10 ft	18.1	2x4
3	ft		

Length of cut pieces: 30 x 8 inchesPre-Burn Fuel Average Moisture: 19.7Time (clock): 10:50 Room Temperature (F): 74 Initials: TZ

TEST FUEL

FUEL TYPE AND AMOUNT: 2 x 4 4 x 4 4CALCULATED LOAD WEIGHT: 22.75 +10% ACTUAL LOAD WEIGHT: 22.2 (2 x 4)FUEL PIECE LENGTH: 21" 22.2 (4 x 4) 22.2 Total

MOISTURE CONTENT (METER -- DRY BASIS)

PIECE	READINGS	TYPE
1	19.3	4x4
2	19.8	4x4
3	18.6	4x4
4	18.6	4x4
5		
6		
7		
8		
9		
10		

OVERALL TEST FUEL LOAD MOISTURE AVERAGE: 19.95Time (clock): 10:50 Room Temperature (F): 74 Initials: TZTechnician signature: T-Z Date: 05/14/10

Run Notes

Client: Monessen

Model: Defiant 2N1 (W)

Project #: 227-S-39-3

Tracking #: 1534

Run #: 5 Date: 04/22/10


Test Crew: TC

OMNI Equipment ID #(s):


PREBURN

DESCRIBE OR SKETCH AIR OR THERMOMSTAT SETTINGS BELOW:
 (SETTINGS MUST BE ACCURATE AND REPRODUCABLE)

PRIMARY:




SECONDARY:



TERTIARY:



FAN:




PREBURN SETTINGS AND ACTIVITIES

TIME	AIR (THERMO) CHANGES PRIMARY/SECONDARY/TERTIARY	FAN SETTING CHANGE	ADD FUEL + WT.	ADD FUEL - WT.	RAKE COAL	COMMENT
0	test setting					
15					x	
65	start test				x	

TEST

TEST FUEL CONFIGURATION SKETCH
 (INDICATE VIEW ANGLE)




START UP PROCEDURES

BYPASS: 50 sec open
 FUEL LOADING: 50 sec
 DOOR: 60 sec open
 PRIMARY AIR: test setting @ +0

OTHER: /

DESCRIBE OR SKETCH TEST SETTINGS BELOW:
 (SETTINGS MUST BE ACCURATE AND REPRODUCIBLE)

PRIMARY:



SECONDARY:



TERTIARY:



FAN:



Technician signature:

Date: 05/14/10

4 - 50 OF 4 - 155

OMNI-Test Laboratories, Inc.

Supplemental Data EPA 5G/5H

Client: Monessen

Model: Defiant 2N1 (NC)

Project #: 227-S-34-3 Tracking #: 1534

Date: 04/22/10 Run #: 5 Booth: N/A

Test Crew: TZ Start Time: 12:50 Stop Time: 6:40

OMNI Equipment #(s): Ending TZ 05/18/10

Gas Analyzer Train Leak Check:

Stack:

Dilution Tunnel (Method 5G Only):

Initial: _____

Initial: _____

Final: _____

Final: _____

Calibrations: Span Gas CO₂: _____ O₂: _____ CO: _____ CO₂(DT): _____

Time	N ₂ Span						
O ₂							
CO ₂							
CO							
CO ₂ (DT)							

Stack Diameter (inches): 6

Air Velocity (ft/min): Initial: <50 ft/min Final: <50 ft/min

Scale Audit (lbs): Pretest: 10.00 Post Test: 10.00

Induced Draft: 0 %Smoke Capture: 100

Pitot Tube Leak Test: Pre: 0.0 @ 3.0 Post: 0.0 @ 3.0

Flue Pipe Cleaned Prior to First Test in Series: Date: 04/18/10 Initials: TZ

	Initial	Middle	Ending
Pb (in/Hg)	29.32	29.31	29.32
Room Temp (°F)	75 72 or	72	71

Technician signature: T. Chesser Date: 05/14/10

Model: Defiant
Monessen Hearth Systems
P.O. Box 501
Bethel, VT 03032

Run 6

Wood Heater Test Data - EPA Method 5G

Manufacturer: Monessen
 Model: Defiant 2N1 (NC)
 Project No.: 227-S-39-3
 Tracking No.: 1534
 Run: 6
 Test Date: 04/23/10

Burn Rate	0.88 kg/hr dry
Average Tunnel Temperature	88 degrees Fahrenheit
Average Gas Velocity In Dilution Tunnel - vs	12.8 feet/second
Average Gas Flow Rate in Dilution Tunnel - Qsd	8222.1 dscf/hour
Average Delta p	0.035 Inches H2O
Average Delta H	0.00 Inches H2O
Total Time of Test	580 minutes

	AVERAGE	SAMPLE TRAIN 1	SAMPLE TRAIN 2
Total Sample Volume - Vm	89.20 cubic feet	93.21 cubic feet	85.20 cubic feet
Average Gas Meter Temperature	75 degrees Fahrenheit	74 degrees Fahrenheit	76 degrees Fahrenheit
Total Sample Volume (Standard Conditions) - Vmstd	86.3 dscf	90.2 dscf	82.4 dscf
Total Particulates - mn			
Particulate Concentration (dry-standard)	0.00027 grams/dscf	0.00026 grams/dscf	0.00028 grams/dscf
Particulate Emission Rate	2.20 grams/hour	2.13 grams/hour	2.28 grams/hour
Adjusted Emissions	3.61 grams/hour	3.41 grams/hour	3.60 grams/hour
Difference from Average			
7.5% of the average emission rate	0.26	0.09 grams/hour	0.09 grams/hour
Weighted Average Emission Rate Limit	4.10 grams/hour		
7.5% of the weighted average emission rate limit	0.31		
Results Are Acceptable			

Wood Heater Test Data - EPA Method 5G

Run:	6
Manufacturer:	Monessen
Model:	Defiant 2N1 (NC)
Tracking No.:	1534
Project No.:	227-S-39-3
Test Date:	23-Apr-10
Beginning Clock Time:	10:49
Recording Interval:	10 min.
Total Sampling Time:	580 min.

Velocity Traverse Data							
	Pt.1	Pt.2	Pt.3	Pt.4	Pt.5	Pt.6	Pt.7
Initial dP	0.022	0.036	0.040	0.037	0.025	0.038	0.038
Initial Temp.	104	104	104	104	104	104	104

OMNI Equipment Numbers:

PM Control Module:				Signature/Date: <i>J R 6/4/10</i>
Dilution Tunnel MW(dry):	29.00	lb/lb-mole	Tunnel Velocity:	12.77 ft/sec.
Dilution Tunnel MW(wet):	28.36	lb/lb-mole	Int'l Tunnel Flow:	132.5 scfm
Dilution Tunnel H2O:	4.00	percent	Average Tunnel Flow:	137.0 scfm
Dilution Tunnel Static:	-0.132	"H2O	Tunnel Area:	0.1963 ft ²
Pitot Tube Cp:	0.99		Post-Test Leak Check (1):	.001@5 cfm@"Hg
Meter Box Y Factor:	0.994 (1)	0.996 (2)	Post-Test Leak Check (2):	.001@9 cfm@"Hg
Barometric Pressure:	Begin	Middle	End	Fuel Moisture (dry basis %): 20.1
	29.47	29.47	29.47	Total Particulate (1): 23.4
				Total Particulate (2): 22.8

Elapsed Time	Particulate Sampling Data												Wood Heater Temperature Data, °F												Stack					
	Gas Meter Cubic Feet (1)	Gas Meter Cubic Feet (2)	Sample Rate, cfm (1)	Sample Rate, cfm (2)	Orifice dH (1)	Orifice dH (2)	Meter oF (1)	Meter oF (2)	Meter Vac. In. Hg. (1)	Meter Vac. In. Hg. (2)	Dilution Tunnel dP	Dilution Tunnel Temp.	Pro. Rate (10%) (1)	Pro. Rate (10%) (2)	Scale Reading	Weight Change	Firebox Top	Firebox Bottom	Firebox Back	Firebox Left	Firebox Right	Catalyst Exit	Averaging Surface	Stack	Filter (1)	Filter (2)	Impinger exit (1)	Impinger exit (2)	Ambient	Draft In. H2O
0	833.180	249.545			0.00	0.00	76	77			104	0.034			22.4		455	288	286	292	305		325.2	294	73	86			73	0.040
10	834.855	251.085	0.17	0.15	0.00	0.00	76	76			94	0.037	102	103	22.1	-0.3	353	277	260	266	279		287.0	279	73	82			75	0.040
20	836.510	252.595	0.17	0.15	0.00	0.00	76	76			93	0.037	101	101	21.7	-0.45	298	261	255	240	251		261.0	309	73	81			73	0.049
30	838.145	254.090	0.16	0.15	0.00	0.00	75	76			97	0.036	102	102	21.0	-0.7	272	244	265	218	231		246.0	367	72	83			72	0.053
40	839.763	255.579	0.16	0.15	0.00	0.00	75	76			100	0.039	97	98	20.2	-0.75	271	230	291	206	217		243.0	388	71	82			69	0.054
50	841.380	257.050	0.16	0.15	0.00	0.00	75	76			102	0.039	97	97	19.2	-1	271	215	314	197	210		241.4	405	71	84			73	0.055
60	842.990	258.515	0.16	0.15	0.00	0.00	75	76			105	0.038	98	98	18.2	-1	281	208	323	193	214		243.8	414	71	81			73	0.056
70	844.615	259.980	0.16	0.15	0.00	0.00	75	77			105	0.040	97	95	17.2	-1	305	201	329	188	214		247.4	416	73	84			71	0.056
80	846.215	261.445	0.16	0.15	0.00	0.00	75	76			105	0.040	95	95	16.2	-1	342	188	329	190	223		254.4	422	73	85			73	0.060
90	847.825	262.910	0.16	0.15	0.00	0.00	75	76			109	0.039	97	97	15.0	-1.2	397	186	338	195	230		269.2	451	73	86			71	0.060
100	849.430	264.374	0.16	0.15	0.00	0.00	75	76			107	0.040	96	95	14.0	-1.05	431	182	348	201	242		280.8	433	73	83			73	0.059
110	851.043	265.848	0.16	0.15	0.00	0.00	75	77			106	0.038	98	98	12.9	-1.05	452	179	344	210	259		288.8	431	73	83			71	0.060
120	852.659	267.334	0.16	0.15	0.00	0.00	75	76			104	0.037	100	100	11.9	-1	485	179	337	214	274		297.8	400	72	83			72	0.058
130	854.275	268.820	0.16	0.15	0.00	0.00	75	76			101	0.035	102	103	11.1	-0.85	489	179	313	220	296		299.4	374	72	85			72	0.055
140	855.890	270.300	0.16	0.15	0.00	0.00	75	76			99	0.035	102	102	10.3	-0.75	483	179	296	227	307		298.4	355	72	83			72	0.052
150	857.525	271.795	0.16	0.15	0.00	0.00	75	76			95	0.036	102	102	9.7	-0.6	480	179	272	231	313		295.0	333	70	83			72	0.049
160	859.090	273.240	0.16	0.14	0.00	0.00	75	76			94	0.036	97	98	9.2	-0.5	463	179	256	233	313		288.8	322	70	83			72	0.045
170	860.703	274.718	0.16	0.15	0.00	0.00	75	76			93	0.035	101	102	8.7	-0.55	443	179	244	233	311		282.0	322	70	83			72	0.045
180	862.310	276.192	0.16	0.15	0.00	0.00	75	76			92	0.036	100	100	8.1	-0.6	434	177	248	230	302		278.2	319	70	83			72	0.045
190	863.923	277.661	0.16	0.15	0.00	0.00	75	76			92	0.034</																		

Wood Heater Test Data - EPA Method 5G

Run:	6
Manufacturer:	Monessen
Model:	Defiant 2NI (NC)
Tracking No.:	1534
Project No.:	227-S-39-3
Test Date:	23-Apr-10
Beginning Clock Time:	10:49
Recording Interval:	10 min.
Total Sampling Time:	580 min.

Velocity Traverse Data							
Shaded	Pt.1	Pt.2	Pt.3	Pt.4	Pt.5	Pt.6	Pt.7
Initial dP	0.022	0.036	0.040	0.037	0.025	0.038	0.036
Initial Temp.	104	104	104	104	104	104	104

°H₂O

OMNI Equipment Numbers: _____

PM Control Module:			
Dilution Tunnel MW(dry):	29.00	lb/lb-mole	Tunnel Velocity: 12.77 ft/sec.
Dilution Tunnel MW(wet):	28.56	lb/lb-mole	Initial Tunnel Flow: 132.5 scfm
Dilution Tunnel H ₂ O:	4.00	percent	Average Tunnel Flow: 137.0 scfm
Dilution Tunnel Static:	-0.132	"H ₂ O	Tunnel Area: 0.1963 ft ²
Pitot Tube Cp:	0.99		Post-Test Leak Check (1): .001@95 cfm@"Hg
Meter Box Y Factor:	0.994 (1)	0.996 (2)	Post-Test Leak Check (2): .001@99 cfm@"Hg
Barometric Pressure:	Begin	Middle	Fuel Moisture (dry basis %): 20.1
	29.47	29.47	Total Particulate (1): 23.4
	29.47	29.47	Total Particulate (2): 22.8

Elapsed Time	Particulate Sampling Data												Wood Heater Temperature Data, °F												Stack				
	Gas Meter Cubic Feet (1)	Gas Meter Cubic Feet (2)	Sample Rate, cfm (1)	Sample Rate, cfm (2)	Orifice dH (1)	Orifice dH (2)	Meter oF (1)	Meter oF (2)	Meter Vac. In. Hg. (1)	Meter Vac. In. Hg. (2)	Dilution Tunnel Temp.	Dilution Tunnel dP	Pro. Rate (10%) (1)	Pro. Rate (10%) (2)	Scale Reading	Weight Change	Firebox Top	Firebox Bottom	Firebox Back	Firebox Left	Firebox Right	Catalyst Exit	Average Surface	Stack	Filter (1)	Filter (2)	Impinger exit (1)	Impinger exit (2)	Ambient
430	902,362	312,888	0.16	0.14	0.00	0.00	74	76			81	0.033	103	100	1.7	-0.15	328	153	134	200	211		205.2	190	66	78		70	0.027
440	903,965	314,315	0.16	0.14	0.00	0.00	74	76			81	0.033	103	100	1.6	-0.1	322	149	134	203	207		203.0	186	66	79		70	0.026
450	905,660	315,775	0.17	0.15	0.00	0.00	74	76			79	0.033	109	102	1.4	-0.15	319	149	129	200	207		200.8	181	65	78		70	0.026
460	907,213	317,238	0.16	0.15	0.00	0.00	74	75			79	0.033	99	103	1.2	-0.2	315	149	127	196	207		198.8	176	65	78		70	0.025
470	908,765	318,700	0.16	0.15	0.00	0.00	73	75			79	0.034	98	101	1.1	-0.1	315	151	140	198	213		203.4	177	66	78		70	0.025
480	910,375	320,160	0.16	0.15	0.00	0.00	73	75			79	0.034	102	101	1.0	-0.15	310	148	151	202	215		205.2	174	65	78		69	0.025
490	912,070	321,620	0.17	0.15	0.00	0.00	73	75			78	0.033	109	102	0.9	-0.1	308	148	161	200	215		206.4	172	65	78		69	0.025
500	913,585	323,190	0.15	0.16	0.00	0.00	73	74			78	0.032	99	112	0.8	-0.1	306	148	161	200	213		205.6	170	65	78		69	0.025
510	915,240	324,580	0.17	0.14	0.00	0.00	73	74			77	0.034	104	96	0.6	-0.15	301	145	163	199	206		202.8	167	64	77		71	0.023
520	916,770	325,995	0.15	0.14	0.00	0.00	73	74			77	0.034	97	98	0.5	-0.1	294	143	163	201	201		200.4	165	65	77		69	0.022
530	918,381	327,460	0.16	0.15	0.00	0.00	73	74			77	0.033	103	103	0.4	-0.1	286	141	163	197	201		197.6	160	64	77		69	0.021
540	919,985	328,971	0.16	0.15	0.00	0.00	73	74			77	0.033	103	106	0.4	-0.05	279	139	161	195	195		193.8	161	65	77		69	0.021
550	921,585	330,371	0.16	0.14	0.00	0.00	73	74			77	0.033	102	98	0.3	-0.1	277	141	158	193	195		192.8	158	66	77		71	0.021
560	923,185	331,840	0.16	0.15	0.00	0.00	73	74			78	0.033	103	103	0.2	-0.1	273	144	156	193	197		192.6	156	67	77		71	0.020
570	924,885	333,385	0.17	0.15	0.00	0.00	73	74			78	0.034	107	107	0.1	-0.1	266	145	154	190	195		190.0	154	66	77		71	0.020
580	926,385	334,744	0.15	0.14	0.00	0.00	73	74			78	0.034	95	94	0.0	-0.05	260	143	154	186	188		186.2	152	67	77		71	0.020
Avg/Total	93,205	85,199	0.16	0.15	0.00	0.00	74.24	75.68			87.76	0.035	100.81	100.81								139		68.20	80.85	#DIV/0!	#DIV/0!	0.037	

Final Laboratory Report - Method 5G Dual Train
Dilution Tunnel Particulate Calculations

Client Name: Monessen
 Model: Defiant 2N1 (NC)
 Project No.: 227-S-39-3
 Tracking No.: 1534

Equipment Numbers:

Run #: 6
 Train #: A
 Date: 04/23/10

Sample Component	Reagent	Filter # or Probe #	Weights		
			Final, mg	Tare, mg	Particulate, mg
A. Front filter catch	Filter	F554	146.7	125.3	21.4
B. Rear filter catch	Filter	F555	117.4	116.3	1.1
C. Probe catch	Probe	VC-1	86785.7	86784.8	0.9

Total Particulate, mg :	23.4
-------------------------	------

Component	Equations:
A. Front filter catch	Final (mg) - Tare (mg) = Particulate, mg
B. Rear filter catch	Final (mg) - Tare (mg) = Particulate, mg
C. Probe catch	Final (mg) - Tare (mg) = Particulate, mg

Analyst: T. Clark Date: 05/28/10

**Final Laboratory Report - Method 5G Dual Train
Dilution Tunnel Particulate Calculations**

Client Name: Monessen
 Model: Defiant 2N1 (NC)
 Project No.: 227-S-39-3
 Tracking No.: 1534

Equipment Numbers:

Run #: 6
 Train #: B
 Date: 04/23/10

Sample Component	Reagent	Filter # or Probe #	Weights		
			Final, mg	Tare, mg	Particulate, mg
A. Front filter catch	Filter	F556	141.8	121.2	20.6
B. Rear filter catch	Filter	F557	126.7	125.7	1.0
C. Probe catch	Probe	VC-5	76855.7	76854.5	1.2

Total Particulate, mg :	22.8
-------------------------	------

Component	Equations:
A. Front filter catch	Final (mg) - Tare (mg) = Particulate, mg
B. Rear filter catch	Final (mg) - Tare (mg) = Particulate, mg
C. Probe catch	Final (mg) - Tare (mg) = Particulate, mg

Analyst: Date: 05/23/10

STOVE TEMPERATURE TEST DATA - METHOD 5G

Page 1 of 1Client/Model: Moenessan / Defiant ZN1 (Hc) Project #: 2275-39-3 Tracking #: 1534Date: 04/23/10 Test Crew: T2OMNI Equipment ID #: 05/24/10

Preburn Test	Coal Bed: <u>4.69 lbs</u> Data: <u>0 =</u>				Range: <u>4.48- 5.60 lbs</u> TEMPERATURES (OF)				Actual: Coal Bed:		
	Time	Fuel Weight	Delta Weight	Stack Draft	Ambient	Top	Bottom	Back	Left	Right	Flue
0	16.0	.05	0.063	73	722	385	171	259	257	431	
10	14.55	1.45	0.015	73	514	379	173	273	273	275	
20	13.75	0.80	0.039	74	432	360	176	262	262	246	
30	12.80	0.95	0.053	74	400	345	172	250	248	378	
40	10.95	1.85	0.063	74	345	309	261	241	231	453	
50	9.45	1.50	0.067	77	378	291	352	242	237	500	
60	8.05	1.40	0.064	75	429	282	397	249	243	483	
70	7.15	0.90	0.102	76	460	286	399	258	256	693	
80	5.80	1.35	0.06	74	478	284	406	276	282	439	
90	5.40	0.40	0.051	77	467	281	367	289	294	372	
00	5.20	0.20	0.045	77	468	283	325	290	301	320	
10											
20											
30											
40											
50											
60											
70											
80											
90											
AVG											

Technician signature: 1-2-2Date: 05/18/10Date: 05/18/10

FUEL DATA

Client: MonessenModel: Defiant 2 NI (NC)Project #: 2275373 Tracking #: 1534Date: 04/23/10 Test Crew: 72 Run #: 6OMNI Equipment ID #: MHS/109 (Monessen moisture meter)FUEL LOAD PREPARED BY: Ralph G. - Moisture/Dimensions measured by TCFUEL: DOUGLAS-FIR SPECIES, UNTREATED, AIR-DRIED, STANDARD GRADE OR BETTER,
DIMENSIONAL LUMBER.

PRE-BURN FUEL

MOISTURE CONTENT (METER -- DRY BASIS)

CALIBRATION: Cal Value (1) = 12% Actual Reading 12.0
 Cal Value (2) = 22% Actual Reading 22.0

Piece	Length	Readings	Type
1	9 ft	20.7	2x4
2	9 ft	22.5	2x4
3	ft	22.1	20.3

Length of cut pieces: 27 x 8 inchesPre-Burn Fuel Average Moisture: 20.4Time (clock): 8:30 Room Temperature (F): 74 Initials: TC

TEST FUEL

FUEL TYPE AND AMOUNT: 2 x 4 4 x 4 4CALCULATED LOAD WEIGHT: 22.75 + 10% ACTUAL LOAD WEIGHT: 22.4 (2 x 4)FUEL PIECE LENGTH: 21" 22.4 (4 x 4)
Total 22.4

MOISTURE CONTENT (METER -- DRY BASIS)

PIECE	READINGS	TYPE
1	18.6	19.7
2	18.6	19.3
3	20.1	20.3
4	20.3	21.1
5		
6		
7		
8		
9		
10		

OVERALL TEST FUEL LOAD MOISTURE A VERAGE: 20.1Time (clock): 8:45 Room Temperature (F): 74 Initials: TCTechnician signature: T. Clark Date: 05/18/10

Run Notes

Client: Manessen
 Model: Defiant 2NI (NC)
 Project #: 227-S-34-3
 Tracking #: 1534

Run #: 6 Date: 04/27/10


Test Crew: T2

OMNI Equipment ID #(s): _____


PREBURN

DESCRIBE OR SKETCH AIR OR THERMOMSTAT SETTINGS BELOW:
 (SETTINGS MUST BE ACCURATE AND REPRODUCABLE)


PRIMARY:



SECONDARY:



TERTIARY:




FAN:

PREBURN SETTINGS AND ACTIVITIES

TIME	AIR (THERMO) CHANGES PRIMARY/SECONDARY/TERTIARY	FAN SETTING CHANGE	ADD FUEL + WT.	ADD FUEL - WT.	RAKE COAL	COMMENT
0.	test setting				x	
45 4/27/10					x	
70 70 min 45 sec					x	
106	start test				x	

TEST

TEST FUEL CONFIGURATION SKETCH
 (INDICATE VIEW ANGLE)


START UP PROCEDURES

BYPASS: 1 min
 FUEL LOADING 50 sec
 DOOR: 1 min
 PRIMARY AIR: test setting @ T=0


OTHER: _____

DESCRIBE OR SKETCH TEST SETTINGS BELOW:
 (SETTINGS MUST BE ACCURATE AND REPRODUCIBLE)

PRIMARY:



SECONDARY:



TERTIARY:



FAN:



Technician signature: T. J. H. Date: 05/18/10

4-60 OF 4-158

OMNI-Test Laboratories, Inc.

Supplemental Data EPA 5G/5H

Client: Monessen

Model: Defiant 2N1 (NC)

Project #: 227-S-34-3 Tracking #: 1534

Date: 04/23/10 Run #: 6 Booth: N/A

Test Crew: T2 Start Time: 10:49 Stop Time: 8:29

OMNI Equipment #(s):

Gas Analyzer Train Leak Check:

Stack:

Dilution Tunnel (Method 5G Only):

Initial: _____

Initial: _____

Final: _____

Final: _____

Calibrations: Span Gas CO₂ O₂ CO CO₂(DT): _____

Time	N ₂ Span						
O ₂							
CO ₂							
CO							
CO ₂ (DT)							

Stack Diameter (inches): 6

Air Velocity (ft/min): Initial: <50 ft/min Final: <50 ft/min

Scale Audit (lbs): Pretest: 10,00 Post Test: 10,00

Induced Draft: 0.0 %Smoke Capture: 100

Pitot Tube Leak Test: Pre: 0.0 @ 3.0 Post: 0.0 @ 3.0

Flue Pipe Cleaned Prior to First Test in Series: Date: 04/18/10 Initials: T2

	Initial	Middle	Ending
Pb (in/Hg)	<u>29.46</u>	<u>29.50</u>	<u>29.58</u>
Room Temp (°F)	<u>73</u>	<u>72</u>	<u>70</u>

Technician signature: T. Chastain Date: 05/18/10

Wood Heater Test Data - EPA Method 5G

Manufacturer: Monessen
 Model: Defiant 2N1
 Project No.: 227-S-39-3
 Tracking No.: 1534
 Run: 7
 Test Date: 04/24/10

Burn Rate	1.00 kg/hr dry
Average Tunnel Temperature	97 degrees Fahrenheit
Average Gas Velocity In Dilution Tunnel - vs	13.4 feet/second
Average Gas Flow Rate in Dilution Tunnel - Qsd	8532.1 dscf/hour
Average Delta p	0.038 inches H2O
Average Delta H	0.00 inches H2O
Total Time of Test	520 minutes

	AVERAGE	SAMPLE TRAIN 1	SAMPLE TRAIN 2
Total Sample Volume - Vin	79.61 cubic feet	83.87 cubic feet	75.35 cubic feet
Average Gas Meter Temperature	76 degrees Fahrenheit	76 degrees Fahrenheit	77 degrees Fahrenheit
Total Sample Volume (Standard Conditions) - Vinstd	77.3 dscf	81.4 dscf	73.1 dscf
Total Particulates - mn		5.3 mg	4.4 mg
Particulate Concentration (dry-standard)	0.00006 grams/dscf	0.00007 grams/dscf	0.00006 grams/dscf
Particulate Emission Rate	0.53 grams/hour	0.56 grams/hour	0.51 grams/hour
Adjusted Emissions	1.08 grams/hour	1.12 grams/hour	1.05 grams/hour
Difference from Average		0.04 grams/hour	0.04 grams/hour
7.5% of the average emission rate	0.08		
Weighted Average Emission Rate Limit	4.10 grams/hour		
7.5% of the weighted average emission rate limit	0.31		

Results Are Acceptable

Wood Heater Test Data - EPA Method 5G

Run:	7
Manufacturer:	Monessen
Model:	Defiant 2N1
Tracking No.:	1534
Project No.:	227-S-39-3
Test Date:	24-Apr-10
Beginning Clock Time:	08:53
Recording Interval:	10 min.
Total Sampling Time:	520 min.

Velocity Traverse Data							
	Pt.1	Pt.2	Pt.3	Pt.4	Pt.5	Pt.6	Pt.7
Initial dP	0.028	0.042	0.044	0.039	0.027	0.042	0.044
Initial Temp.	97	97	97	97	97	97	97

"H₂O

OMNI Equipment Numbers: _____

PM Control Module:			
Dilution Tunnel MW(dry):	29.00	lb/lb-mole	Tunnel Velocity: 13.38 ft/sec.
Dilution Tunnel MW(wet):	28.56	lb/lb-mole	Intial Tunnel Flow: 142.5 scfm
Dilution Tunnel H ₂ O:	4.00	percent	Average Tunnel Flow: 142.2 scfm
Dilution Tunnel Static:	-0.144	"H ₂ O	Tunnel Area: 0.1963 ft ²
Pitot Tube Cp:	0.99		Post-Test Leak Check (1): 0.0@5 cfm@Hg
Meter Box Y Factor:	0.994	(1)	Post-Test Leak Check (2): 0.0@9 cfm@Hg
Barometric Pressure:	Begin	Middle	Fuel Moisture (dry basis %): 19.27
	29.76	29.6	Total Particulate (1): 5.3
	29.58	29.65	Total Particulate (2): 4.4

Elapsed Time	Particulate Sampling Data												Wood Heater Temperature Data, °F												Stack				
	Gas Meter Cubic Feet (1)	Gas Meter Cubic Feet (2)	Sample Rate, cfm (1)	Sample Rate, cfm (2)	Orifice dH (1)	Orifice dH (2)	Meter of (1)	Meter of (2)	Meter Vac. In. Hg. (1)	Meter Vac. In. Hg. (2)	Dilution Tunnel dP	Dilution Tunnel Temp.	Pro. Rate (10%) (1)	Pro. Rate (10%) (2)	Scale Reading	Weight Change	Firebox Top	Firebox Bottom	Firebox Back	Firebox Left	Firebox Right	Catalyst Exit	Average Surface	Stack	Filter (1)	Filter (2)	Impinger exit (1)	Impinger exit (2)	Ambient
0	926.540	334.883			0.00	0.00	69	70			97	0.039			22.7		429	290	340	262	305		325.2	316	73	75		66	0.056
10	928.140	336.383	0.16	0.15	0.00	0.00	69	70			99	0.039	100	105	22.0	-0.75	344	277	336	247	281		297.0	357	71	73		66	0.057
20	929.792	337.860	0.17	0.15	0.00	0.00	69	70			100	0.038	105	104		-21.95	306	265	352	228	256		281.4	397	72	72		67	0.058
30	931.371	339.262	0.16	0.14	0.00	0.00	70	71			104	0.037	102	101	20.2	20.15	293	256	369	215	241		274.8	428	72	72		68	0.060
40	932.992	340.738	0.16	0.15	0.00	0.00	70	72			106	0.038	103	105	19.0	-1.15	307	246	383	210	233		275.8	448	72	72		68	0.060
50	934.600	342.182	0.16	0.14	0.00	0.00	71	72			110	0.038	103	103	17.8	-1.2	327	231	394	207	229		277.6	459	72	72		68	0.063
60	936.205	343.625	0.16	0.14	0.00	0.00	71	73			112	0.037	104	104	16.6	-1.25	351	223	403	208	227		282.4	466	73	73		69	0.065
70	937.815	344.880	0.16	0.13	0.00	0.00	71	73			113	0.038	103	89	15.3	-1.3	386	219	412	210	232		291.8	471	73	73		69	0.065
80	939.421	346.528	0.16	0.16	0.00	0.00	72	73			115	0.037	104	119	13.9	-1.4	443	215	417	219	239		306.6	477	74	74		72	0.067
90	941.034	347.983	0.16	0.15	0.00	0.00	72	74			115	0.038	103	103	12.5	-1.4	489	211	419	228	248		319.0	473	74	74		70	0.065
100	942.634	349.440	0.16	0.15	0.00	0.00	73	74			114	0.039	101	102	11.3	-1.2	513	205	416	240	257		326.2	466	75	75		71	0.066
110	944.240	350.898	0.16	0.15	0.00	0.00	73	74			113	0.039	101	102	10.1	-1.2	518	208	408	249	269		330.4	453	75	75		71	0.067
120	945.852	352.355	0.16	0.15	0.00	0.00	73	75			112	0.040	100	101	9.0	-1.05	503	204	395	256	275		326.6	442	75	75		71	0.063
130	947.463	353.820	0.16	0.15	0.00	0.00	73	75			111	0.038	102	104	7.9	-1.1	499	204	389	265	284		328.2	432	76	76		72	0.063
140	949.073	355.280	0.16	0.15	0.00	0.00	74	76			108	0.039	101	101	7.1	-0.85	510	205	371	272	291		329.8	402	74	74		72	0.059
150	950.682	356.736	0.16	0.15	0.00	0.00	74	76			105	0.038	102	102	6.4	-0.65	498	205	350	276	298		325.4	372	74	74		72	0.055
160	952.299	358.200	0.16	0.15	0.00	0.00	74	76			102	0.037	103	104	5.9	-0.55	494	201	322	277	298		318.4	350	75	73		71	0.053
170	953.907	359.658	0.16	0.15	0.00	0.00	74	76			100	0.036	104	105	5.4	-0.5	488	199	305	277	299		313.6	338	73	73		71	0.050
180	955.526	361.124	0.16	0.15	0.00	0.00	74	76			98	0.038	102	102	5.0	-0.35	479	197	288	275	299		307.6	327	73	71		71	0.050
190	957.145	362.593	0.16	0.15	0.00	0.00	74	76			96	0.037	103	104	4.7	-0.35	468	195	275	275	295</td								

Wood Heater Test Data - EPA Method 5G

Run:	7
Manufacturer:	Monessen
Model:	Defiant 2N1
Tracking No.:	1534
Project No.:	227-S-39-3
Test Date:	24-Apr-10
Beginning Clock Time:	08:53
Recording Interval:	10 min.
Total Sampling Time:	520 min.

Velocity Traverse Data							
	Pt.1	Pt.2	Pt.3	Pt.4	Pt.5	Pt.6	Pt.7
Initial dP	0.028	0.042	0.044	0.039	0.027	0.042	0.044
Initial Temp.	97	97	97	97	97	97	97

"H₂O of

OMNI Equipment Numbers:

PM Control Module:			
Dilution Tunnel MW(dry):	29.00	lb/lb-mole	Tunnel Velocity: 13.38 ft/sec.
Dilution Tunnel MW(wet):	28.56	lb/lb-mole	Initial Tunnel Flow: 142.5 scfm
Dilution Tunnel H ₂ O:	4.00	percent	Average Tunnel Flow: 142.2 scfm
Dilution Tunnel Static:	-0.144	"H ₂ O	Tunnel Area: 0.1963 ft ²
Pitot Tube Cp:	0.99		Post-Test Leak Check (1): 0.0@95 cfm@1"hg
Meter Box Y Factor:	0.994 (1)	0.996 (2)	Post-Test Leak Check (2): 0.0@99 cfm@1"hg
Barometric Pressure:	Begin	Middle	Fuel Moisture (dry basis %): 19.27
	29.76	29.6	Total Particulate (1): 5.3
	29.58	29.65	Total Particulate (2): 4.4

Elapsed Time	Particulate Sampling Data												Wood Heater Temperature Data, °F												Stack					
	Gas Meter Cubic Feet (1)	Gas Meter Cubic Feet (2)	Sample Rate, cfm (1)	Sample Rate, cfm (2)	Orifice dH (1)	Orifice dH (2)	Meter oF (1)	Meter oF (2)	Meter Vac. In. Hg. (1)	Meter Vac. In. Hg. (2)	Dilution Tunnel dP	Dilution Tunnel Temp.	Pro. Rate (10%) (1)	Pro. Rate (10%) (2)	Scale Reading	Weight Change	Firebox Top	Firebox Bottom	Firebox Back	Firebox Left	Firebox Right	Catalyst Exit	Average Surface	Stack	Filter (1)	Filter (2)	Impinger exit (1)	Impinger exit (2)	Ambient	Draft In. H ₂ O
430	995.857	397.378	0.16	0.14	0.00	0.00	81	82			91	0.039	99	98	0.9	-0.15	364	167	137	223	212		220.6	182	73	75			82	0.025
440	997.475	398.810	0.16	0.14	0.00	0.00	81	82			91	0.040	97	96	0.8	-0.1	352	168	138	220	213		218.2	179	74	76			81	0.025
450	999.089	400.243	0.16	0.14	0.00	0.00	81	82			91	0.040	97	96	0.7	-0.1	339	170	136	215	211		214.2	177	74	78			83	0.025
460	1000.713	401.678	0.16	0.14	0.00	0.00	81	83			90	0.040	97	96	0.6	-0.1	330	168	132	211	209		210.0	175	74	76			83	0.025
470	1002.330	403.118	0.16	0.14	0.00	0.00	82	83			90	0.040	97	96	0.5	-0.1	323	168	131	209	207		207.6	170	74	76			80	0.025
480	1003.953	404.555	0.16	0.14	0.00	0.00	82	83			90	0.040	97	96	0.4	-0.1	322	168	130	203	205		205.6	168	75	77			83	0.023
490	1005.561	405.995	0.16	0.14	0.00	0.00	82	83			90	0.039	97	97	0.3	-0.1	318	169	130	203	203		204.6	169	75	77			81	0.023
500	1007.188	407.430	0.16	0.14	0.00	0.00	82	83			90	0.038	100	98	0.2	-0.1	311	166	128	198	201		200.8	162	75	77			81	0.023
510	1008.812	408.867	0.16	0.14	0.00	0.00	82	83			90	0.039	98	97	0.1	-0.1	304	168	128	192	198		198.0	160	75	77			81	0.023
520	1010.413	410.228	0.16	0.14	0.00	0.00	82	83			89	0.039	97	92	0.0	-0.05	300	164	126	190	197		195.4	160	75	77			81	0.020
Avg/Total	83.873	75.345	0.16	0.14	0.00	0.00	75.68	77.02	██████████	██████████	96.53	0.038	100.79	100.81			██████████	██████████	██████████	██████████	██████████	██████████	130	██████████	72.83	73.75	#DIV/0!	#DIV/0!	0.041	

PRINT

**Final Laboratory Report - Method 5G Dual Train
Dilution Tunnel Particulate Calculations**

Client Name: Monessen
 Model: Defiant 2NI
 Project No.: 227-S-39-3
 Tracking No.: 1534

Equipment Numbers:
OMNI-00023
OMNI-00131
OMNI-00342
VC-1

Run #: 7
 Train #: A
 Date: 04/24/10

Sample Component	Reagent	Filter # or Probe #	Weights		
			Final, mg	Tare, mg	Particulate, mg
A. Front filter catch	Filter	F558	120.4	116.6	3.8
B. Rear filter catch	Filter	F559	121.1	120.4	0.7
C. Probe catch	Probe	VC-7	86367.6	86366.8	0.8

Total Particulate, mg :	5.3
-------------------------	-----

Component	Equations:
A. Front filter catch	Final (mg) - Tare (mg) = Particulate, mg
B. Rear filter catch	Final (mg) - Tare (mg) = Particulate, mg
C. Probe catch	Final (mg) - Tare (mg) = Particulate, mg

Analyst: J. Parker Date: 4/24/10

PRINT

**Final Laboratory Report - Method 5G Dual Train
Dilution Tunnel Particulate Calculations**

Client Name:	<u>Moussen</u>	Equipment Numbers:	<u>OMNI-00023</u>	Run #:	<u>7</u>
Model:	<u>Defiant 2N1</u>		<u>OMNI-00131</u>	Train #:	<u>B</u>
Project No.:	<u>227-S-39-3</u>		<u>OMNI-00342</u>	Date:	<u>04/24/10</u>
Tracking No.:	<u>1534</u>		<u>VC-1</u>		

Sample Component	Reagent	Filter # or Probe #	Weights		
			Final, mg	Tare, mg	Particulate, mg
A. Front filter catch	Filter	F560	128.8	125.3	3.5
B. Rear filter catch	Filter	F561	117.0	116.4	0.6
C. Probe catch	Probe	VC-0	79819.1	79818.8	0.3

Total Particulate, mg :	<u>4.4</u>
-------------------------	------------

Component	Equations:
A. Front filter catch	Final (mg) - Tare (mg) = Particulate, mg
B. Rear filter catch	Final (mg) - Tare (mg) = Particulate, mg
C. Probe catch	Final (mg) - Tare (mg) = Particulate, mg

Analyst: Date: 4/27/10

Monessen Defiant 2N1
 Run 7 - Category 2, Non-Cat
 Pre-Burn Data

Green Number	Scatter(1a)	Scatter(1b)	Weight(1b)	Scatter(1c)	Weight(1c)	Scatter(1d)	Weight(1d)	Scatter(1e)	Weight(1e)	Scatter(1f)	Weight(1f)	Scatter(1g)	Weight(1g)	Scatter(1h)	Weight(1h)	Scatter(1i)	Weight(1i)	Scatter(1j)	Weight(1j)	Scatter(1k)	Weight(1k)
0	0	0	0	0	0	61	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
10	10	6.33	13.95526	0	0.051	64	618	389	203	257	387	285	285	285	285	285	285	285	285	285	285
20	20	5.96	13.13955	0.81571037	0.045	62	515	364	191	253	344	253	253	253	253	253	253	253	253	253	253
30	30	5.74	12.65453	0.485016977	0.04	62	470	342	182	247	316	247	247	247	247	247	247	247	247	247	247
40	40	5.31	11.70655	0.947987727	0.054	64	412	320	186	238	297	238	238	238	238	238	238	238	238	238	238
50	50	4.85	10.669242	1.014126406	0.061	65	377	304	262	230	286	230	230	230	230	230	230	230	230	230	230
60	60	4.42	9.744432	0.947987727	0.062	65	375	293	321	225	282	225	225	225	225	225	225	225	225	225	225
70	70	3.83	8.443705	1.300727347	0.067	65	391	295	354	226	289	226	226	226	226	226	226	226	226	226	226
80	80	3.31	7.297301	1.146403763	0.066	66	400	285	402	231	293	231	231	231	231	231	231	231	231	231	231
90	90	3.02	6.65796	0.63934056	0.061	66	415	285	395	239	296	239	239	239	239	239	239	239	239	239	239
100	100	2.54	5.599741	1.058218859	0.055	66	429	285	364	253	303	253	253	253	253	253	253	253	253	253	253

FUEL DATA

Client: MoresonModel: Defiant 2N1 (NC)Project #: 247-1-19 Tracking #: Date: 4/23/10 Test Crew: TC, JC Run #: 7OMNI Equipment ID #: FUEL LOAD PREPARED BY: Ralph; measured & moisture by TC, JCFUEL: DOUGLAS-FIR SPECIES, UNTREATED, AIR-DRIED, STANDARD GRADE OR BETTER,
DIMENSIONAL LUMBER.

PRE-BURN FUEL

MOISTURE CONTENT (METER -- DRY BASIS)

CALIBRATION:	Cal Value (1) = 12%	Actual Reading <u>12.0</u>
	Cal Value (2) = 22%	Actual Reading <u>22.0</u>

Piece	Length	Readings	Type
1	10 ft	20.3 20.9 20.2	2x4
2	10 ft	22.0 22.0 20.7	2x4
3	ft		

Length of cut pieces: 30 x 8 inches Pre-Burn Fuel Average Moisture:Time (clock): 6:15 Room Temperature (F): 70 Initials: JC

TEST FUEL

FUEL TYPE AND AMOUNT:	2 x 4 <u>6</u>	1 x 4 <u>4</u>
CALCULATED LOAD WEIGHT:	<u> </u>	
ACTUAL LOAD WEIGHT:	<u>6</u>	(2 x 4) <u>22.7</u>
FUEL PIECE LENGTH:	<u>21 inches</u>	
	(4 x 4) <u>22.7</u>	
	Total <u> </u>	

MOISTURE CONTENT (METER -- DRY BASIS)

PIECE	READINGS	TYPE
1	18.3 19.5 19.1	4 x 4
2	19.1 19.5 20.7	4 x 4
3	19.1 19.7 19.1	
4	19.1 19.2 19.2	
5		
6		
7		
8		
9		
10		

OVERALL TEST FUEL LOAD MOISTURE AVERAGE: 19.27 %Time (clock): 6:15 Room Temperature (F): 70 Initials: JCTechnician signature: JJC Date: 4/24/10

Run Notes

Client: Monaca
 Model: Defiant 2N1
 Project #: 227-5-39-3
 Tracking #: 1534
 Run #: 7 Date: 4/24/10
 Test Crew: TC Jc
 OMNI Equipment ID #(s): _____

PREBURN

DESCRIBE OR SKETCH AIR OR THERMOMSTAT SETTINGS BELOW:
 (SETTINGS MUST BE ACCURATE AND REPRODUCABLE)


PRIMARY:

SECONDARY: N/ATERTIARY: ↓FAN: lowPREBURN SETTINGS AND ACTIVITIES

TIME	AIR (THERMO) CHANGES PRIMARY/SECONDARY/TERTIARY	FAN SETTING CHANGE	ADD FUEL + WT.	ADD FUEL - WT.	RAKE COAL	COMMENT
0	Test setting				X	
34					X	
66 min					X	
90 min				0.55%		
105	Fuel on, test start				X	



TEST

TEST FUEL CONFIGURATION SKETCH
 (INDICATE VIEW ANGLE)



DESCRIBE OR SKETCH TEST SETTINGS BELOW:
 (SETTINGS MUST BE ACCURATE AND REPRODUCIBLE)

PRIMARY:

START UP PROCEDURESBYPASS: 1 minFUEL LOADING: 1 minDOOR: 1 minPRIMARY AIR: Test setting @ 0 min (no change)OTHER: N/ASECONDARY: N/ATERTIARY: ↓FAN: lowTechnician signature: Date: 4/24/10

4-70 OF 4-155

Supplemental Data EPA 5G/5H

Client: HansenModel: Delfin 2N1Project #: 227-S-39-3 Tracking #: 1534Date: 4/24/10 Run #: 7 Booth: (Cat 2 rebo)Test Crew: TC, JC Start Time: 8:51 Stop Time: 5:33

OMNI Equipment #(s): _____

Gas Analyzer Train Leak Check:

Stack: _____

Dilution Tunnel (Method 5G Only): _____

Initial: _____

Initial: _____

Final: _____

Final: _____

Calibrations: Span Gas CO₂: _____ O₂: _____ CO: _____ CO₂(DT): _____

Time	N ₂ Span						
O ₂							
CO ₂							
CO							
CO ₂ (DT)							

Stack Diameter (inches): 6Air Velocity (ft/min): Initial: < 50 Final: < 50Scale Audit (lbs): Pretest: 10.0 Post Test: 10.0Induced Draft: 0 %Smoke Capture: 100%Pitot Tube Leak Test: Pre: 0.0 at 3.1 in H₂O Post: 0.0 @ 3.0 in H₂OFlue Pipe Cleaned Prior to First Test in Series: Date: 4/18/10 Initials: JC

	Initial	Middle	Ending
Pb (in/Hg)	<u>29.76 in Hg</u>	<u>29.60</u>	<u>29.58</u>
Room Temp (°F)	<u>68 °F</u>	<u>76 °F</u>	<u>81 °F</u>

Technician signature: J. J. DeMaio Date: 4/24/10

Model: Defiant
Monessen Hearth Systems
P.O. Box 501
Bethel, VT 05032

Run 8

Wood Heater Test Data - EPA Method 5G

Manufacturer: Monessen
 Model: Defiant 2N1
 Project No.: 227-S-39-3
 Tracking No.: 1534
 Run: 8
 Test Date: 04/25/10

Burn Rate	0.85 kg/hr dry
Average Tunnel Temperature	94 degrees Fahrenheit
Average Gas Velocity in Dilution Tunnel - vs	13.1 feet/second
Average Gas Flow Rate in Dilution Tunnel - Qsd	8221.0 dscfhour
Average Delta p	0.036 inches H2O
Average Delta H	0.00 inches H2O
Total Time of Test	530 minutes

	AVERAGE	SAMPLE TRAIN 1	SAMPLE TRAIN 2
Total Sample Volume - Vm	80.57 cubic feet	84.30 cubic feet	76.84 cubic feet
Average Gas Meter Temperature	77 degrees Fahrenheit	78 degrees Fahrenheit	78 degrees Fahrenheit
Total Sample Volume (Standard Conditions) - Vmstd	76.8 dscf	80.4 dscf	73.3 dscf
Total Particulates - mn		27.9 mg	27.5 mg
Particulate Concentration (dry-standard)	0.00038 grams/dscf	0.00035 grams/dscf	0.00038 grams/dscf
Particulate Emission Rate	2.97 grams/hour	2.85 grams/hour	3.09 grams/hour
Adjusted Emissions	4.49 grams/hour	4.34 grams/hour	4.64 grams/hour
Difference from Average		0.15 grams/hour	0.15 grams/hour
7.5% of the average emission rate	0.34		
Weighted Average Emission Rate Limit	4.10 grams/hour		
7.5% of the weighted average emission rate limit	0.31		
Results Are Acceptable			

Wood Heater Test Data - EPA Method 5G

Run:	8
Manufacturer:	Monessen
Model:	Defiant 2NI
Tracking No.:	1534
Project No.:	227-S-39-3
Test Date:	25-Apr-10
Beginning Clock Time:	10:27
Recording Interval:	10 min.
Total Sampling Time:	530 min.

Velocity Traverse Data							
	Pt.1	Pt.2	Pt.3	Pt.4	Pt.5	Pt.6	Pt.7
Initial dP	0.026	0.039	0.045	0.041	0.025	0.039	0.041
Initial Temp.	101	101	101	101	101	101	101

"H₂O

OMNI Equipment Numbers:

PM Control Module:			
Dilution Tunnel MW(dry):	29.00	lb/lb-mole	
Dilution Tunnel MW(wet):	28.56	lb/lb-mole	
Dilution Tunnel H ₂ O:	4.00	percent	
Dilution Tunnel Static:	-0.16	"H ₂ O	
Pitot Tube Cp:	0.99		
Meter Box Y Factor:	0.994 (1)	0.996 (2)	Fuel Moisture (dry basis %): 20.7
Barometric Pressure:	Begin 29.30	Middle 29.1	Average 29.17 "Hg Total Particulate (1): 27.9
	End 29.1		Total Particulate (2): 27.5

Signature/Date: *JR 6/4/10*

Tunnel Velocity:	13.06	ft/sec.
Initial Tunnel Flow:	136.9	scfm
Average Tunnel Flow:	137.0	scfm
Tunnel Area:	0.1963 ft ²	
Post-Test Leak Check (1):	0.0@5	cfm@"Hg
Post-Test Leak Check (2):	0.0@9	cfm@"Hg

Elapsed Time	Particulate Sampling Data										Wood Heater Temperature Data, °F										Stack								
	Gas Meter Cubic Feet (1)	Gas Meter Cubic Feet (2)	Sample Rate, cfm (1)	Sample Rate, cfm (2)	Orifice dH(1)	Orifice dH(2)	Meter oF (1)	Meter oF (2)	Meter Vac. In. Hg. (1)	Meter Vac. In. Hg. (2)	Dilution Tunnel dP	Dilution Tunnel Temp.	Pro. Rate (10%) (1)	Pro. Rate (10%) (2)	Scale Reading	Weight Change	Firebox Top	Firebox Bottom	Firebox Back	Firebox Left	Firebox Right	Catalyst Exit	Average Surface	Stack	Filter (1)	Filter (2)	Impinger exit (1)	Impinger exit (2)	Ambient
0	10.629	410.446			0.00	0.00	72	72			101	0.036			22.3		438	273	318	262	299		318.0	331	69	69		71	0.045
10	12.332	411.985	0.17	0.15	0.00	0.00	72	73			97	0.036	109	108	21.6	-0.7	347	260	306	252	276		288.2	328	72	72		69	0.045
20	13.970	413.465	0.16	0.15	0.00	0.00	72	73			99	0.035	106	105	20.9	-0.7	302	250	312	232	250		269.2	360	72	72		72	0.050
30	15.568	414.923	0.16	0.15	0.00	0.00	72	74			102	0.036	102	102	20.0	-0.9	280	235	330	217	232		258.8	400	72	72		72	0.053
40	17.173	416.375	0.16	0.15	0.00	0.00	73	74			108	0.036	103	102	18.8	-1.2	293	226	356	211	224		262.0	443	72	74		72	0.058
50	18.761	417.833	0.16	0.15	0.00	0.00	73	74			109	0.037	101	102	17.7	-1.1	337	215	369	207	220		269.6	441	72	74		72	0.060
60	20.360	419.289	0.16	0.15	0.00	0.00	73	75			111	0.036	103	103	16.5	-1.2	372	207	374	209	220		276.4	448	72	74		72	0.060
70	21.951	420.747	0.16	0.15	0.00	0.00	73	75			111	0.036	103	103	15.3	-1.2	387	201	370	212	225		279.0	441	72	75		70	0.060
80	23.541	422.208	0.16	0.15	0.00	0.00	74	75			112	0.035	104	105	14.1	-1.15	403	197	368	216	236		284.0	444	73	75		73	0.060
90	25.137	423.668	0.16	0.15	0.00	0.00	74	76			114	0.036	103	103	12.7	-1.4	444	193	373	223	249		296.4	451	75	77		73	0.060
100	26.733	425.128	0.16	0.15	0.00	0.00	74	76			114	0.037	102	102	11.7	-1.05	470	193	366	230	264		304.6	449	75	77		71	0.060
110	28.322	426.591	0.16	0.15	0.00	0.00	74	76			112	0.035	104	105	10.7	-0.95	490	189	360	239	282		312.0	421	76	76		74	0.058
120	29.913	428.057	0.16	0.15	0.00	0.00	75	77			107	0.037	100	101	9.8	-0.9	501	191	341	248	297		315.6	371	76	76		74	0.055
130	31.510	429.516	0.16	0.15	0.00	0.00	75	77			104	0.035	103	103	9.1	-0.7	491	190	311	252	309		310.6	348	76	76		74	0.050
140	33.099	430.985	0.16	0.15	0.00	0.00	75	77			102	0.036	101	103	8.5	-0.65	481	188	285	257	316		305.4	329	75	77		73	0.048
150	34.692	432.438	0.16	0.15	0.00	0.00	76	77			100	0.036	101	101	7.9	-0.6	463	184	263	257	315		296.4	313	75	75		72	0.045
160	36.288	433.900	0.16	0.15	0.00	0.00	76	77			99	0.036	101	102	7.3	-0.55	455	184	247	255	314		291.0	307	75	75		75	0.045
170	37.875	435.370	0.16	0.15	0.00	0.00	76	78			99	0.035	102	104	6.9	-0.45	455	182	238	258	310		288.6	301	76	76		76	0.045
180	39.466	436.820	0.16	0.14	0.00	0.00	76	78			98	0.035	102																

Wood Heater Test Data - EPA Method 5G

Run: 8
 Manufacturer: Monessen
 Model: Defiant 2N1
 Tracking No.: 1534
 Project No.: 227-S-39-3
 Test Date: 25-Apr-10
 Beginning Clock Time: 10:27
 Recording Interval: 10 min.
 Total Sampling Time: 530 min.

Velocity Traverse Data							
	Pt.1	Pt.2	Pt.3	Pt.4	Pt.5	Pt.6	Pt.7
Initial dP	0.026	0.039	0.045	0.041	0.025	0.039	0.041
Initial Temp.	101	101	101	101	101	101	101

°H₂O

OMNI Equipment Numbers:

PM Control Module:
 Dilution Tunnel MW(dry): 29.00 lb/lb-mole
 Dilution Tunnel MW(wet): 28.56 lb/lb-mole
 Dilution Tunnel H₂O: 4.00 percent
 Dilution Tunnel Static: -0.196 "H₂O
 Pitot Tube Cp: 0.99
 Meter Box Y Factor: 0.994 (1) 0.996 (2)
 Barometric Pressure: Begin 29.30 Middle 29.1 End 29.17 °Hg
 Tunnel Velocity: 13.06 ft/sec.
 Initial Tunnel Flow: 136.9 scfm
 Average Tunnel Flow: 137.0 scfm
 Tunnel Area: 0.1963 ft²
 Post-Test Leak Check (1): 0.0@5 cfm@°Hg
 Post-Test Leak Check (2): 0.0@9 cfm@°Hg
 Fuel Moisture (dry basis %): 20.7
 Total Particulate (1): 27.9
 Total Particulate (2): 27.5

Elapsed Time	Particulate Sampling Data												Wood Heater Temperature Data, °F												Stack				
	Gas Meter Cubic Feet (1)	Gas Meter Cubic Feet (2)	Sample Rate, cfm (1)	Sample Rate, cfm (2)	Orifice dH (1)	Orifice dH (2)	Meter of (1)	Meter of (2)	Meter Vac. In. Hg. (1)	Meter Vac. In. Hg. (2)	Dilution Tunnel Temp.	Dilution Tunnel dP	Pro. Rate (10%) (1)	Pro. Rate (10%) (2)	Scale Reading	Weight Change	Firebox Top	Firebox Bottom	Firebox Back	Firebox Left	Firebox Right	Catalyst Exit	Average Surface	Stack	Filter (1)	Filter (2)	Impinger exit (1)	Impinger exit (2)	Ambient
430	79.080	472.910	0.16	0.14	0.00	0.00	77	79			86	0.037	98	97	1.3	-0.15	341	144	170	224	222		220.2	172	72	70		74	0.023
440	80.664	474.357	0.16	0.14	0.00	0.00	77	78			85	0.036	99	99	1.1	-0.15	343	142	172	224	220		220.2	172	72	72		74	0.023
450	82.255	475.790	0.16	0.14	0.00	0.00	77	78			85	0.034	102	101	1.0	-0.15	343	146	172	223	215		219.8	172	71	69		76	0.023
460	83.842	477.235	0.16	0.14	0.00	0.00	77	78			86	0.036	99	99	0.9	-0.1	340	148	172	226	215		220.2	172	71	71		76	0.023
470	85.425	478.670	0.16	0.14	0.00	0.00	77	78			86	0.036	99	99	0.7	-0.15	332	152	172	226	215		219.4	170	73	71		76	0.023
480	87.011	480.103	0.16	0.14	0.00	0.00	78	79			87	0.036	99	98	0.6	-0.15	328	155	174	224	213		218.8	170	72	72		78	0.023
490	88.593	481.535	0.16	0.14	0.00	0.00	78	79			86	0.036	99	98	0.4	-0.15	326	155	172	222	213		217.6	168	74	72		78	0.023
500	90.177	482.975	0.16	0.14	0.00	0.00	78	80			86	0.035	100	100	0.3	-0.1	322	160	175	218	211		217.2	166	74	72		79	0.020
510	91.755	484.411	0.16	0.14	0.00	0.00	79	80			86	0.036	98	98	0.2	-0.15	318	158	173	216	209		214.8	166	72	72		79	0.023
520	93.350	485.860	0.16	0.14	0.00	0.00	79	80			86	0.036	99	99	0.1	-0.1	315	160	171	214	209		213.8	164	75	72		79	0.020
530	94.929	487.290	0.16	0.14	0.00	0.00	79	80			86	0.035	100	99	0.0	-0.05	309	160	171	212	210		212.4	167	75	73		79	0.020
Avg/Total	84.300	76.843	0.16	0.14	0.00	0.00	76.30	77.63			94.41	0.036	100.78	100.78								106		73.07	72.80	#DIV/0!	#DIV/0!	0.036	

PRINT

**Final Laboratory Report - Method 5G Dual Train
Dilution Tunnel Particulate Calculations**

Client Name: Monessen
 Model: Defiant 2N1
 Project No.: 227-S-39-3
 Tracking No.: 1534

Equipment Numbers: OMNI-00023
 OMNI-00131
 OMNI-00342
 VC-1

Run #: 8
 Train #: A
 Date: 04/25/10

Sample Component	Reagent	Filter # or Probe #	Weights		
			Final, mg	Tare, mg	Particulate, mg
A. Front filter catch	Filter	F562	146.1	120.4	25.7
B. Rear filter catch	Filter	F563	126.0	124.9	1.1
C. Probe catch	Probe	VC-C	85527.3	85526.2	1.1

Total Particulate, mg :	27.9
-------------------------	------

Component	Equations:
A. Front filter catch	Final (mg) - Tare (mg) = Particulate, mg
B. Rear filter catch	Final (mg) - Tare (mg) = Particulate, mg
C. Probe catch	Final (mg) - Tare (mg) = Particulate, mg

Analyst: 

Date: 4/26/10

PRINT

Final Laboratory Report - Method 5G Dual Train Dilution Tunnel Particulate Calculations

Client Name: Monessen
 Model: Defiant 2N1
 Project No.: 227-S-39-3
 Tracking No.: 1534

Equipment Numbers: OMNI-00023
 OMNI-00131
 OMNI-00342
 VC-I

Run #: 8
 Train #: B
 Date: 04/25/10

Sample Component	Reagent	Filter # or Probe #	Weights		
			Final, mg	Tare, mg	Particulate, mg
A. Front filter catch	Filter	F564	141.9	116.7	25.2
B. Rear filter catch	Filter	F565	120.8	119.6	1.2
C. Probe catch	Probe	VC-S	73572.5	73571.4	1.1

Total Particulate, mg :	27.5
-------------------------	------

Component	Equations:
A. Front filter catch	Final (mg) - Tare (mg) = Particulate, mg
B. Rear filter catch	Final (mg) - Tare (mg) = Particulate, mg
C. Probe catch	Final (mg) - Tare (mg) = Particulate, mg

Analyst: Date: 6/2/10

STOVE TEMPERATURE TEST DATA - METHOD 5G

Page 1 of 1Client/Model: Hensel / Duraflame 2W1Project #: 227-5-39-3 Tracking #: 1534Date: 4/25/10 Test Crew: ACOMNI Equipment ID #:

Preburn Test	Coal Bed: 5.236 ft Data: 0 =				Actual: Range: 5.57 - 445 ft Coal Bed:					
	Fuel(kg)	Delta Weight	Stack Draft	Ambient	Top	Bottom	Back	Right	Flue	Catalyst
0	7.01	—	0	64						N/A
10	6.39	0.62	0.055	68	575	415	211	252	467	322
20	5.96	0.43	0.048	69	500	377	203	251	409	283
30	5.67	0.29	0.044	69	464	340	199	249	371	260
40	5.24	0.43	0.055	69	403	323	208	238	344	351
50	4.76	0.48	0.060	69	380	300	216	232	317	406
60	4.24	0.52	0.063	70	387	289	335	226	300	441
70	3.61	0.63	0.066	70	415	289	376	223	296	476
80	3.22	0.39	0.060	70	417	285	400	235	298	426
90	3.02	0.20	0.054	71	429	281	375	249	301	377
100	2.59	0.43	0.052	71	440	279	340	253	301	362
110	2.47	0.12	0.053	71	438	271	320	262	299	334
20										
30										
40										
50										
60										
70										
80										
90										
AVG										

Technician signature: JohnDate: 5/6/10

FUEL DATA

Client: Manesen

Model: Defiant 2411

Project #: 222-5-27 Tracking #: 1534

Date: 4/25/12

OMNI Equipment ID #: 100-000000 Job Crew: 100 Job #: 0

FUEL LOAD PREPARED BY: B.L. 1000-1000-1000-1000

FUEL LOAD PREPARED BY: Ralph Measured & Monitored by Jeremy Clark
FUEL: DOUGLAS FIR SPECIES, 100% DRYNESS, no major organisms or imperfections

PRE-BURN FUEL

MOISTURE CONTENT (METER -- DRY BASIS)

CALIBRATION: Cal Value (1) = 12% Actual Reading 12.0%
Cal Value (2) = 22% Actual Reading 22.0%

Piece	Length	Readings	Type
1	14.3 14.3 ft	20.6	22.6
2	14.3 14.3 ft	19.3	20.0
3	ft		22.6

Length of cut pieces: 30~~5~~ inches Pre-Burn Fuel Average Moisture: 20.53%

Time (clock): 7:50 Room Temperature (F): 70 °F Initials: JC

TEST FUEL

FUEL TYPE AND AMOUNT: 2×4 $\frac{1}{2}$ 4×4 $\frac{1}{2}$

CALCULATED LOAD WEIGHT: _____ ACTUAL LOAD WEIGHT: 5 (2 x 4)

FUEL PIECE LENGTH: 21 inches 22.25 (4 x 4) 22.25 Total

MOISTURE CONTENT (METER - DRY BASIS)

PIECE	READINGS	TYPE
1	<u>21.3</u>	<u>22.0</u>
2	<u>18.9</u>	<u>21.3</u>
3	<u>22.4</u>	<u>18.3</u>
4	<u>21.6</u>	<u>22.0</u>
5	_____	_____
6	_____	_____
7	_____	_____
8	_____	_____
9	_____	_____
10	_____	_____

OVERALL TEST FUEL LOAD MOISTURE AVERAGE: 20.7%

Time (clock): 7:30 Room Temperature (F): 70 °F Initials: SL

Technician signature:

Date: 4/25/12

4-29 OF 4-155


Run Notes

Client: MarscoModel: Defiant 2N1Project #: 227-5-31-3Tracking #: 1534Run #: 8Date: 4/25/10Test Crew: JL


OMNI Equipment ID #(s): _____

PREBURNDESCRIBE OR SKETCH AIR OR THERMOMSTAT SETTINGS BELOW:
(SETTINGS MUST BE ACCURATE AND REPRODUCABLE)


PRIMARY:

SECONDARY: N/ATERTIARY: FAN: LowPREBURN SETTINGS AND ACTIVITIES

TIME	AIR (THERMO) CHANGES PRIMARY/SECONDARY/TERTIARY	FAN SETTING CHANGE	ADD FUEL + WT.	ADD FUEL - WT.	RAKE COAL	COMMENT
0	Test Setting				X	
32					X	
67					X	
97				0.5 lb		
110	Fuel on, test start				X	

TESTTEST FUEL CONFIGURATION SKETCH
(INDICATE VIEW ANGLE)START UP PROCEDURESBYPASS: 1 min 30 secFUEL LOADING 1 min 30 secDOOR: 1 min 30 secPRIMARY AIR: Test setting @ 0 min (no change)OTHER: N/ADESCRIBE OR SKETCH TEST SETTINGS BELOW:
(SETTINGS MUST BE ACCURATE AND REPRODUCIBLE)

PRIMARY:

SECONDARY: N/ATERTIARY: FAN: LowTechnician signature: J. MillerDate: 4/25/10

4 - 80 OF 4 - 155

Page 1 of 1

Supplemental Data EPA 5G/5H

Client: MesssenModel: DFT-2N1Project #: 227-5-31-3 Tracking #: 1534Date: 4/25/10 Run #: 8 Booth: _____Test Crew: JC Start Time: 10:27 Stop Time: 11:17

OMNI Equipment #(s): _____

Gas Analyzer Train Leak Check:

Stack:

Dilution Tunnel (Method 5G Only):

Initial: _____

Initial: _____

Final: _____

Final: _____

Calibrations: Span Gas CO₂: _____ O₂: _____ CO: _____ CO₂(DT): _____

Time	N ₂ Span						
O ₂							
CO ₂							
CO							
CO ₂ (DT)							

Stack Diameter (inches): 6Air Velocity (ft/min): Initial: <50 Final: <50Scale Audit (lbs): Pretest: 10.0 Post Test: 10.0Induced Draft: 0 %Smoke Capture: 100%Pitot Tube Leak Test: Pre: 0.0 @ 3.0 in H₂O Post: 0.0 @ 3.1 in H₂OFlue Pipe Cleaned Prior to First Test in Series: Date: 4/18/10 Initials: JC

	Initial	Middle	Ending
Pb (in/Hg)	29.30	29.10	29.10
Room Temp (°F)	78 °F	79 °F	79 °F

Technician signature: JJC Date: 4/25/10

Model: Defiant
Monessen Hearth Systems
P.O. Box 501
Bethel, VT 05032

Run 9

Wood Heater Test Data - EPA Method 5G

Run:	9
Manufacturer:	Monessen
Model:	Defiant 2N1
Tracking No.:	1534
Project No.:	227-S-39-3
Test Date:	26-Apr-10
Beginning Clock Time:	09:47
Recording Interval:	10 min.
Total Sampling Time:	580 min.

Velocity Traverse Data							
Initial dP	Pt.1	Pt.2	Pt.3	Pt.4	Pt.5	Pt.6	Pt.8
Initial Temp.	105	105	105	105	105	105	105
"H ₂ O							

OMNI Equipment Numbers: _____

PM Control Module:		
Dilution Tunnel MW(dry):	29.00	lb/lb-mole
Dilution Tunnel MW(wet):	28.56	lb/lb-mole
Dilution Tunnel H ₂ O:	4.00	percent
Dilution Tunnel Static:	-0.144	"Hg
Pitot Tube Cp:	0.99	
Meter Box Y Factor:	0.994 (1)	0.996
Barometric Pressure:	Begin	Middle
	Average	Total Particulate (1):
	28.98	28.91
	28.86	28.92 "Hg
		Total Particulate (2):
		24.4

Signature/Date: *JR* 6/4/10

Tunnel Velocity:	13.41	ft/sec.
Initial Tunnel Flow:	137.6	scfm
Average Tunnel Flow:	139.5	scfm
Tunnel Area:	0.1963 ft ²	
Post-Test Leak Check (1):	0.0@5 cfm@"Hg	
Post-Test Leak Check (2):	0.0@9 cfm@"Hg	
(2) Fuel Moisture (dry basis %):	19.8	
Average	Total Particulate (1):	25.6
	Total Particulate (2):	24.4

Elapsed Time	Particulate Sampling Data										Wood Heater Temperature Data, °F										Stack Draft In. H ₂ O									
	Gas Meter Cubic Feet (1)	Gas Meter Cubic Feet (2)	Sample Rate, cfm (1)	Sample Rate, cfm (2)	Orifice dH (1)	Orifice dH (2)	Meter oF (1)	Meter oF (2)	Meter Vac. In. Hg. (1)	Meter Vac. In. Hg. (2)	Dilution Tunnel Temp.	Dilution Tunnel dP	Pro. Rate (10%) (1)	Pro. Rate (10%) (2)	Scale Reading	Weight Change	Firebox Top	Firebox Bottom	Firebox Back	Firebox Left	Firebox Right	Catalyst Exit	Average Surface	Stack	Filter (1)	Filter (2)	Impinger exit (1)	Impinger exit (2)	Ambient	
0	94.991	487.372	0.00	0.00	73	73			105	0.037			22.2		462	301	457	310	312		368.4	316	67	71			71	0.045		
10	96.650	488.850	0.17	0.15	0.00	0.00	73	74			97	0.036	108	109	21.6	-0.6	360	290	436	288	293		333.4	319	71	73			71	0.045
20	98.292	490.300	0.16	0.14	0.00	0.00	73	74			98	0.037	105	106	21.0	-0.65	310	278	436	262	267		310.6	356	71	74			71	0.048
30	99.933	491.749	0.16	0.14	0.00	0.00	74	75			101	0.036	107	107	20.2	-0.8	289	267	450	244	248		299.6	398	72	74			72	0.050
40	101.573	493.198	0.16	0.14	0.00	0.00	74	75			105	0.036	107	107	19.2	-1	289	254	476	233	235		297.4	430	72	74			72	0.055
50	103.180	494.617	0.16	0.14	0.00	0.00	75	76			107	0.038	102	102	18.1	-1.1	309	244	496	227	231		301.4	437	75	75			75	0.058
60	104.786	496.040	0.16	0.14	0.00	0.00	75	76			108	0.037	103	104	17.0	-1.1	347	236	507	223	232		309.0	440	75	77			75	0.058
70	106.395	497.455	0.16	0.14	0.00	0.00	76	77			110	0.037	104	104	15.9	-1.1	377	228	514	223	236		315.6	443	76	78			76	0.058
80	107.995	498.875	0.16	0.14	0.00	0.00	76	77			110	0.038	102	103	14.8	-1.1	401	224	516	226	245		322.4	445	76	78			76	0.058
90	109.602	500.299	0.16	0.14	0.00	0.00	76	77			110	0.039	101	102	13.7	-1.05	424	218	517	231	259		329.8	441	76	78			76	0.058
100	111.208	501.722	0.16	0.14	0.00	0.00	77	78			111	0.038	102	103	12.7	-1	435	214	515	235	274		334.6	439	77	79			75	0.060
110	112.821	503.150	0.16	0.14	0.00	0.00	77	78			110	0.038	102	103	11.7	-1.05	446	210	515	240	290		340.2	433	77	79			75	0.060
120	114.422	504.570	0.16	0.14	0.00	0.00	77	79			109	0.039	100	101	10.8	-0.9	464	208	511	245	308		347.2	423	78	80			75	0.058
130	116.033	505.997	0.16	0.14	0.00	0.00	77	79			109	0.039	101	101	9.9	-0.9	475	206	507	249	321		351.6	416	78	78			76	0.058
140	117.634	507.415	0.16	0.14	0.00	0.00	78	79			106	0.038	101	102	9.1	-0.75	480	202	497	259	332		354.0	384	78	78			76	0.055
150	119.245	508.838	0.16	0.14	0.00	0.00	78	80			103	0.039	100	100	8.5	-0.6	484	205	469	263	339		352.0	346	76	79			76	0.050
160	120.851	510.248	0.16	0.14	0.00	0.00	78	80			101	0.037	102	102	8.0	-0.5	472	203	407	268	340		338.0	305	77	77			77	0.048
170	122.458	511.659	0.16	0.14	0.00	0.00	78	80			100	0.037	102	102	7.6	-0.45	438	199	362	262	331		318.4	281	75	75			77	0.048
180	124.067	513.084	0.16	0.14	0.00	0.00	78	80			98	0.037	102	103	7.1	-0.45	413	203	322	257	322		303.4	257	75	75				

Wood Heater Test Data - EPA Method 5G

Run:	9
Manufacturer:	Monessen
Model:	Defiant 2N1
Tracking No.:	1534
Project No.:	227-S-39-3
Test Date:	26-Apr-10
Beginning Clock Time:	09:47
Recording Interval:	10 min.
Total Sampling Time:	580 min.

Velocity Traverse Data							
	Pt.1	Pt.2	Pt.3	Pt.4	Pt.5	Pt.6	Pt.7
Initial dP	0.028	0.041	0.042	0.039	0.025	0.040	0.045
Initial Temp.	105	105	105	105	105	105	105

"H₂O

OMNI Equipment Numbers: _____

PM Control Module:			
Dilution Tunnel MW(dry):	29.00	lb/lb-mole	Tunnel Velocity: 13.41 ft/sec.
Dilution Tunnel MW(wet):	28.56	lb/lb-mole	Initial Tunnel Flow: 137.6 scfm
Dilution Tunnel H ₂ O:	4.00	percent	Average Tunnel Flow: 139.5 scfm
Dilution Tunnel Static:	-0.144	"H ₂ O	Tunnel Area: 0.1963 ft ²
Pitot Tube Cp:	0.99		Post-Test Leak Check (1): 0.0@5 cfm@"Hg
Meter Box Y Factor:	0.994 (1)	0.996 (2)	Post-Test Leak Check (2): 0.0@9 cfm@"Hg
Barometric Pressure:	Begin	Middle	Fuel Moisture (dry basis %): 19.8
	28.98	28.91	Total Particulate (1): 25.6
		28.86	Total Particulate (2): 24.4

Elapsed Time	Particulate Sampling Data										Fuel Weight, lb										Wood Heater Temperature Data, °F										Stack
	Gas Meter Cubic Feet (1)	Gas Meter Cubic Feet (2)	Sample Rate, cfm (1)	Sample Rate, cfm (2)	Orifice dH(1)	Orifice dH(2)	Meter of (1)	Meter of (2)	Meter Vac. (1)	Meter Vac. (2)	Dilution Tunnel Temp.	Dilution Tunnel dP	Pro. Rate (10%) (1)	Pro. Rate (10%) (2)	Scale Reading	Weight Change	Firebox Top	Firebox Bottom	Firebox Back	Firebox Left	Firebox Right	Catalyst Exit	Average Surface	Stack	Filter (1)	Filter (2)	Impinger exit (1)	Impinger exit (2)	Ambient	Draft In. H ₂ O	
430	163.956	548.172	0.16	0.14	0.00	0.00	80	81			89	0.037	100	99	2.1	-0.15	362	167	202	238	238		241.4	184	73	73			80	0.025	
440	165.546	549.566	0.16	0.14	0.00	0.00	80	81			88	0.037	100	99	2.0	-0.1	356	167	195	232	238		237.6	180	73	73			80	0.025	
450	167.145	550.968	0.16	0.14	0.00	0.00	80	82			88	0.037	100	100	1.9	-0.1	345	166	194	226	235		233.2	181	74	74			80	0.025	
460	168.738	552.370	0.16	0.14	0.00	0.00	81	82			88	0.037	100	100	1.8	-0.15	339	166	192	222	228		229.4	179	74	74			80	0.025	
470	170.325	553.760	0.16	0.14	0.00	0.00	80	82			88	0.037	100	99	1.7	-0.1	332	163	187	219	224		225.0	174	72	74			80	0.025	
480	171.922	555.160	0.16	0.14	0.00	0.00	80	82			87	0.037	100	99	1.6	-0.1	328	163	185	217	219		222.4	174	74	74			80	0.025	
490	173.515	556.557	0.16	0.14	0.00	0.00	80	82			87	0.037	100	99	1.4	-0.15	323	161	183	215	217		219.8	172	74	74			80	0.020	
500	175.105	557.956	0.16	0.14	0.00	0.00	80	81			87	0.037	100	100	1.3	-0.1	323	161	180	215	215		218.8	169	71	73			78	0.020	
510	176.704	559.361	0.16	0.14	0.00	0.00	80	81			87	0.037	100	100	1.2	-0.15	318	159	180	215	215		217.4	169	73	73			80	0.020	
520	178.296	560.759	0.16	0.14	0.00	0.00	80	81			86	0.037	100	99	1.1	-0.1	299	161	178	210	210		211.6	184	73	73			78	0.020	
530	179.885	562.160	0.16	0.14	0.00	0.00	80	81			86	0.037	99	100	0.9	-0.15	333	160	192	212	210		221.4	222	73	75			77	0.020	
540	181.485	563.565	0.16	0.14	0.00	0.00	80	81			86	0.037	100	100	0.9	-0.05	323	161	183	215	217		219.8	172	72	74			78	0.020	
550	183.076	564.956	0.16	0.14	0.00	0.00	80	81			86	0.038	98	98	0.7	-0.2	325	161	180	215	215		219.2	172	71	73			78	0.023	
560	184.668	566.358	0.16	0.14	0.00	0.00	80	81			87	0.037	100	100	0.4	-0.3	314	158	178	212	214		215.2	167	73	73			77	0.023	
570	186.263	567.754	0.16	0.14	0.00	0.00	80	81			88	0.038	99	98	0.1	-0.3	314	158	182	210	208		214.4	204	73	73			77	0.025	
580	187.855	569.158	0.16	0.14	0.00	0.00	80	81			89	0.037	100	100	0.0	-0.05	335	160	201	214	214		224.8	229	73	75			77	0.025	
Avg/Total	92.864	81.786	0.16	0.14	0.00	0.00	78.27	79.49			94.41	0.037	100.75	100.75								144	73.81	74.81	#DIV/0!	#DIV/0!		0.035			

PRINT

**Final Laboratory Report - Method 5G Dual Train
Dilution Tunnel Particulate Calculations**

Client Name: Monessen
 Model: Default 2N1
 Project No.: 227-S-39-3
 Tracking No.: 1534

Equipment Numbers: OMNI-00023
 OMNI-00131
 OMNI-00342
 VC-1

Run #: 9
 Train #: A
 Date: 04/24/10

Sample Component	Reagent	Filter # or Probe #	Weights		
			Final, mg	Tare, mg	Particulate, mg
A. Front filter catch	Filter	F566	148.8	125.6	23.2
B. Rear filter catch	Filter	F567	117.7	116.3	1.4
C. Probe catch	Probe	VC-L	77119.9	77118.9	1.0

Total Particulate, mg :	25.6
-------------------------	------

Component	Equations:
A. Front filter catch	Final (mg) - Tare (mg) = Particulate, mg
B. Rear filter catch	Final (mg) - Tare (mg) = Particulate, mg
C. Probe catch	Final (mg) - Tare (mg) = Particulate, mg

Analyst:



Date: 6/2/10

PRINT

**Final Laboratory Report - Method 5G Dual Train
Dilution Tunnel Particulate Calculations**

Client Name: Monessea
 Model: Defiant 2N1
 Project No.: 227-S-39-3
 Tracking No.: 1534

Equipment Numbers:
OMNI-00023
OMNI-00131
OMNI-00342
VC-1

Run #: 9
 Train #: B
 Date: 04/24/10

Sample Component	Reagent	Filter # or Probe #	Weights		
			Final, mg	Tare, mg	Particulate, mg
A. Front filter catch	Filter	F568	142.0	119.8	22.2
B. Rear filter catch	Filter	F569	127.4	125.9	1.5
C. Probe catch	Probe	VC-N	77897.4	77896.7	0.7

Total Particulate, mg :	24.4
-------------------------	------

Component	Equations:
A. Front filter catch	Final (mg) - Tare (mg) = Particulate, mg
B. Rear filter catch	Final (mg) - Tare (mg) = Particulate, mg
C. Probe catch	Final (mg) - Tare (mg) = Particulate, mg

Analyst:

Date: 4/21/10

Monessen Defiant 2N1
 Run 9 - Fan Confirmation, Category 2, Non-Cat
 Pre-Burn Data

Record#	TestTime	Scalor(KG)	Scaler(PSI)	WaterTemp(°C)	WaterTemp(°F)	Top	Bottom	Bottom	Bottom	Bottom	Bottom
0	0	0	0.00	0	0	65	0	0	0	0	0
10	10	6.28	13.85	0	0.055	69	612	349	260	319	256
20	20	5.65	12.46	1.39	0.048	70	540	350	274	315	263
30	30	5.19	11.44	1.01	0.044	68	504	344	277	307	264
40	40	4.31	9.50	1.94	0.063	71	444	331	334	305	283
50	50	3.7	8.16	1.34	0.064	69	427	317	438	304	262
60	60	3.33	7.34	0.82	0.061	69	427	317	473	304	260
70	70	2.88	6.35	0.99	0.061	72	450	315	506	311	278
80	80	2.7	5.95	0.40	0.054	70	465	307	504	313	296
90	90	2.56	5.64	0.31	0.049	71	466	303	474	311	307
							342				

FUEL DATA

Client: Meneskin

Model: Defant 2N1

Project #: 227-5-11 Tracking #: 1534

Date: 4/26/10 Test Crew: SC Run #: 9

OMNI Equipment ID #:

FUEL LOAD PREPARED BY: Ralph; measured & moisture by SC

FUEL: DOUGLAS-FIR SPECIES, UNTREATED, AIR-DRIED, STANDARD GRADE OR BETTER, DIMENSIONAL LUMBER.

PRE-BURN FUEL

MOISTURE CONTENT (METER -- DRY BASIS)

CALIBRATION: Cal Value (1) = 12% Actual Reading 12.0 %
 Cal Value (2) = 22% Actual Reading 22.0 %

Piece	Length	Readings	Type
1	15 ft	21.5 22.3 15.0	2x4
2	15 ft	22.6 16.0 20.7	2x4
3	ft		

371.6 Length of cut pieces: 45 x 8 inches Pre-Burn Fuel Average Moisture: 19.7 %

Time (clock): 7:05 Room Temperature (F): 70 °F Initials: SC

TEST FUEL

FUEL TYPE AND AMOUNT: 2 x 4

4 x 4 4

CALCULATED LOAD WEIGHT: _____

ACTUAL LOAD WEIGHT: 10 (2 x 4)

FUEL PIECE LENGTH: 21 inches

22.20 lb (4 x 4)

22.20 lb Total

MOISTURE CONTENT (METER -- DRY BASIS)

PIECE	READINGS	TYPE
1	20.5 21.6 20.4	4x4
2	20.2 19.6 20.2	4x4
3	19.2 19.3 19.3	4x4
4	20.5 19.0 18.9	4x4
5		
6		
7		
8		
9		
10		

OVERALL TEST FUEL LOAD MOISTURE AVERAGE: 19.8 %

Time (clock): 7:15 Room Temperature (F): 70 °F Initials: SC

Technician signature: 

Date: 4/26/10


Run Notes

Client: MonesseModel: Defiant 2WIProject #: 227-5-31-3Tracking #: 1534Run #: 9Date: 4/26/10Test Crew: JC


OMNI Equipment ID #(s): _____

PREBURNDESCRIBE OR SKETCH AIR OR THERMOMSTAT SETTINGS BELOW;
(SETTINGS MUST BE ACCURATE AND REPRODUCIBLE)


PRIMARY:

SECONDARY: ~~N/A~~TERTIARY: ~~N/A~~FAN: No/OffPREBURN SETTINGS AND ACTIVITIES

TIME	AIR (THERMO) CHANGES PRIMARY/SECONDARY/TERTIARY	FAN SETTING CHANGE	ADD FUEL + WT.	ADD FUEL - WT.	RAKE COAL	COMMENT
0	Test setting					
32					X	
62					X	
94	Fuel on, test start				X	

TESTTEST FUEL CONFIGURATION SKETCH
(INDICATE VIEW ANGLE)START UP PROCEDURESBYPASS: 1 min, 10 secFUEL LOADING 1 min, 10 secDOOR: 1 min, 10 secPRIMARY AIR: Test setting @ 0 min (no change)OTHER: N/ADESCRIBE OR SKETCH TEST SETTINGS BELOW;
(SETTINGS MUST BE ACCURATE AND REPRODUCIBLE)

PRIMARY:

SECONDARY: ~~N/A~~TERTIARY: ~~N/A~~FAN: OffTechnician signature: JandaDate: 4/26/10

Supplemental Data EPA 5G/5H

Client: HoversonModel: Draft 2N1Project #: 227-S-31-3 Tracking #: 1534Date: 4/29/10 Run #: 9 Booth: _____Test Crew: JC Start Time: 7:47 AM Stop Time: 7:37 7:27 PM

OMNI Equipment #(s): _____

Gas Analyzer Train Leak Check:

Stack: _____

Dilution Tunnel (Method 5G Only): _____

Initial: _____

Initial: _____

Final: _____

Final: _____

Calibrations: Span Gas CO₂: _____ O₂: _____ CO: _____ CO₂(DT): _____

Time	N ₂ Span						
O ₂							
CO ₂							
CO							
CO ₂ (DT)							

Stack Diameter (inches): 6Air Velocity (ft/min): Initial: 450 Final: <50Scale Audit (lbs): Pretest: 10.0 Post Test: 10.0Induced Draft: 0 %Smoke Capture: 100%Pitot Tube Leak Test: Pre: 0.0 @ 3.0 Post: 0.0 @ 3.0Flue Pipe Cleaned Prior to First Test in Series: Date: 4/18/2010 Initials: JC

	Initial	Middle	Ending
Pb (in/Hg)	28.98	28.91	28.86
Room Temp (°F)	68 °F	80 °F	78 °F

Technician signature: JJCDate: 4/29/10

Model: Defiant
Monessen Hearth Systems
P.O. Box 501
Bethel, VT 05032

Run 10

STOVE TEMPERATURE TEST DATA - METHOD 5G

Client/Model: Mesmer/Defiant 2N1 Project #: 227-5-39-3 Tracking #: 1534

Date: 4/27/00 Test Crew: SC

OMNI Equipment ID #:

Preburn Test	Coal Bed:					Actual: TEMPERATURES (°F)					
	Fuel Weight	Delta Weight	Stack Draft	Ambient	Top	Bottom	Back	Left	Right	Flue	Catalyst
0											
10											
20											
30											
40											
50											
60											
70											
80											
90											
00											
10											
20											
30											
40											
50											
60											
70											
80											
90											
Avg											

Technician signature: 

Date: 4/27/00

FUEL DATA

Client: MonasenModel: Defeat 2 NJProject #: 227-5-39.3 Tracking #: 1534Date: 4/27/10 Test Crew: dc Run #: 10

OMNI Equipment ID #:

FUEL LOAD PREPARED BY: Ralph; measured moisture by dc.FUEL: DOUGLAS-FIR SPECIES, UNTREATED, AIR-DRIED, STANDARD GRADE OR BETTER,
DIMENSIONAL LUMBER.

PRE-BURN FUEL MOISTURE CONTENT (METER -- DRY BASIS)					
CALIBRATION:	Cal Value (1) = 12%	Actual Reading <u>12.0 %</u>			
	Cal Value (2) = 22%	Actual Reading <u>22.0 %</u>			
Piece	Length	Readings	Type		
1	<u>19</u> ft	<u>19.1</u>	<u>33.6</u>	<u>18.1</u>	<u>2x4</u>
2	<u>19</u> ft	<u>17.3</u>	<u>20.6</u>	<u>16.9</u>	<u>2x4</u>
3	<u> </u> ft	<u> </u>	<u> </u>	<u> </u>	<u> </u>
Length of cut pieces: <u>57 x 8</u> inches			Pre-Burn Fuel Average Moisture: <u>20.9 %</u>		
Time (clock): <u>7:30</u>			Room Temperature (F): <u>70 °F</u> Initials: <u>dc</u>		

TEST FUEL					
FUEL TYPE AND AMOUNT:	2 x 4	<u>Ø</u>	4 x 4	<u>4</u>	
CALCULATED LOAD WEIGHT:				ACTUAL LOAD WEIGHT: <u>Ø</u>	(2 x 4)
FUEL PIECE LENGTH:	<u>21 inches</u>			<u>22.25</u>	(4 x 4)
				<u>22.25</u>	Total <u> </u>
MOISTURE CONTENT (METER -- DRY BASIS)					
PIECE	READINGS			TYPE	
1	<u>20.7</u>	<u>21.5</u>	<u>22.0</u>	<u>4 x 4</u>	
2	<u>20.2</u>	<u>19.8</u>	<u>20.5</u>	<u>4 x 4</u>	
3	<u>20.8</u>	<u>21.8</u>	<u>22.3</u>	<u>4 x 4</u>	
4	<u>21.2</u>	<u>21.5</u>	<u>21.0</u>	<u>4 x 4</u>	
5	<u> </u>	<u> </u>	<u> </u>	<u> </u>	
6	<u> </u>	<u> </u>	<u> </u>	<u> </u>	
7	<u> </u>	<u> </u>	<u> </u>	<u> </u>	
8	<u> </u>	<u> </u>	<u> </u>	<u> </u>	
9	<u> </u>	<u> </u>	<u> </u>	<u> </u>	
10	<u> </u>	<u> </u>	<u> </u>	<u> </u>	
OVERALL TEST FUEL LOAD MOISTURE AVERAGE: <u>21.1 %</u>					
Time (clock): <u>7:30</u>	Room Temperature (F): <u>70 °F</u>			Initials: <u>dc</u>	

Technician signature: Ralph Date: 4/27/10

Run Notes

Scrapped
A/GM, filing


Client: MenesesModel: Defiant 2N1Project #: 2275-34-3Tracking #: 1534Run #: 10Date: 4/27/10Test Crew: JC

OMNI Equipment ID #(s): _____

PREBURN

DESCRIBE OR SKETCH AIR OR THERMOMSTAT SETTINGS BELOW:
(SETTINGS MUST BE ACCURATE AND REPRODUCABLE)

PRIMARY:

SECONDARY: N/A


TERTIARY: _____

FAN: OFFPREBURN SETTINGS AND ACTIVITIES

TIME	AIR (THERMO) CHANGES PRIMARY/SECONDARY/TERTIARY	FAN SETTING CHANGE	ADD FUEL + WT.	ADD FUEL - WT.	RAKE COAL	COMMENT
0	Test setting				X	
61 min					X	
94					X	
114					X	
124	Fuel on, test start		0.90 lb		X	


TEST

TEST FUEL CONFIGURATION SKETCH
(INDICATE VIEW ANGLE)

START UP PROCEDURESBYPASS: 1 min, 15 secFUEL LOADING 1 minDOOR: 1 min, 15 secPRIMARY AIR: Test setting @ 0 min, no changeOTHER: N/A

DESCRIBE OR SKETCH TEST SETTINGS BELOW:
(SETTINGS MUST BE ACCURATE AND REPRODUCIBLE)

PRIMARY:

SECONDARY: N/A

TERTIARY: _____

FAN: OFFTechnician signature: JJCDate: 4/27/10

4-98 OF 4-155

OMNI-Test Laboratories, Inc.

Supplemental Data EPA 5G/5H

Client: Messina

Model: Draft 2N1

Project #: 227-5-39-3 Tracking #: 1534

Date: 4/27/10 Run #: 1 Booth: _____

Test Crew: JL Start Time: _____ Stop Time: _____

OMNI Equipment #(s): _____

Gas Analyzer Train Leak Check:

Stack:

Dilution Tunnel (Method 5G Only):

Initial: _____

Initial: _____

Final: _____

Final: _____

Calibrations: Span Gas CO₂: _____ O₂: _____ CO: _____ CO₂(DT): _____

Time	N ₂ Span						
O ₂							
CO ₂							
CO							
CO ₂ (DT)							

Stack Diameter (inches): 6

Air Velocity (ft/min): Initial: <60 Final: <50

Scale Audit (lbs): Pretest: 10.0 Post Test: _____

Induced Draft: 0 %Smoke Capture: 100%

Pitot Tube Leak Test: Pre: 0.0 @ 3.1 Post: 0.0 @ 3.0

Flue Pipe Cleaned Prior to First Test in Series: Date: 4/18/10 Initials: JL

	Initial	Middle	Ending
Pb (in/Hg)	28.86 in Hg		
Room Temp (°F)	74 °F		

Technician signature: JL Date: 4/27/10

4-96 OF 4-159

Model: Defiant
Monessen Hearth Systems
P.O. Box 501
Bethel, VT 05032

Run 11

Wood Heater Test Data - EPA Method 5G

Manufacturer: Monessen
 Model: Defiant 2N1
 Project No.: 227-S-39-3
 Tracking No.: 1534
 Run: 11
 Test Date: 04/27/10

Burn Rate	0.89 kg/hr dry
Average Tunnel Temperature Average Gas Velocity in Dilution Tunnel - vs Average Gas Flow Rate in Dilution Tunnel - Qsd	90 degrees Fahrenheit 13.6 feet/second 8586.1 dscf/hour
Average Delta p Average Delta H Total Time of Test	0.038 inches H2O 0.00 inches H2O 570 minutes

	AVERAGE	SAMPLE TRAIN 1	SAMPLE TRAIN 2
Total Sample Volume - Vm	85.05 cubic feet	90.00 cubic feet	80.11 cubic feet
Average Gas Meter Temperature	75 degrees Fahrenheit	74 degrees Fahrenheit	75 degrees Fahrenheit
Total Sample Volume (Standard Conditions) - Vmstd	80.8 dscf	85.5 dscf	76.2 dscf
Total Particulates - mn		39.6 mg	38 mg
Particulate Concentration (dry-standard)	0.00048 grams/dscf	0.00046 grams/dscf	0.00050 grams/dscf
Particulate Emission Rate	4.13 grams/hour	3.98 grams/hour	4.28 grams/hour
Adjusted Emissions	5.91 grams/hour	5.73 grams/hour	6.09 grams/hour
Difference from Average		0.18 grams/hour	0.18 grams/hour
7.5% of the average emission rate	0.44		
Weighted Average Emission Rate Limit	4.10 grams/hour		
7.5% of the weighted average emission rate limit	0.31		
Results Are Acceptable			

Wood Heater Test Data - EPA Method 5G

Run:	11
Manufacturer:	Monessen
Model:	Defiant 2N1
Tracking No.:	1534
Project No.:	227-S-39-3
Test Date:	27-Apr-10
Beginning Clock Time:	16:54
Recording Interval:	10 min.
Total Sampling Time:	570 min.

	Velocity Traverse Data							
	Pt.1	Pt.2	Pt.3	Pt.4	Pt.5	Pt.6	Pt.7	Pt.8
Initial dP	0.032	0.044	0.054	0.044	0.030	0.044	0.050	0.042
Initial Temp.	91	91	91	91	91	91	91	91

"H₂O

OMNI Equipment Numbers: _____

PM Control Module:	13.64	ft/sec.	
Dilution Tunnel MW(dry):	29.00	lb/lb-mole	
Dilution Tunnel MW(wet):	28.56	lb/lb-mole	
Dilution Tunnel H ₂ O:	4.00	percent	
Dilution Tunnel Static:	-0.166	"H ₂ O	
Pitot Tube Cp:	0.99		
Meter Box Y Factor:	0.994 (1)	0.996 (2)	
Barometric Pressure:	Begin 28.88	Middle 28.98	Average 28.93 "Hg
Total Particulate (1):	39.6	Total Particulate (2): 38.0	

Signature/Date: *JL* 6/4/10

Tunnel Velocity:	13.64	ft/sec.
Initial Tunnel Flow:	148.6	scfm
Average Tunnel Flow:	143.1	scfm
Tunnel Area:	0.1963 ft ²	
Post-Test Leak Check (1):	0.0@95 cfm@"Hg	
Post-Test Leak Check (2):	0.0@99 cfm@"Hg	
Fuel Moisture (dry basis %):	20.4	

Elapsed Time	Particulate Sampling Data												Wood Heater Temperature Data, °F																	
	Gas Meter Cubic Feet (1)	Gas Meter Cubic Feet (2)	Sample Rate, cfm (1)	Sample Rate, cfm (2)	Orifice dH (1)	Orifice dH (2)	Meter oF (1)	Meter oF (2)	Meter Vac.	Meter Vac.	Dilution Tunnel dP	Dilution Tunnel Temp.	Pro. Rate (10%) (1)	Pro. Rate (10%) (2)	Scale Reading	Weight Change	Firebox Top	Firebox Bottom	Firebox Back	Firebox Left	Firebox Right	Catalyst Exit	Average Surface	Stack	Filter (1)	Filter (2)	Impinger exit (1)	Impinger exit (2)	Ambient	Draft In. H ₂ O
0	188.218	569.468	0.16	0.15	0.00	0.00	72	73			91	0.043	22.4		404	267	369	284	291		323.0	282	69	69			69	0.040		
10	189.851	570.922	0.16	0.15	0.00	0.00	72	72			93	0.039	105	105	21.8	-0.6	324	256	360	265	271		295.2	321	70	72			70	0.045
20	191.488	572.362	0.16	0.14	0.00	0.00	73	73			96	0.039	105	104	21.1	-0.7	284	245	382	243	248		280.4	371	72	70			72	0.050
30	193.092	573.780	0.16	0.14	0.00	0.00	72	73			100	0.039	104	103	20.3	-0.85	276	231	417	226	231		276.2	415	72	72			72	0.055
40	194.690	575.193	0.16	0.14	0.00	0.00	72	73			106	0.039	104	103	19.2	-1.05	298	222	456	217	224		283.4	447	72	72			70	0.060
50	196.285	576.608	0.16	0.14	0.00	0.00	72	73			109	0.038	105	105	18.1	-1.15	330	211	482	213	222		291.6	458	72	72			72	0.060
60	197.864	578.015	0.16	0.14	0.00	0.00	73	74			110	0.039	103	103	16.9	-1.15	378	205	493	216	224		303.2	454	74	74			70	0.060
70	199.450	579.414	0.16	0.14	0.00	0.00	73	75			112	0.040	102	101	15.8	-1.15	411	201	495	220	231		311.6	461	74	74			72	0.060
80	201.029	580.820	0.16	0.14	0.00	0.00	74	74			112	0.040	102	102	14.6	-1.2	444	195	498	223	244		320.8	461	75	75			71	0.060
90	202.625	582.220	0.16	0.14	0.00	0.00	73	74			114	0.039	104	103	13.4	-1.15	487	195	507	231	259		335.8	474	75	75			73	0.063
100	204.207	583.633	0.16	0.14	0.00	0.00	74	75			111	0.039	103	103	12.3	-1.1	511	188	509	235	274		343.4	448	75	75			70	0.060
110	205.800	585.048	0.16	0.14	0.00	0.00	74	75			107	0.040	102	102	11.4	-0.95	504	188	494	242	292		344.0	416	75	75			71	0.060
120	207.383	586.457	0.16	0.14	0.00	0.00	74	75			103	0.039	102	102	10.6	-0.8	494	182	461	247	307		338.2	375	75	73			71	0.055
130	208.968	587.879	0.16	0.14	0.00	0.00	74	75			99	0.039	102	103	9.9	-0.7	479	184	425	249	321		331.6	342	73	73			71	0.050
140	210.552	589.299	0.16	0.14	0.00	0.00	74	75			96	0.041	99	100	9.3	-0.6	457	180	392	247	325		320.2	316	73	73			69	0.058
150	212.139	590.721	0.16	0.14	0.00	0.00	74	75			95	0.039	102	102	8.7	-0.55	444	180	364	249	329		313.2	301	73	73			71	0.045
160	213.725	592.143	0.16	0.14	0.00	0.00	74	75			93	0.040	100	101	8.2	-0.55	440	178	344	247	329		307.6	292	73	71			71	0.040
170	215.304	593.561	0.16	0.14	0.00	0.00	74	75			92	0.041	99	99	7.7	-0.45	429	178	329	245	327		301.6	286	71	71			69	0.043
180	216.885	594.982	0.16	0.14	0.00	0.00	74	75			91	0.041	99	99	7.3	-0.4	414	173	316	240	323		293.2	275	71	71			71	0.040

Wood Heater Test Data - EPA Method 5G

Run:	11
Manufacturer:	Monessen
Model:	Defiant 2NI
Tracking No.:	1534
Project No.:	227-S-39-3
Test Date:	27-Apr-10
Beginning Clock Time:	16:54
Recording Interval:	10 min.
Total Sampling Time:	570 min.

Velocity Traverse Data							
	Pt.1	Pt.2	Pt.3	Pt.4	Pt.5	Pt.6	Pt.7
Initial dP	0.032	0.044	0.054	0.044	0.030	0.044	0.050
Initial Temp.	91	91	91	91	91	91	91

°H₂O

OMNI Equipment Numbers: _____

PM Control Module:				
Dilution Tunnel MW(dry):	29.00	lb/lb-mole		
Dilution Tunnel MW(wet):	28.56	lb/lb-mole		
Dilution Tunnel H ₂ O:	4.00	percent		
Dilution Tunnel Static:	-0.166	"H ₂ O		
Pitot Tube Cp:	-0.99			
Meter Box Y Factor:	0.994 (1)	0.996 (2)	Fuel Moisture (dry basis %): 20.4	
Barometric Pressure:	Begin	Middle	End	
	28.88	28.98	28.92	Average 28.93 "Hg
				Total Particulate (1): 39.6
				Total Particulate (2): 38.0

Elapsed Time	Particulate Sampling Data												Wood Heater Temperature Data, °F												Stack				
	Gas Meter Cubic Feet (1)	Gas Meter Cubic Feet (2)	Sample Rate, cfm (1)	Sample Rate, cfm (2)	Orifice dH (1)	Orifice dH (2)	Meter Vac. of (1)	Meter Vac. of (2)	Meter Vac. In. Hg. (1)	Meter Vac. In. Hg. (2)	Dilution Tunnel Temp.	Dilution Tunnel dP	Pro. Rate (10%) (1)	Pro. Rate (10%) (2)	Scale Reading	Weight Change	Firebox Top	Firebox Bottom	Firebox Back	Firebox Left	Firebox Right	Catalyst Exit	Average Surface	Stack	Filter (1)	Filter (2)	Impinger exit (1)	Impinger exit (2)	Ambient
430	256.227	629.990	0.16	0.14	0.00	0.00	76	76			83	0.039	99	99	1.8	-0.1	337	170	189	220	235		230.2	181	70	70		74	0.025
440	257.799	631.392	0.16	0.14	0.00	0.00	76	76			83	0.040	98	98	1.7	-0.15	326	166	185	216	231		224.8	179	70	70		74	0.025
450	259.373	632.788	0.16	0.14	0.00	0.00	76	76			83	0.039	100	99	1.6	-0.1	320	166	181	218	224		221.8	175	68	70		74	0.025
460	260.946	634.192	0.16	0.14	0.00	0.00	76	76			83	0.039	99	100	1.5	-0.1	316	166	179	218	218		219.4	171	70	70		75	0.023
470	262.516	635.591	0.16	0.14	0.00	0.00	76	76			83	0.039	99	99	1.4	-0.1	311	164	177	218	211		216.2	170	68	70		74	0.023
480	264.085	636.986	0.16	0.14	0.00	0.00	76	76			82	0.039	99	99	1.3	-0.1	305	164	175	218	207		213.8	167	68	71		75	0.023
490	265.655	638.383	0.16	0.14	0.00	0.00	76	76			82	0.039	99	99	1.2	-0.1	298	162	170	222	203		211.0	162	70	70		74	0.020
500	267.230	639.779	0.16	0.14	0.00	0.00	76	76			82	0.038	101	100	1.0	-0.2	313	162	171	242	201		217.8	162	70	70		75	0.020
510	268.802	641.180	0.16	0.14	0.00	0.00	76	76			82	0.039	99	99	0.8	-0.15	318	158	169	257	201		220.6	160	68	70		75	0.020
520	270.371	642.583	0.16	0.14	0.00	0.00	76	76			82	0.039	99	100	0.7	-0.1	316	158	169	266	199		221.6	160	68	70		75	0.020
530	271.940	643.982	0.16	0.14	0.00	0.00	77	76			82	0.039	99	99	0.6	-0.15	311	155	166	268	196		219.2	160	70	70		74	0.020
540	273.512	645.388	0.16	0.14	0.00	0.00	77	76			82	0.039	99	100	0.5	-0.1	305	156	164	270	194		217.8	158	71	71		75	0.020
550	275.078	646.782	0.16	0.14	0.00	0.00	76	77			82	0.039	99	99	0.4	-0.05	301	154	164	266	190		215.0	156	68	71		75	0.018
560	276.645	648.175	0.16	0.14	0.00	0.00	77	77			82	0.039	99	99	0.2	-0.2	285	151	164	259	186		209.0	164	70	70		75	0.020
570	278.213	649.574	0.16	0.14	0.00	0.00	77	76			83	0.039	99	99	0.0	-0.2	279	151	166	246	181		204.6	177	68	70		75	0.020
Avg/Total	89.995	80.106	0.16	0.14	0.00	0.00	74.28	74.74			90.00	0.039	100.85	100.85								118	70.45	70.71	#DIV/0!	#DIV/0!		0.035	

PRINT

**Final Laboratory Report - Method 5G Dual Train
Dilution Tunnel Particulate Calculations**

Client Name: Monessen
 Model: Defiant 2N1
 Project No.: 227-S-39-3
 Tracking No.: 1534

Equipment Numbers: OMNI-00023
OMNI-00131
OMNI-00342
VC-1

Run #: 11
 Train #: A
 Date: 04/27/10

Sample Component	Reagent	Filter # or Probe #	Weights		
			Final, mg	Tare, mg	Particulate, mg
A. Front filter catch	Filter	F570	152.2	116.2	36.0
B. Rear filter catch	Filter	F571	122.8	120.9	1.9
C. Probe catch	Probe	VC-B	84218.8	84217.1	1.7

Total Particulate, mg :	39.6
-------------------------	------

Component	Equations:
A. Front filter catch	Final (mg) - Tare (mg) = Particulate, mg
B. Rear filter catch	Final (mg) - Tare (mg) = Particulate, mg
C. Probe catch	Final (mg) - Tare (mg) = Particulate, mg

Analyst: Date: 6/2/10

PRINT

**Final Laboratory Report - Method 5G Dual Train
Dilution Tunnel Particulate Calculations**

Client Name: Monessen
 Model: Defiant 2N1
 Project No.: 227-S-39-3
 Tracking No.: 1534

Equipment Numbers:
OMNI-00023
OMNI-00131
OMNI-00342
VC-1

Run #: 11
 Train #: B
 Date: 04/27/10

Sample Component	Reagent	Filter # or Probe #	Weights		
			Final, mg	Tare, mg	Particulate, mg
A. Front filter catch	Filter	F570	160.7	125.9	34.8
B. Rear filter catch	Filter	F571	118.1	116.6	1.5
C. Probe catch	Probe	VC-B	75950.5	75948.8	1.7

Total Particulate, mg :	38.0
-------------------------	------

Component	Equations:
A. Front filter catch	Final (mg) - Tare (mg) = Particulate, mg
B. Rear filter catch	Final (mg) - Tare (mg) = Particulate, mg
C. Probe catch	Final (mg) - Tare (mg) = Particulate, mg

Analyst: Date: 6/2/10

STOVE TEMPERATURE TEST DATA - METHOD 5G

Page ____ of ____

Client/Model: Monessen / Defiant 2N1Project #: 227-5-39-3 Tracking #: 1534Date: 4/27/10 Test Crew: ACOMNI Equipment ID #:

Preburn Test #	Coal Bed:					Actual: Coal Bed:				
	Fuel Weight	Delta Weight	Stack Draft	Ambient	Top	Bottom	Back	Left	Right	Flue
0	15.57	—	68							N/A
10	14.64	0.43	0.049	72	587	378	243	254	380	297
20	13.85	0.32	0.044	72	493	348	259	255	363	270
30	13.40	0.18	0.040	70	448	320	263	246	346	246
40	13.05	0.13	0.038	70	426	302	259	237	332	233
50	12.50	0.25	0.037	70	378	287	255	231	315	237
60	11.84	0.28	0.036	70	343	271	252	224	302	235
70	10.60	0.54	0.057	70	343	263	267	217	293	400
80	9.39	0.50	0.062	69	338	256	386	215	291	458
90	8.25	0.46	0.064	69	356	254	468	217	293	471
100	8.00	0.32	0.060	69	382	260	496	225	295	425
110	6.86	0.22	0.056	69	403	264	490	238	297	390
120	6.39	0.18	0.052	69	416	273	466	251	297	355
130	5.91	0.20	0.051	69	416	275	449	264	297	353
140	5.71	0.09	0.048	69	412	271	430	275	295	330
150	5.49	0.51	0.045	71	410	271	406	282	293	308
160	5.36	0.06	0.043	71	406	267	380	284	290	270
70										
80										
90										
AVG										

Technician signature: J. ClarkDate: 5/6/10

FUEL DATA

Client: Monterra

Model: Defiant 2N1

Project #: 227-3-31-Tracking #: 1534

Date: 4/27/10 Test Crew: SC Run #: 11


OMNI Equipment ID #:

FUEL LOAD PREPARED BY: Ralph ; moisture & measures by SC

FUEL: DOUGLAS-FIR SPECIES, UNTREATED, AIR-DRIED, STANDARD GRADE OR BETTER, DIMENSIONAL LUMBER.

PRE-BURN FUEL					
MOISTURE CONTENT (METER -- DRY BASIS)					
CALIBRATION:	Cal Value (1) = 12%	Actual Reading	12.0 %		
	Cal Value (2) = 22%	Actual Reading	22.0 %		
Piece	Length	Readings		Type	
1	14.3 ft	22.6	22.7	2x4	
2	14.3 ft	22.0	17.3	18.4	2x4
3	ft				
Length of cut pieces: 43 x 8 inches			Pre-Burn Fuel Average Moisture: 20.7 %		
Time (clock): 12:50 Room Temperature (F): 70 °F Initials: SC					

TEST FUEL					
FUEL TYPE AND AMOUNT:		2 x 4	4 x 4		
CALCULATED LOAD WEIGHT:				ACTUAL LOAD WEIGHT:	0 (2 x 4) 22.40 lb (4 x 4) 22.40 lb Total
FUEL PIECE LENGTH:		21 inches			
MOISTURE CONTENT (METER -- DRY BASIS)					
PIECE	READINGS			TYPE	
1	22.6	20.2	19.5	4 x 4	
2	20.1	21.0	20.0	4 x 4	
3	19.6	19.7	20.1	4 x 4	
4	20.4	20.8	21.3	4 x 4	
5					
6					
7					
8					
9					
10					
OVERALL TEST FUEL LOAD MOISTURE AVERAGE: 20.4 %					
Time (clock): 1:00		Room Temperature (F): 70 °F		Initials: SC	

Technician signature: 

Date: 4/27/10

Run Notes

Client: Monessen
 Model: Defiant 2N1


Project #: 22-7-S-39-7Tracking #: 1534Run #: 11 Date: 4/27/10Test Crew: JC

OMNI Equipment ID #(s): _____

PREBURN

DESCRIBE OR SKETCH AIR OR THERMOMSTAT SETTINGS BELOW:
 (SETTINGS MUST BE ACCURATE AND REPRODUCABLE)


PRIMARY:

SECONDARY: N/ATERTIARY: ↓FAN: OFFPREBURN SETTINGS AND ACTIVITIES

TIME	AIR (THERMO) CHANGES PRIMARY/SECONDARY/TERTIARY	FAN SETTING CHANGE	ADD FUEL + WT.	ADD FUEL - WT.	RAKE COAL	COMMENT
0	Test setting					
45					X	
66					X	
124					X	
164	Test fuel on				X	


TEST

TEST FUEL CONFIGURATION SKETCH
 (INDICATE VIEW ANGLE)



DESCRIBE OR SKETCH TEST SETTINGS BELOW:
 (SETTINGS MUST BE ACCURATE AND REPRODUCABLE)

PRIMARY:



START UP PROCEDURES

BYPASS: 1 min, 15 secFUEL LOADING noneDOOR: 1 min, 15 secPRIMARY AIR: Test setting @ 0 min, no changeOTHER: N/ASECONDARY: N/ATERTIARY: ↓FAN: OFFTechnician signature: [Signature]Date: 4/27/10

Supplemental Data EPA 5G/5H

Client: MaversonModel: 227-5-34-3 ^{dc} Defiant 2N1Project #: 227-5-34-3 Tracking #: 1534Date: 4/27/10 Run #: 11 Booth: _____Test Crew: JL Start Time: 4:54 PM Stop Time: 2:24 AM

OMNI Equipment #(s): _____

Gas Analyzer Train Leak Check:

Stack: _____

Dilution Tunnel (Method 5G Only): _____

Initial: _____

Initial: _____

Final: _____

Final: _____

Calibrations: Span Gas CO₂: _____ O₂: _____ CO: _____ CO₂(DT): _____

Time	N ₂ Span						
O ₂							
CO ₂							
CO							
CO ₂ (DT)							

Stack Diameter (inches): 6Air Velocity (ft/min): Initial: <50 Final: <50Scale Audit (lbs): Pretest: 10.0 Post Test: _____Induced Draft: 0 %Smoke Capture: 100%Pilot Tube Leak Test: Pre: 0.0 ± 3.1 Post: 0.0 ± 3.0Flue Pipe Cleaned Prior to First Test in Series: Date: 4/18/10 Initials: JL

	Initial	Middle	Ending
Pb (in/Hg)	28.88 in Hg	28.98 in Hg	28.92 in Hg
Room Temp (°F)	73 °F 69 °C	75 °F	76 °F 73 °C

Technician signature: J. L. L. Date: 4/28/10

4-106 OF 4-155

*Model: Defiant
Monessen Hearth Systems
P.O. Box 501
Bethel, VT 05032*

Run 12

Wood Heater Test Data - EPA Method 5G

Manufacturer: Monessen
 Model: Defiant 2N1
 Project No.: 227-S-39-3
 Tracking No.: 1534
 Run: 12
 Test Date: 04/28/10

Burn Rate	2.61 kg/hr dry
Average Tunnel Temperature	141 degrees Fahrenheit
Average Gas Velocity in Dilution Tunnel - vs	14.2 feet/second
Average Gas Flow Rate in Dilution Tunnel - Qsd	8221.7 dscf/hour
Average Delta p	0.039 inches H2O
Average Delta H	0.00 inches H2O
Total Time of Test	180 minutes

	AVERAGE	SAMPLE TRAIN 1	SAMPLE TRAIN 2
Total Sample Volume - Vm	27.04 cubic feet	28.31 cubic feet	25.78 cubic feet
Average Gas Meter Temperature	78 degrees Fahrenheit	78 degrees Fahrenheit	79 degrees Fahrenheit
Total Sample Volume (Standard Conditions) - Vmsld	25.6 dscf	26.8 dscf	24.4 dscf
Total Particulates - mn		14.6 mg	14.2 mg
Particulate Concentration (dry-standard)	0.00056 grams/dscf	0.00054 grams/dscf	0.00058 grams/dscf
Particulate Emission Rate	4.63 grams/hour	4.48 grams/hour	4.78 grams/hour
Adjusted Emissions	6.49 grams/hour	6.31 grams/hour	6.67 grams/hour
Difference from Average		0.18 grams/hour	0.18 grams/hour
7.5% of the average emission rate	0.49		
Weighted Average Emission Rate Limit	4.10 grams/hour		
7.5% of the weighted average emission rate limit	0.31		
Results Are Acceptable			

Wood Heater Test Data - EPA Method 5G

Run: 12
 Manufacturer: Monessen
 Model: Defiant 2N1
 Tracking No.: 1534
 Project No.: 227-S-39-3
 Test Date: 28-Apr-10
 Beginning Clock Time: 12:39
 Recording Interval: 10 min.
 Total Sampling Time: 180 min.

Velocity Traverse Data							
	Pt.1	Pt.2	Pt.3	Pt.4	Pt.5	Pt.6	Pt.8
Initial dP	0.030	0.042	0.046	0.045	0.034	0.046	0.042
Initial Temp.	124	124	124	124	124	124	124

°H₂O

OMNI Equipment Numbers:

PM Control Module:
 Dilution Tunnel MW(dry): 29.00 lb/lb-mole
 Dilution Tunnel MW(wet): 28.56 lb/lb-mole
 Dilution Tunnel H₂O: 4.00 percent
 Dilution Tunnel Static: -0.64 °H₂O
 Pitot Tube Cp: 0.99
 Meter Box Y Factor: 0.994 (1) 0.996 (2)
 Barometric Pressure: Begin Middle End Average
 28.95 29.04 29.1 29.03 °Hg Total Particulate (1): 14.6
 Total Particulate (2): 14.2

Elapsed Time	Particulate Sampling Data												Wood Heater Temperature Data, °F																	
	Gas Meter Cubic Feet (1)	Gas Meter Cubic Feet (2)	Sample Rate, cfm (1)	Sample Rate, cfm (2)	Orifice dH (1)	Orifice dH (2)	Meter oF (1)	Meter oF (2)	Meter Vac In. Hg (1)	Meter Vac In. Hg (2)	Dilution Tunnel Temp.	Dilution Tunnel dP	Pro. Rate (10%) (1)	Pro. Rate (10%) (2)	Scale Reading	Weight Change	Firebox Top	Firebox Bottom	Firebox Back	Firebox Left	Firebox Right	Catalyst Exit	Average Surface	Stack	Filter (1)	Filter (2)	Impinger exit (1)	Impinger exit (2)	Ambient	Draft In. H ₂ O
0	278.253	649.603			0.00	0.00	74	75			124	0.041			22.4		616	318	400	366	409		421.8	398	79	81			73	0.060
10	279.897	651.095	0.16	0.15	0.00	0.00	75	75			129	0.040	103	103	20.9	-1.45	488	303	444	340	366		388.2	554	82	84			73	0.068
20	281.512	652.543	0.16	0.14	0.00	0.00	75	76			146	0.038	106	104	18.9	-2.05	533	286	518	312	345		398.8	638	86	86			71	0.073
30	283.087	653.967	0.16	0.14	0.00	0.00	75	77			155	0.038	104	103	16.5	-2.35	568	272	579	300	363		416.4	641	89	91			76	0.075
40	284.662	655.390	0.16	0.14	0.00	0.00	76	77			165	0.038	104	104	14.3	-2.25	613	259	605	298	413		437.6	679	91	93			74	0.080
50	286.218	656.800	0.16	0.14	0.00	0.00	77	78			168	0.041	99	99	11.8	-2.5	707	246	633	307	446		467.8	686	81	89			77	0.080
60	287.768	658.213	0.15	0.14	0.00	0.00	75	77			168	0.038	103	103	9.6	-2.2	724	240	646	323	435		473.6	682	77	84			75	0.080
70	289.325	659.632	0.16	0.14	0.00	0.00	77	79			160	0.038	103	103	7.8	-1.75	725	230	647	338	427		473.4	649	74	82			76	0.080
80	290.882	661.051	0.16	0.14	0.00	0.00	79	80			157	0.038	102	102	6.0	-1.8	742	228	641	354	434		479.8	636	72	80			76	0.080
90	292.446	662.483	0.16	0.14	0.00	0.00	79	80			150	0.039	101	101	4.7	-1.3	738	224	622	370	463		483.4	590	70	81			75	0.075
100	294.005	663.913	0.16	0.14	0.00	0.00	79	81			143	0.042	96	97	3.6	-1.15	770	223	582	396	463		486.8	539	69	79			75	0.070
110	295.564	665.331	0.16	0.14	0.00	0.00	79	81			137	0.042	96	95	2.7	-0.85	773	225	528	427	461		482.8	500	69	77			75	0.065
120	297.129	666.756	0.16	0.14	0.00	0.00	79	81			133	0.038	101	100	2.1	-0.65	739	225	483	446	459		470.4	472	69	75			75	0.065
130	298.697	668.187	0.16	0.14	0.00	0.00	79	81			129	0.038	100	101	1.6	-0.45	672	228	449	451	451		450.2	456	69	76			76	0.060
140	300.263	669.621	0.16	0.14	0.00	0.00	79	80			126	0.038	100	101	1.2	-0.4	636	230	421	447	434		433.6	436	69	76			74	0.060
150	301.831	671.052	0.16	0.14	0.00	0.00	79	81			123	0.039	99	99	0.8	-0.4	615	230	397	436	419		419.4	421	69	73			73	0.055
160	303.397	672.482	0.16	0.14	0.00	0.00	79	80			120	0.038	100	100	0.5	-0.35	602	230	379	427	412		410.0	410	71	76			73	0.055
170	304.997	673.946	0.16	0.15	0.00	0.00	79	80			119	0.038	102	102	0.1	-0.4	588	234	364	416	401		400.6	401	71	75			73	0.055
180	306.560	675.380	0.16	0.14	0.00	0.00	79	79			118	0.037	100	101	0.0	-0.05	580	236	353	405	392		393.2	390	73	75			75	0.055
Avg/Total	28.307	25.777	0.16	0.14	0.00	0.00	77.53	78.84			140.53	0.039	101.02	101.01								29		75.26	80.68	#DIV/0!	#DIV/0!		0.068	

PRINT

**Final Laboratory Report - Method 5G Dual Train
Dilution Tunnel Particulate Calculations**

Client Name: Monesson
 Model: Defiant 2NI
 Project No.: 227-S-39-3
 Tracking No.: 1534

Equipment Numbers: OMNI-00023
OMNI-00131
OMNI-00342
VC-1

Run #: 12
 Train #: A
 Date: 04/28/10

Sample Component	Reagent	Filter # or Probe #	Weights		
			Final, mg	Tare, mg	Particulate, mg
A. Front filter catch	Filter	F574	132.7	120.2	12.5
B. Rear filter catch	Filter	F575	126.8	125.3	1.5
C. Probe catch	Probe	22	114341.0	114340.4	0.6

Total Particulate, mg :	14.6
-------------------------	------

Component	Equations:
A. Front filter catch	Final (mg) - Tare (mg) = Particulate, mg
B. Rear filter catch	Final (mg) - Tare (mg) = Particulate, mg
C. Probe catch	Final (mg) - Tare (mg) = Particulate, mg

Analyst:

Date: 4/28/10

PRINT

**Final Laboratory Report - Method 5G Dual Train
Dilution Tunnel Particulate Calculations**

Client Name: Mouessen
 Model: Defiant 2NI
 Project No.: 227-S-39-3
 Tracking No.: 1534

Equipment Numbers: OMNI-00023
 OMNI-00131
 OMNI-00342
 VC-I

Run #: 12
 Train #: B
 Date: 04/28/10

Sample Component	Reagent	Filter # or Probe #	Weights		
			Final, mg	Tare, mg	Particulate, mg
A. Front filter catch	Filter	F576	128.4	116.6	11.8
B. Rear filter catch	Filter	F577	122.2	120.8	1.4
C. Probe catch	Probe	38	114146.3	114145.3	1.0

Total Particulate, mg:	14.2
------------------------	------

Component	Equations:
A. Front filter catch	Final (mg) - Tare (mg) = Particulate, mg
B. Rear filter catch	Final (mg) - Tare (mg) = Particulate, mg
C. Probe catch	Final (mg) - Tare (mg) = Particulate, mg

Analyst:



Date: 6/2/10

STOVE TEMPERATURE TEST DATA - METHOD 5G

ClientModel: Monessen/Definit 2N1

Date: 4/28/10 Test Crew:

OMNI Equipment ID #:

Page _____ of _____

Project #: 227-5-39-3

J. P.

Run #:

MAIL #. 2

卷之三

Technician signature:

Chen

Date: 5/16/10

11

FUEL DATA

Client: MoenessanModel: Defeat 2N1Project #: 122439-3 Tracking #: 1534Date: 4/28/10 Test Crew: JC Run #: 12

OMNI Equipment ID #:

FUEL LOAD PREPARED BY: Ralph G; moisture & dimension check by JCFUEL: DOUGLAS-FIR SPECIES, UNTREATED, AIR-DRIED, STANDARD GRADE OR BETTER,
DIMENSIONAL LUMBER.

PRE-BURN FUEL

MOISTURE CONTENT (METER -- DRY BASIS)

CALIBRATION: Cal Value (1) = 12% Actual Reading 12.0%
 Cal Value (2) = 22% Actual Reading 22.0%

Piece	Length	Readings	Type
1	14 ft	18.5	2x4
2	14 ft	18.8	2x4
3	ft		

35.2 lb

Length of cut pieces: 42 x 8 inchesPre-Burn Fuel Average Moisture: 19.95%Time (clock): 9:25 Room Temperature (F): 70°F Initials: JC


TEST FUEL

FUEL TYPE AND AMOUNT: 2 x 4 6 4 x 4 4
 CALCULATED LOAD WEIGHT: _____ ACTUAL LOAD WEIGHT: 15 (2 x 4)
22.35 (4 x 4)

FUEL PIECE LENGTH: 21 inches 22.35 Total

MOISTURE CONTENT (METER -- DRY BASIS)

PIECE	READINGS	TYPE
1	20.4	4x4
2	19.8	4x4
3	20.0	4x4
4	20.8	4x4
5		
6		
7		
8		
9		
10		

OVERALL TEST FUEL LOAD MOISTURE AVERAGE: 20.18%Time (clock): 9:30 AM Room Temperature (F): 70°F Initials: JCTechnician signature: Date: 4/28/10


Run Notes

Client: Maverson
Model: Defiant 2N1
Project #: 227-5-39-3
Tracking #: 1534
Run #: 12
Test Crew: J
OMNI Equipment ID #:

PREBURN

**DESCRIBE OR SKETCH AIR OR THERMOMSTAT SETTINGS BELOW:
(SETTINGS MUST BE ACCURATE AND REPRODUCABLE)**

PRIMARY



SECONDARY: : N/A


TERTIARY:

FAN

PREBURN SETTINGS AND ACTIVITIES

TIME	AIR (THERMO) CHANGES PRIMARY/SECONDARY/TERTIALY	FAN SETTING CHANGE	ADD FUEL + WT.	ADD FUEL - WT.	RAKE COAL	COMMENT
0	Test setting					
21					X	
35					X	
65					X	
82	Test start ⁺ Test start, fuel on				X	

**TEST FUEL CONFIGURATION SKETCH
(INDICATE VIEW ANGLE)**



TEST

START UP PROCEDURES

BYPASS:

FUEL LOADING


DOOR:

PRIMARY AIR: Test setting @ 0 min no change

OTHER.

DESCRIBE OR SKETCH TEST SETTINGS BELOW:
(SETTINGS MUST BE ACCURATE AND REPRODUCIBLE)
PRIMARY:

PRIMARY:



SECONDARY: N/A

TERTIARY:

FAN: OFF

Technician signature:

Date: 4/20/00

Supplemental Data EPA 5G/5H

Client: MonesenModel: Dektat 2N1Project #: 227-5-34-3 Tracking #: 1534Date: 4/28/10 Run #: 12, Booth: _____Test Crew: JC Start Time: 12:39 Stop Time: 3:39

OMNI Equipment #(s): _____

Gas Analyzer Train Leak Check:

Stack: _____

Dilution Tunnel (Method 5G Only):

Initial: _____

Initial: _____

Final: _____

Final: _____

Calibrations: Span Gas CO₂: _____ O₂: _____ CO: _____ CO₂(DT): _____

Time	N ₂ Span						
O ₂							
CO ₂							
CO							
CO ₂ (DT)							

Stack Diameter (inches): 6Air Velocity (ft/min): Initial: 450 Final: 450Scale Audit (lbs): Pretest: 10.0 Post Test: 10.0Induced Draft: 0 %Smoke Capture: 100 %Pitot Tube Leak Test: Pre: 0.0 @ 3.0 Post: 0.0 @ 3.0Flue Pipe Cleaned Prior to First Test in Series: Date: 4/28/10 Initials: JC

	Initial	Middle	Ending
Pb (in/Hg)	<u>28.98</u> in Hg	<u>29.04</u> in Hg	<u>29.10</u> in Hg
Room Temp (°F)	<u>73.4</u> °F	<u>80</u> °F	<u>75.6</u> °F

Technician signature: J. C. DeLoachDate: 4/28/10

Model: Defiant
Monessen Hearth Systems
P.O. Box 501
Bethel, VT 05032

Run 13

Wood Heater Test Data - EPA Method 5G

Manufacturer: Monessen
Model: Defiant 2N1
Project No.: 227-S-39-3
Tracking No.: 1534
Run: 13
Test Date: 04/29/10

Burn Rate	0.64 kg/hr dry
Average Tunnel Temperature	87 degrees Fahrenheit
Average Gas Velocity In Dilution Tunnel - vs	13.3 feet/second
Average Gas Flow Rate In Dilution Tunnel - Qsd	8528.0 scsf/hour
Average Delta p	0.038 inches H2O
Average Delta H	0.00 inches H2O
Total Time of Test	800 minutes

	AVERAGE	SAMPLE TRAIN 1	SAMPLE TRAIN 2
Total Sample Volume - Vm	117.53 cubic feet	125.05 cubic feet	110.02 cubic feet
Average Gas Meter Temperature	76 degrees Fahrenheit	76 degrees Fahrenheit	77 degrees Fahrenheit
Total Sample Volume (Standard Conditions) - Vmsld	112.8 dscf	120.0 dscf	105.8 dscf
Total Particulates - mn		28.8 mg	27.6 mg
Particulate Concentration (dry-standard)	0.00025 grams/dscf	0.00024 grams/dscf	0.00026 grams/dscf
Particulate Emission Rate	2.14 grams/hour	2.05 grams/hour	2.23 grams/hour
Adjusted Emissions	3.42 grams/hour	3.30 grams/hour	3.54 grams/hour
Difference from Average		0.12 grams/hour	0.12 grams/hour
7.5% of the average emission rate	0.26		
Weighted Average Emission Rate Limit	4.10 grams/hour		
7.5% of the weighted average emission rate limit	0.31		

Wood Heater Test Data - EPA Method 5G

Run: 13
 Manufacturer: Monessen
 Model: Defiant 2N1
 Tracking No.: 1534
 Project No.: 227-S-39-3
 Test Date: 29-Apr-10
 Beginning Clock Time: 12:10
 Recording Interval: 10 min.
 Total Sampling Time: 800 min.

Velocity Traverse Data							
	Pt.1	Pt.2	Pt.3	Pt.4	Pt.5	Pt.6	Pt.7
Initial dP	0.032	0.041	0.044	0.043	0.029	0.040	0.043
Initial Temp.	94	94	94	94	94	94	94

OMNI Equipment Numbers: _____

PM Control Module:							
Dilution Tunnel MW(dry):	29.00	lb/lb-mole					
Dilution Tunnel MW(wet):	28.56	lb/lb-mole					
Dilution Tunnel H2O:	4.00	percent					
Dilution Tunnel Static:	-0.147	"H2O					
Pitot Tube Cp:	0.99						
Meter Box Y Factor:	0.994 (1)	0.996					
Barometric Pressure:	Begin	Middle	End	Average	Total Particulate (1):	28.8	
	29.29	29.3	29.33	29.31	"Hg	Total Particulate (2):	27.6

Signature/Date: *JR* 6/14/00
 Tunnel Velocity: 13.31 ft/sec.
 Initial Tunnel Flow: 143.4 scfm
 Average Tunnel Flow: 142.1 scfm
 Tunnel Area: 0.1963 ft²
 Post-Test Leak Check (1): 0.0@5 cfm@"Hg
 Post-Test Leak Check (2): 0.0@9 cfm@"Hg
 Fuel Moisture (dry basis %): 19.85
 (2) Total Particulate (1): 28.8
 Total Particulate (2): 27.6

Elapsed Time	Particulate Sampling Data												Wood Heater Temperature Data, °F												Stack				
	Gas Meter Cubic Feet (1)	Gas Meter Cubic Feet (2)	Sample Rate, cfm (1)	Sample Rate, cfm (2)	Orifice dH (1)	Orifice dH (2)	Meter Vac. of (1)	Meter Vac. of (2)	Meter Vac. In. Hg. (1)	Meter Vac. In. Hg. (2)	Dilution Tunnel Temp.	Dilution Tunnel dP	Pro. Rate (10%) (1)	Pro. Rate (10%) (2)	Scale Reading	Weight Change	Firebox Top	Firebox Bottom	Firebox Back	Firebox Left	Firebox Right	Catalyst Exit	Average Surface	Stack	Filter (1)	Filter (2)	Impinger exit (1)	Impinger exit (2)	Ambient
0	306.598	675.417			0.00	0.00	73	74			94	0.039			22.6		374	272	307	265	276		298.8	242	72	72		72	0.035
10	308.252	676.890	0.17	0.15	0.00	0.00	73	74			94	0.040	105	106	22.0	-0.55	304	257	315	246	254		275.2	309	72	70		72	0.040
20	309.865	678.323	0.16	0.14	0.00	0.00	73	74			97	0.038	105	106	21.4	-0.65	266	242	342	227	233		262.0	359	71	71		73	0.045
30	311.463	679.736	0.16	0.14	0.00	0.00	73	74			101	0.038	105	105	20.6	-0.8	255	229	388	214	218		260.8	394	73	71		73	0.050
40	313.051	681.147	0.16	0.14	0.00	0.00	74	75			109	0.039	103	104	19.7	-0.9	259	220	426	207	210		264.4	416	73	71		73	0.050
50	314.630	682.546	0.16	0.14	0.00	0.00	74	75			106	0.039	102	103	18.7	-1	276	214	459	205	205		271.8	428	72	72		72	0.053
60	316.206	683.950	0.16	0.14	0.00	0.00	74	75			107	0.039	102	103	17.6	-1.05	299	208	476	205	203		278.2	433	73	73		73	0.055
70	317.779	685.345	0.16	0.14	0.00	0.00	75	76			107	0.039	102	103	16.6	-1.05	323	206	483	203	206		284.2	427	75	73		73	0.055
80	319.357	686.748	0.16	0.14	0.00	0.00	75	76			107	0.039	102	103	15.6	-1	351	201	483	206	210		290.2	427	75	73		73	0.055
90	320.934	688.153	0.16	0.14	0.00	0.00	75	76			108	0.040	101	102	14.6	-1	388	202	486	210	215		300.2	429	75	73		73	0.055
100	322.509	689.556	0.16	0.14	0.00	0.00	75	76			109	0.039	102	103	13.6	-1	414	202	486	217	223		308.4	429	75	75		73	0.055
110	324.079	690.964	0.16	0.14	0.00	0.00	75	76			108	0.039	102	104	12.7	-0.9	438	200	479	221	230		313.6	410	76	74		74	0.055
120	325.651	692.370	0.16	0.14	0.00	0.00	76	77			107	0.040	100	102	11.9	-0.8	456	200	467	228	239		318.0	402	76	74		74	0.055
130	327.227	693.772	0.16	0.14	0.00	0.00	76	77			105	0.039	102	103	11.1	-0.8	473	200	449	235	248		321.0	371	76	74		74	0.055
140	328.803	695.178	0.16	0.14	0.00	0.00	76	77			103	0.039	101	103	10.3	-0.75	473	198	421	239	254		317.0	350	74	74		74	0.050
150	330.374	696.581	0.16	0.14	0.00	0.00	76	77			101	0.040	100	101	9.6	-0.7	460	198	395	243	261		311.4	337	74	74		74	0.050
160	331.942	697.985	0.16	0.14	0.00	0.00	76	77			99	0.039	101	102	9.0	-0.6	434	196	374	246	265		303.0	319	74	72		74	0.048
170	333.512	699.389	0.16	0.14	0.00	0.00	76	77			97	0.041	98	100	8.5	-0.5	413	194	357	244	270		295.6	304	74	72		74	0.045
180	335.075	700.790	0.16	0.14	0.00	0.00	76	77			96	0.039	100	102	8.0	-0.5	402	192	341	243	272		290.0	298	74	72		72	0.045
190	336.637	702.190	0.16	0.14	0.00	0.00	76	77			96	0.039	100	102	7.6	-0.4	393	189	328	241	274		285.0	291	72	72		72	0.043
200	338.204	703.598	0.16	0.14	0.00	0.00	76	77			95	0.038	101	104	7.2	-0.4	387	190	317	239	276		281.8	289	72	72		74	0.040
210	339.768	705.002	0.16	0.14	0.00	0.00	76	77			95	0.037	103	105	6.9	-0.35	380	190											

Wood Heater Test Data - EPA Method 5G

Run: 13
 Manufacturer: Monessen
 Model: Defiant 2N1
 Tracking No.: 1534
 Project No.: 227-S-39-3
 Test Date: 29-Apr-10
 Beginning Clock Time: 12:10
 Recording Interval: 10 min.
 Total Sampling Time: 800 min.

Velocity Traverse Data								
	Pt.1	Pt.2	Pt.3	Pt.4	Pt.5	Pt.6	Pt.7	Pt.8
Initial dP	0.032	0.041	0.044	0.043	0.029	0.040	0.043	0.041
Initial Temp.	94	94	94	94	94	94	94	94

°H₂O

OMNI Equipment Numbers: _____

PM Control Module:
 Dilution Tunnel MW(dry): 29.00 lb/lb-mole
 Dilution Tunnel MW(wet): 28.56 lb/lb-mole
 Dilution Tunnel H₂O: 4.00 percent
 Dilution Tunnel Static: -0.147 °H₂O
 Pitot Tube Cp: 0.99
 Meter Box Y Factor: 0.994 (1) 0.996 (2)
 Barometric Pressure: Begin 29.29 Middle 29.3 End 29.33 Average 29.31 °Hg
 Post-Test Leak Check (1): 0.0@5 cfm@°Hg
 Post-Test Leak Check (2): 0.0@9 cfm@°Hg
 Fuel Moisture (dry basis %): 19.85
 Total Particulate (1): 28.8
 Total Particulate (2): 27.6

JL 6/4/10

Elapsed Time	Particulate Sampling Data												Wood Heater Temperature Data, °F																
	Gas Meter Cubic Feet (1)	Gas Meter Cubic Feet (2)	Sample Rate, cfm (1)	Sample Rate, cfm (2)	Orifice dH (1)	Orifice dH (2)	Meter oF (1)	Meter oF (2)	Meter Vac. In. Hg. (1)	Meter Vac. In. Hg. (2)	Dilution Tunnel Temp.	Dilution Tunnel dP	Pro. Rate (10%) (1)	Pro. Rate (10%) (2)	Scale Reading	Weight Change	Firebox Top	Firebox Bottom	Firebox Back	Firebox Left	Firebox Right	Catalyst Exit	Average Surface	Stack	Filter (1)	Filter (2)	Impinger exit (1)	Impinger exit (2)	Ambient
430	374.022	735.297	0.16	0.14	0.00	0.00	78	78			83	0.039	98	99	3.5	-0.05	313	173	184	214	214		219.6	166	68	70		75	0.023
440	375.575	736.673	0.16	0.14	0.00	0.00	78	78			83	0.038	99	100	3.4	-0.1	309	170	181	214	211		217.0	164	70	70		77	0.225
450	377.129	738.043	0.16	0.14	0.00	0.00	78	78			82	0.038	99	99	3.4	-0.05	302	168	179	211	209		213.8	162	68	70		74	0.023
460	378.686	739.415	0.16	0.14	0.00	0.00	77	78			82	0.038	99	99	3.3	-0.1	297	168	176	211	204		211.2	159	70	70		74	0.020
470	380.243	740.780	0.16	0.14	0.00	0.00	77	78			82	0.037	101	100	3.2	-0.1	293	168	172	209	202		208.8	155	70	68		74	0.020
480	381.803	742.157	0.16	0.14	0.00	0.00	77	78			81	0.038	100	100	3.1	-0.1	290	163	169	208	197		205.4	152	67	67		75	0.020
500	384.920	744.881	0.16	0.13	0.00	0.00	77	77			81	0.038	96	102	3.0	-0.05	290	163	167	206	197		204.6	150	67	67		75	0.020
510	386.479	746.255	0.16	0.14	0.00	0.00	77	77			80	0.038	102	96	2.9	-0.1	296	160	165	203	195		203.8	150	66	66		73	0.020
520	388.020	747.637	0.15	0.14	0.00	0.00	77	77			80	0.037	101	101	2.8	-0.1	297	158	165	199	197		203.2	148	67	67		73	0.020
530	389.595	748.982	0.16	0.13	0.00	0.00	76	77			80	0.036	101	103	2.7	-0.1	292	158	162	197	199		201.6	147	66	68		73	0.020
540	391.151	750.349	0.16	0.14	0.00	0.00	76	77			80	0.037	102	99	2.6	-0.1	289	158	160	192	201		200.0	147	68	68		72	0.018
550	392.709	751.714	0.16	0.14	0.00	0.00	76	77			80	0.037	101	100	2.6	-0.05	287	156	158	188	205		198.8	145	68	68		72	0.018
560	394.269	753.073	0.16	0.14	0.00	0.00	76	77			80	0.037	101	100	2.4	-0.15	276	155	157	185	207		196.0	142	68	68		74	0.015
570	395.824	754.429	0.16	0.14	0.00	0.00	76	77			79	0.036	102	101	2.4	0	270	153	155	181	211		194.0	140	68	68		74	0.015
580	397.382	755.782	0.16	0.14	0.00	0.00	76	77			79	0.037	101	100	2.3	-0.1	266	151	153	177	207		190.8	138	68	68		75	0.018
590	398.939	757.135	0.16	0.14	0.00	0.00	76	77			79	0.036	102	101	2.3	-0.05	263	151	151	173	201		187.8	136	68	68		74	0.015
600	400.499	758.497	0.16	0.14	0.00	0.00	76	77			78	0.036	102	101	2.2	-0.1	259	147	151	168	194		183.8	134	68	68		72	0.015
610	402.063	759.844	0.16	0.13	0.00	0.00	76	77			78	0.037	101	99	2.0	-0.1	259	138	147	164	185		180.0	134	68	68		72	0.015
620	403.626	761.197	0.16	0.14	0.00	0.00	75	76			78	0.037	101	99	2.0	-0.05	263	138	147	164	185		178.6	134	68	68		72	0.015
630	405.185	762.555	0.16	0.14	0.00	0.00	75	75			78	0.038	100	99	1.9	-0.1	260	135	146	161	178		176.0	135	67	67		72	0.015
640	406.748	763.920	0.16	0.14	0.00	0.00	75	75			78	0.036	103	102	1.8	-0.1	258	135	144	161	176		174.8	135	67	67		71	0.015
650	408.309	765.261	0.16	0.13	0.00	0.00	75	75			78	0.036	102	100	1.7	-0.1	258	135	144	161	174		174.4	135	67	67		71	0.015
660	409.871	766.613	0.16	0.14	0.00	0.00	74	75			78	0.037	101	100	1.6	-0.1	260	139	1										

PRINT

**Final Laboratory Report - Method 5G Dual Train
Dilution Tunnel Particulate Calculations**

Client Name:	Monessen	Equipment Numbers:	OMNI-00023	Run #:	13
Model:	Defiant 2N1		OMNI-00131	Train #:	A
Project No.:	227-S-39-3		OMNI-00342	Date:	04/24/10
Tracking No.:	1534		VC-1		

Sample Component	Reagent	Filter # or Probe #	Weights		
			Final, mg	Tare, mg	Particulate, mg
A. Front filter catch	Filter	F578	151.5	125.2	26.3
B. Rear filter catch	Filter	F517	118.3	117.1	1.2
C. Probe catch	Probe	VC-Q	76940.4	76939.1	1.3

Total Particulate, mg :	28.8
-------------------------	------

Component	Equations:
A. Front filter catch	Final (mg) - Tare (mg) = Particulate, mg
B. Rear filter catch	Final (mg) - Tare (mg) = Particulate, mg
C. Probe catch	Final (mg) - Tare (mg) = Particulate, mg

Analyst: Date: 4/21/10

PRINT

**Final Laboratory Report - Method 5G Dual Train
Dilution Tunnel Particulate Calculations**

Client Name: Monessen
 Model: Defiant 2NI
 Project No.: 227-S-39-3
 Tracking No.: 1534

Equipment Numbers: OMNI-00023
OMNI-00131
OMNI-00342
VC-I

Run #: 13
 Train #: B
 Date: 04/24/10

Sample Component	Reagent	Filter # or Probe #	Weights		
			Final, mg	Tare, mg	Particulate, mg
A. Front filter catch	Filter	F518	150.5	125.5	25.0
B. Rear filter catch	Filter	F519	122.1	120.8	1.3
C. Probe catch	Probe	VC-I	76841.5	76840.2	1.3


Total Particulate, mg :	27.6
-------------------------	------

Component	Equations:
A. Front filter catch	Final (mg) - Tare (mg) = Particulate, mg
B. Rear filter catch	Final (mg) - Tare (mg) = Particulate, mg
C. Probe catch	Final (mg) - Tare (mg) = Particulate, mg

Analyst:



Date:



FUEL DATA

Client: MoresonModel: Defiant 2N1Project #: 227-5-29-7 Tracking #: 1534Date: 4/29/10 Test Crew: SC Run #: 13

OMNI Equipment ID #:

FUEL LOAD PREPARED BY: Ralph, monitors dimensions by SCFUEL: DOUGLAS-FIR SPECIES, UNTREATED, AIR-DRIED, STANDARD GRADE OR BETTER,
DIMENSIONAL LUMBER.

PRE-BURN FUEL

MOISTURE CONTENT (METER -- DRY BASIS)

CALIBRATION: Cal Value (1) = 12% Actual Reading 12.0
 Cal Value (2) = 22% Actual Reading 22.0

Piece	Length	Readings	Type
1	13.7 ft	24.6	2x4
2	13.7 ft	23.3	2x4
3	ft		

Length of cut pieces: 41 x 8 inches

Pre-Burn Fuel Average Moisture:

Time (clock): 8:15 Room Temperature (F): 70 °F Initials: SC

TEST FUEL

FUEL TYPE AND AMOUNT: 2 x 4 6 4 x 4 4
 CALCULATED LOAD WEIGHT: _____ ACTUAL LOAD WEIGHT: 6 (2 x 4)
 FUEL PIECE LENGTH: 21 in. 22.55 (4 x 4)
22.55 Total

MOISTURE CONTENT (METER -- DRY BASIS)

PIECE	READINGS	TYPE
1	20.7	20.6
2	20.6	18.9
3	19.9	18.9
4	19.1	20.5
5		
6		
7		
8		
9		
10		

OVERALL TEST FUEL LOAD MOISTURE AVERAGE: 19.85 %Time (clock): 8:15 Room Temperature (F): 70 °F Initials: SCTechnician signature: Date: 5/6/10

Run Notes


Client: MonessenModel: Defiant 2N1Project #: 227-5-39-3Tracking #: 1534Run #: 13Date: 4/27/08Test Crew: JC

OMNI Equipment ID #(s): _____

PREBURN

DESCRIBE OR SKETCH AIR OR THERMOMSTAT SETTINGS BELOW:
 (SETTINGS MUST BE ACCURATE AND REPRODUCABLE)

PRIMARY:

SECONDARY: N/A


TERTIARY: _____

FAN: OFFPREBURN SETTINGS AND ACTIVITIES

TIME	AIR (THERMO) CHANGES PRIMARY/SECONDARY/TERTIARY	FAN SETTING CHANGE	ADD FUEL + WT.	ADD FUEL - WT.	RAKE COAL	COMMENT
0	Test setting					
31					X	
62					X	
150					X	
165	Test start, Fuel on				X	


TEST

TEST FUEL CONFIGURATION SKETCH
 (INDICATE VIEW ANGLE)

START UP PROCEDURESBYPASS: 1 min, 3 secFUEL LOADING 1 min, 0 secDOOR: 1 min, 2 secPRIMARY AIR: Test setting @ owing, no changeOTHER: N/A

DESCRIBE OR SKETCH TEST SETTINGS BELOW:
 (SETTINGS MUST BE ACCURATE AND REPRODUCIBLE)

PRIMARY:

SECONDARY: N/A

TERTIARY: _____

FAN: OFFTechnician signature: Date: 4/27/08

4-1240F 4-155

Page 1 of 1

Supplemental Data EPA 5G/5H

Client: MonessenModel: Defiant 2N1Project #: 227-5-34-3 Tracking #: 1534Date: 4/26/10 Run #: 13 Booth: _____Test Crew: JL Start Time: 12:10 PM Stop Time: 1:30 AM

OMNI Equipment #(s): _____

Gas Analyzer Train Leak Check:

Stack:

Dilution Tunnel (Method 5G Only):

Initial: _____

Initial: _____

Final: _____

Final: _____

Calibrations: Span Gas CO₂: _____ O₂: _____ CO: _____ CO₂(DT): _____

Time	N ₂ Span						
O ₂							
CO ₂							
CO							
CO ₂ (DT)							

Stack Diameter (inches): 6Air Velocity (ft/min): Initial: <50 Final: <50Scale Audit (lbs): Pretest: 10.0 Post Test: 10.0Induced Draft: 0 %Smoke Capture: 100 %Pitot Tube Leak Test: Pre: 0.0 @ 3.0 Post: 0.0 @ 3.1Flue Pipe Cleaned Prior to First Test in Series: Date: 4/26/10 Initials: JL

	Initial	Middle	Ending
Pb (in/Hg)	29.29	29.30	29.33
Room Temp (°F)	75	79	75

Technician signature: JL Date: 4/26/10

4-1250F 4-155

*Model: Defiant
Monessen Hearth Systems
P.O. Box 501
Bethel, VT 05032*

Run 14

Wood Heater Test Data - EPA Method 5G

Manufacturer: Monessen
 Model: Defiant 2N1
 Project No.: 227-S-39-3
 Tracking No.: 1534
 Run: 14
 Test Date: 04/30/10

Burn Rate	1.51 kg/hr dry
Average Tunnel Temperature	109 degrees Fahrenheit
Average Gas Velocity in Dilution Tunnel - vs	13.5 feet/second
Average Gas Flow Rate in Dilution Tunnel - Qsd	8360.6 dscf/hour
Average Delta p	0.038 inches H2O
Average Delta H	0.00 inches H2O
Total Time of Test	340 minutes

	AVERAGE	SAMPLE TRAIN 1	SAMPLE TRAIN 2
Total Sample Volume - Vm	50.85 cubic feet	53.86 cubic feet	47.84 cubic feet
Average Gas Meter Temperature	79 degrees Fahrenheit	79 degrees Fahrenheit	80 degrees Fahrenheit
Total Sample Volume (Standard Conditions) - Vmsld	46.8 dscf	51.5 dscf	45.7 dscf
Total Particulates - mn		2.1 mg	1.9 mg
Particulate Concentration (dry-standard)	0.00004 grams/dscf	0.00004 grams/dscf	0.00004 grams/dscf
Particulate Emission Rate	0.34 grams/hour	0.34 grams/hour	0.35 grams/hour
Adjusted Emissions	0.76 grams/hour	0.76 grams/hour	0.76 grams/hour
Difference from Average		0.01 grams/hour	0.01 grams/hour
7.5% of the average emission rate	0.06		
Weighted Average Emission Rate Limit	4.10 grams/hour		
7.5% of the weighted average emission rate limit	0.31		

Results Are Acceptable

Wood Heater Test Data - EPA Method 5G

Run:	14
Manufacturer:	Monessen
Model:	Defiant 2N1
Tracking No.:	1534
Project No.:	227-S-39-3
Test Date:	30-Apr-10
Beginning Clock Time:	16:20
Recording Interval:	10 min.
Total Sampling Time:	340 min.

Velocity Traverse Data							
	Pt.1	Pt.2	Pt.3	Pt.4	Pt.5	Pt.6	Pt.8
Initial dP	0.031	0.042	0.047	0.042	0.032	0.044	0.045
Initial Temp.	110	110	110	110	110	110	110

°H₂O

OMNI Equipment Numbers: _____

PM Control Module:		Signature/Date:	JR 6/4/10
Dilution Tunnel MW(dry):	29.00	Tunnel Velocity:	13.53 ft/sec.
Dilution Tunnel MW(wet):	28.56	Initial Tunnel Flow:	144.1 scfm
Dilution Tunnel H ₂ O:	4.00	Average Tunnel Flow:	139.3 scfm
Dilution Tunnel Static:	-0.57 °H ₂ O	Tunnel Area:	0.1963 ft ²
Pitot Tube Cp:	0.99	Post-Test Leak Check (1):	0.0@25 cfm@°Hg
Meter Box Y Factor:	0.994 (1)	Post-Test Leak Check (2):	0.0@29 cfm@°Hg
Barometric Pressure:	Begin 29.35	Fuel Moisture (dry basis %):	19.87
	Middle 29.34	Average 29.37	Total Particulate (1): 2.1
	End 29.35		Total Particulate (2): 1.9

Elapsed Time	Particulate Sampling Data												Wood Heater Temperature Data, °F												Stack					
	Gas Meter Cubic Feet (1)	Gas Meter Cubic Feet (2)	Sample Rate, cfm (1)	Sample Rate, cfm (2)	Orifice dH (1)	Orifice dH (2)	Meter of (1)	Meter of (2)	Meter Vac. In. Hg. (1)	Meter Vac. In. Hg. (2)	Dilution Tunnel Temp.	Dilution Tunnel dP	Pro. Rate (10%) (1)	Pro. Rate (10%) (2)	Scale Reading	Weight Change	Firebox Top	Firebox Bottom	Firebox Back	Firebox Left	Firebox Right	Catalyst Exit	Average Surface	Stack	Filter (1)	Filter (2)	Impinger exit (1)	Impinger exit (2)	Ambient	Draft in. H ₂ O
0	431.685	785.450	0.16	0.14	0.00	0.00	79	79			110	0.041	22.7		456	222	345	326	306		331.0	304	70	72			76	0.040		
10	433.183	786.903	0.15	0.15	0.00	0.00	78	79			107	0.038	95	104	21.7	-0.95	360	215	339	295	282		298.2	384	76	76			76	0.050
20	434.810	788.336	0.16	0.14	0.00	0.00	78	79			117	0.038	104	103	20.6	-1.15	365	211	382	267	258		296.6	473	78	78			78	0.060
30	436.409	789.753	0.16	0.14	0.00	0.00	78	79			121	0.038	102	102	19.3	-1.3	428	202	441	250	245		313.2	495	80	80			78	0.060
40	437.998	791.160	0.16	0.14	0.00	0.00	78	80			125	0.039	101	100	17.8	-1.5	487	197	479	242	238		328.6	509	79	79			75	0.063
50	439.586	792.567	0.16	0.14	0.00	0.00	79	80			129	0.039	101	101	16.2	-1.55	531	193	507	242	242		343.0	537	82	82			77	0.065
60	441.167	793.972	0.16	0.14	0.00	0.00	79	80			129	0.040	99	99	14.6	-1.6	535	191	524	247	260		351.4	537	82	82			75	0.065
70	442.746	795.374	0.16	0.14	0.00	0.00	79	80			132	0.040	99	99	13.0	-1.65	546	193	540	254	284		363.4	561	82	82			76	0.070
80	444.324	796.785	0.16	0.14	0.00	0.00	79	80			131	0.040	99	100	11.4	-1.55	567	191	554	260	316		377.6	552	84	84			75	0.070
90	445.906	798.229	0.16	0.14	0.00	0.00	79	81			127	0.040	99	102	10.1	-1.35	593	189	559	266	336		388.6	531	84	82			75	0.070
100	447.487	799.578	0.16	0.13	0.00	0.00	79	81			126	0.040	99	95	8.8	-1.25	606	188	552	273	347		393.2	516	84	84			75	0.070
110	449.068	800.979	0.16	0.14	0.00	0.00	79	81			123	0.038	101	101	7.7	-1.15	614	188	541	281	355		395.8	500	82	82			75	0.065
120	450.645	802.381	0.16	0.14	0.00	0.00	79	81			120	0.037	102	102	6.7	-0.95	608	189	527	288	362		394.8	477	82	82			75	0.065
130	452.226	803.783	0.16	0.14	0.00	0.00	79	81			118	0.039	100	99	5.9	-0.85	586	188	507	292	366		387.8	459	82	82			75	0.063
140	453.815	805.190	0.16	0.14	0.00	0.00	79	81			114	0.038	101	101	5.2	-0.65	578	189	486	299	369		384.2	434	80	82			76	0.060
150	455.400	806.598	0.16	0.14	0.00	0.00	79	81			111	0.038	101	100	4.8	-0.45	567	189	462	299	366		376.6	408	80	80			75	0.060
160	456.984	808.003	0.16	0.14	0.00	0.00	79	81			108	0.038	100	100	4.3	-0.5	561	188	438	301	362		370.0	390	79	82			75	0.055
170	458.564	809.409	0.16	0.14	0.00	0.00	79	80			106	0.038	100	100	3.9	-0.4	539	188	416	305	355		360.6	377	79	81			75	0.053
180	460.155	810.815	0.16	0.14	0.00	0.00	79	80			104	0.038	100	100	3.5	-0.35	524	188	396	309	348		353.0	359	77	79			75	0.050
190	461.739	812.220	0.16	0.14	0.00	0.00	78	80			103	0.038																		

**Final Laboratory Report - Method 5G Dual Train
Dilution Tunnel Particulate Calculations**

Client Name: Monescou
 Model: Defiant 2N1
 Project No.: 227-S-39-3
 Tracking No.: 1534

Equipment Numbers:
OMNI-00023
OMNI-00131
OMNI-00342
VC-1

Run #: 14
 Train #: A
 Date: 04/30/10

Sample Component	Reagent	Filter # or Probe #	Weights		
			Final, mg	Tare, mg	Particulate, mg
A. Front filter catch	Filter	F520	118.3	116.4	1.9
B. Rear filter catch	Filter	F521	125.2	125.0	0.2
C. Probe catch	Probe	VC-H	69300.3	69300.3	0.0

Total Particulate, mg :	2.1
-------------------------	-----

Component	Equations:
A. Front filter catch	Final (mg) - Tare (mg) = Particulate, mg
B. Rear filter catch	Final (mg) - Tare (mg) = Particulate, mg
C. Probe catch	Final (mg) - Tare (mg) = Particulate, mg

Analyst:

Date: 6/2/10

PRINT

**Final Laboratory Report - Method 5G Dual Train
Dilution Tunnel Particulate Calculations**

Client Name: Monesen
 Model: Defiant 2NI
 Project No.: 227-S-39-3
 Tracking No.: 1534

Equipment Numbers: OMNI-00023
OMNI-00131
OMNI-00342
VC-1

Run #: 14
 Train #: B
 Date: 04/30/10

Sample Component	Reagent	Filter # or Probe #	Weights		
			Final, mg	Tare, mg	Particulate, mg
A. Front filter catch	Filter	F522	122.4	121.0	1.4
B. Rear filter catch	Filter	F523	117.7	117.5	0.2
C. Probe catch	Probe	VC-1	77918.0	77917.7	0.3

Total Particulate, mg :	1.9
-------------------------	-----

Component	Equations:
A. Front filter catch	Final (mg) - Tare (mg) = Particulate, mg
B. Rear filter catch	Final (mg) - Tare (mg) = Particulate, mg
C. Probe catch	Final (mg) - Tare (mg) = Particulate, mg

Analyst: Date: 6/2/10

STOVE TEMPERATURE TEST DATA - METHOD 5G

Page 1 of 2Client/Model: Moenster/Defur 2N1Project #: 227-S-39-3 Tracking #: 1534Date: 4/30/10 Test Crew: AC

OMNI Equipment ID #:

Run #: 14

Preburn [X] Test	Coal Bed:			Range: 5.7 - 4.5 TEMPERATURES (OF)			Actual: Coal Bed:				
	Fuel [g]	Weight	Delta Weight	Stack Draft	Ambient	Top	Bottom	Back	Left	Right	Flue
0	16.576		0.066	74	434	332	499	254	315	501	N/A
10	15.39	1.17	0.065	74	371	345	512	263	317	490	
20	14.24	1.15	0.064	74	357	361	517	270	315	480	
30	12.94	1.70	0.068	74	389	365	534	280	313	517	
40	11.40	1.15	0.065	74	467	357	543	291	317	520	
50	10.25	1.15	0.065	75	429	357	548	301	318	494	
60	9.26	0.99	0.064	75	453	357	550	305	320	489	
70	8.25	1.01	0.064	76	471	364	550	314	325	492	
80	6.94	1.30	0.065	74	544	349	566	332	339	508	
90	6.35	0.60	0.057	76	540	337	553	343	348	452	
100	6.00	0.35	0.053	74	540	328	510	345	352	387	
110	5.75	0.24	0.049	75	535	322	457	344	350	348	
120	5.56	0.20	0.045	77	519	316	411	337	346	318	
130	5.36	0.20	0.042	77	504	309	376	333	339	303	
140	4.86	-12.70	0.044	76	425	299	351	319	323	297	
150	3.50	17.50	0.043	75	370	286	329	297	299	299	
160	6.00	16.84	0.043	77	351	271	314	286	281	303	
170	7.00	15.94	0.90	0.055	75	345	260	303	279	271	371
180	8.00	14.55	1.39	0.057	76	347	247	349	280	264	455
190	9.00	13.14	1.41	0.064	77	375	236	410	281	260	500
	Avg										

Technician signature: J. A. H.Date: 5/6/10

STOVE TEMPERATURE TEST DATA - METHOD 5G

Page 2 of 2Client/Model: Hanesssen/Defrost 2NIDate: 4/30/10OMNI Equipment ID #: ATProject #: 227-5-39-3Tracking #: 1534Test Crew: ATRun #: 14

Preburn Test	Coal Bed: Data:			0 = Range:	TEMPERATURES (°F)						Actual: Coal Bed:	
	Fuel Weight	Delta Weight	Stack Draft		Ambient	Top	Bottom	Back	Left	Right	Flue	
200 0	11.51	1.63	0.060	77	425	234	485	288	271	556	556	N/A
210 10	9.90	1.61	0.072	78	486	232	535	303	271	565		
220 20	8.49	1.41	0.070	78	596	230	559	321	291	553		
230 30	7.14	1.34	0.072	78	626	235	559	339	317	521		
240 40	6.70	0.44	0.057	76	564	237	523	348	328	426		
250 50	6.31	0.40	0.052	77	534	235	476	348	328	383		
260 60	6.11	0.20	0.048	77	504	231	430	344	320	350		
270 70	5.95	0.15	0.045	77	485	224	389	337	313	326		
280 80	5.75	0.20	0.043	76	471	222	361	328	309	311		
290 90												
	00											
	10											
	20											
	30											
	40											
	50											
	60											
	70											
	80											
	90											
	Avg											

Technician signature: ZelDate: 5/6/10

Monessen Defiant 2N1
Run 14 - Category 3 Fan Confirmation, Non-Cat
Pre-Burn Data

Rec No	Test Time	Scal (kg)	Scal (lb)	Weight (kg)	Weight (lb)	Scal Temp	Scal Temp	Total	Total	Backgnd	Background	Diff	Diff	Rate	Rate	Temp
74	0	7.51	16.56	0.066	74	434	332	499	254	315	315	501	501			
84	10	6.98	15.39	1.17	0.065	74	371	345	512	263	317	317	490	490		
94	20	6.46	14.24	1.15	0.064	74	359	361	517	270	315	315	480	480		
104	30	5.69	12.54	1.70	0.068	74	389	365	534	280	313	313	517	517		
114	40	5.17	11.40	1.15	0.065	74	407	357	543	291	317	317	500	500		
124	50	4.65	10.25	1.15	0.065	75	429	357	548	301	318	318	494	494		
134	60	4.2	9.26	0.99	0.064	75	453	357	550	305	320	320	489	489		
144	70	3.74	8.25	1.01	0.064	76	471	364	550	314	325	325	492	492		
154	80	3.15	6.94	1.30	0.065	74	544	349	566	332	339	339	508	508		
164	90	2.88	6.35	0.60	0.059	76	540	337	553	343	348	348	452	452		
174	100	2.72	6.00	0.35	0.053	74	540	328	510	345	352	352	387	387		
184	110	2.61	5.75	0.24	0.049	75	535	322	457	344	350	350	348	348		
194	120	2.52	5.56	0.20	0.045	77	519	316	411	337	346	346	318	318		
204	130	2.43	5.36	0.20	0.042	77	504	309	376	333	339	339	303	303		
214	140	8.19	18.06	-12.70	0.044	76	425	299	351	319	323	323	297	297		
224	150	7.94	17.50	0.55	0.043	75	370	286	329	297	299	299				
234	160	7.64	16.84	0.66	0.043	77	351	271	314	286	281	281	303	303		
244	170	7.23	15.94	0.90	0.055	75	345	260	303	279	271	271				
254	180	6.6	14.55	1.39	0.059	76	347	247	349	280	264	264	455	455		
264	190	5.96	13.14	1.41	0.064	77	375	236	410	281	260	260	500	500		
274	200	5.22	11.51	1.63	0.06	77	425	234	485	288	271	271				
284	210	4.49	9.90	1.61	0.072	78	486	232	535	303	279	279	565	565		
294	220	3.85	8.49	1.41	0.07	78	596	230	559	321	291	291				
304	230	3.24	7.14	1.34	0.072	78	626	235	559	339	317	317				
314	240	3.04	6.70	0.44	0.057	76	564	237	523	348	328	328				
324	250	2.86	6.31	0.40	0.052	77	534	235	476	348	328	328				
334	260	2.77	6.11	0.20	0.048	77	504	231	430	344	320	320				
344	270	2.7	5.95	0.15	0.045	77	485	224	389	337	313	313				
354	280	2.61	5.75	0.20	0.043	76	471	222	361	328	309	309	311	311		

Note: Pre-burn restarted at 74 minutes of recorded time.

Long Old 6/10

FUEL DATA

Client: Monessen

Model: Defiant 2N1

Project #: 2073313 Tracking #: 1534

Date: 4/30/10

Test Crew:

JC

Run #: 14

OMNI Equipment ID #: MHS-109

FUEL LOAD PREPARED BY: Ralph; dimensions of moisture by JC

FUEL: DOUGLAS-FIR SPECIES, UNTREATED, AIR-DRIED, STANDARD GRADE OR BETTER, DIMENSIONAL LUMBER.

PRE-BURN FUEL

MOISTURE CONTENT (METER -- DRY BASIS)

CALIBRATION: Cal Value (1) = 12% Actual Reading 12.0 %
 Cal Value (2) = 22% Actual Reading 22.0 %

Piece	Length	Readings	Type
1	14.7 ft	18.5	2x4
2	14.7 ft	22.0	2x4
3	7.3 ft	23.0	2x4

Length of cut pieces: 44 x 8 inches + 11 x 8Pre-Burn Fuel Average Moisture: 21.8 % 22.1 %

(approx.)

Time (clock): 9:30 AM Room Temperature (F): 70 °F Initials: JC

TEST FUEL

FUEL TYPE AND AMOUNT: 2 x 4044

CALCULATED LOAD WEIGHT: _____

ACTUAL LOAD WEIGHT: 0

(2 x 4)

22.65

(4 x 4)


22.65

Total

FUEL PIECE LENGTH: 21 inches

MOISTURE CONTENT (METER -- DRY BASIS)

PIECE	READINGS	TYPE
1	20.2	4x4
2	20.3	4x4
3	19.1	4x4
4	19.9	4x4
5		
6		
7		
8		
9		
10		

OVERALL TEST FUEL LOAD MOISTURE AVERAGE: 19.87 %Time (clock): 9:30 AMRoom Temperature (F): 70 °FInitials: JCTechnician signature: Date: 4/30/10

Run Notes

Client: MoenesModel: Defiant 2N1Project #: 227-5-39-3Tracking #: 1584Run #: 14Date: 4/30/10Test Crew: ACOMNI Equipment ID #(s): PREBURN

DESCRIBE OR SKETCH AIR OR THERMOMSTAT SETTINGS BELOW:
 (SETTINGS MUST BE ACCURATE AND REPRODUCABLE)

PRIMARY:



SECONDARY:

N/A

TERTIARY:


FAN:

OFFPREBURN SETTINGS AND ACTIVITIES

TIME	AIR (THERMO) CHANGES PRIMARY/SECONDARY/TERTIARY	FAN SETTING CHANGE	ADD FUEL + WT.	ADD FUEL - WT.	RAKE COAL	COMMENT
0	Test Setting				X	
22					X	
71					X	
131					X	
167					X	
225					X	
284	Test Fuel on				X	

TEST


TEST FUEL CONFIGURATION SKETCH
 (INDICATE VIEW ANGLE)

START UP PROCEDURES

BYPASS: 50 sec
 FUEL LOADING 50 sec
 DOOR: 50 sec
 PRIMARY AIR: Test setting @ 0 min, no change
 OTHER: N/A

DESCRIBE OR SKETCH TEST SETTINGS BELOW:
 (SETTINGS MUST BE ACCURATE AND REPRODUCIBLE)

PRIMARY:

SECONDARY: N/A

TERTIARY:

FAN:

OFFTechnician signature: Date: 4/30/10

4-135 OF 4-155

OMNI-Test Laboratories, Inc.

Supplemental Data EPA 5G/5H

Client: Moessner

Model: Defiant 2N1

Project #: 227-5-39-3 Tracking #: 1534

Date: 4/30/10 Run #: 14 Booth: _____

Test Crew: SC Start Time: 4:20 PM Stop Time: 10:00 PM

OMNI Equipment #(s): _____

Gas Analyzer Train Leak Check:

Stack: _____

Dilution Tunnel (Method 5G Only): _____

Initial: _____

Initial: _____

Final: _____

Final: _____

Calibrations: Span Gas CO₂: _____ O₂: _____ CO: _____ CO₂(DT): _____

Time	N ₂ Span						
O ₂							
CO ₂							
CO							
CO ₂ (DT)							

Stack Diameter (inches): 6

Air Velocity (ft/min): Initial: 450 Final: 450

Scale Audit (lbs): Pretest: 10.00 Post Test: 10.00

Induced Draft: 0 %Smoke Capture: 100%

Pilot Tube Leak Test: Pre: 0.0 @ 3.0 Post: 0.0 @ 3.1

Flue Pipe Cleaned Prior to First Test in Series: Date: 4/18/10 Initials: SC

	Initial	Middle	Ending
Pb (in/Hg)	29.35	29.34	29.37
Room Temp (°F)	75 76 cr	81	80 76 cr

Technician signature:

Date: 4/30/10

4-136 OF 4-155

Model: Defiant
Monessen Hearth Systems
P.O. Box 501
Bethel, VT 05032

Run 15

Wood Heater Test Data - EPA Method 5G

Manufacturer: Monessen
 Model: Defiant 2N1
 Project No.: 237-S-39-3
 Tracking No.: 1534
 Run: 15
 Test Date: 05/04/10

Burn Rate	0.87 kg/hr dry
Average Tunnel Temperature	91 degrees Fahrenheit
Average Gas Velocity In Dilution Tunnel - vs	13.8 feet/second
Average Gas Flow Rate In Dilution Tunnel - Qsd	8907.0 dscf/hour
Average Delta p	0.041 inches H2O
Average Delta H	0.00 inches H2O
Total Time of Test	580 minutes

	AVERAGE	SAMPLE TRAIN 1	SAMPLE TRAIN 2
Total Sample Volume - Vm	80.29 cubic feet	85.66 cubic feet	74.92 cubic feet
Average Gas Meter Temperature	78 degrees Fahrenheit	78 degrees Fahrenheit	78 degrees Fahrenheit
Total Sample Volume (Standard Conditions) - Vmsstd	78.3 dscf	83.5 dscf	73.1 dscf
Total Particulates - mn		11.6 mg	11.5 mg
Particulate Concentration (dry-standard)	0.00015 grams/dscf	0.00014 grams/dscf	0.00016 grams/dscf
Particulate Emission Rate	1.32 grams/hour	1.24 grams/hour	1.40 grams/hour
Adjusted Emissions	2.29 grams/hour	2.17 grams/hour	2.41 grams/hour
Difference from Average		0.12 grams/hour	0.12 grams/hour
7.5% of the average emission rate	0.17		
Weighted Average Emission Rate Limit	4.10 grams/hour		
7.5% of the weighted average emission rate limit	0.31		
Results Are Acceptable			

Wood Heater Test Data - EPA Method 5G

Run:	15
Manufacturer:	Monessen
Model:	Defiant 2N1
Tracking No.:	1534
Project No.:	237-S-39-3
Test Date:	04-May-10
Beginning Clock Time:	03:15
Recording Interval:	10 min.
Total Sampling Time:	580 min.

Velocity Traverse Data								
Initial dP	Pt.1	Pt.2	Pt.3	Pt.4	Pt.5	Pt.6	Pt.7	Pt.8
Initial Temp.	101	101	101	101	101	101	101	101
"H ₂ O								

OMNI Equipment Numbers: _____

PM Control Module:			
Dilution Tunnel MW(dry):	29.00	lb/lb-mole	
Dilution Tunnel MW(wet):	28.56	lb/lb-mole	
Dilution Tunnel H ₂ O:	4.00	percent	
Dilution Tunnel Static:	-0.140	"H ₂ O	
Pitot Tube Cp:	0.99		
Meter Box Y Factor:	0.994 (1)	0.996 (2)	Fuel Moisture (dry basis %): 22.05
Barometric Pressure:	Begin	Middle	Average
	29.72	29.76	29.8
	"Hg	"Hg	Total Particulate (1): 11.6
			Total Particulate (2): 11.5

Elapsed Time	Particulate Sampling Data												Wood Heater Temperature Data, °F												Stack					
	Gas Meter Cubic Feet (1)	Gas Meter Cubic Feet (2)	Sample Rate, cfm (1)	Sample Rate, cfm (2)	Orifice dH (1)	Orifice dH (2)	Meter oF (1)	Meter oF (2)	Meter Vac. In. Hg. (1)	Meter Vac. In. Hg. (2)	Dilution Tunnel dP	Dilution Tunnel Temp.	Pro. Rate (10%) (1)	Pro. Rate (10%) (2)	Scale Reading	Weight Change	Firebox Top	Firebox Bottom	Firebox Back	Firebox Left	Firebox Right	Catalyst Exit	Average Surface	Stack	Filter (1)	Filter (2)	Impinger exit (1)	Impinger exit (2)	Ambient	Draft In. H ₂ O
0	486.291	833.975	0.00	0.00	76	74	-0.6	-2.6	101	0.038			22.5		417	237	334	282	295		313.0	304	72	72			76	0.040		
10	487.850	835.330	0.16	0.14	0.00	0.00	76	74	-0.6	-2.6	95	0.040	108	108	21.7	-0.85	330	230	317	263	272		282.4	282	74	74			76	0.039
20	489.360	836.620	0.15	0.13	0.00	0.00	77	77	-0.6	-2.6	98	0.040	105	102	21.4	-0.25	285	222	322	237	248		262.8	346	75	75			77	0.045
30	490.850	837.910	0.15	0.13	0.00	0.00	77	77	-0.6	-2.6	100	0.042	101	100	20.6	-0.8	264	214	350	220	233		256.2	379	77	75			77	0.050
40	492.331	839.195	0.15	0.13	0.00	0.00	77	77	-0.6	-2.6	103	0.042	101	100	19.9	-0.7	262	206	388	208	221		257.0	407	75	75			77	0.050
50	493.817	840.460	0.15	0.13	0.00	0.00	77	77	-0.6	-2.6	105	0.042	101	98	19.0	-0.9	269	199	418	197	215		259.6	421	78	78			78	0.053
60	495.297	841.740	0.15	0.13	0.00	0.00	78	78	-0.6	-2.6	105	0.042	100	99	18.1	-0.9	299	193	436	193	210		266.2	410	77	77			75	0.055
70	496.769	843.020	0.15	0.13	0.00	0.00	77	79	-0.6	-2.6	107	0.042	100	99	17.1	-1	319	189	444	193	210		271.0	425	78	78			78	0.055
80	498.253	844.296	0.15	0.13	0.00	0.00	78	80	-0.6	-2.6	107	0.042	101	99	16.1	-1	349	184	449	195	215		278.4	423	78	78			75	0.055
90	499.720	845.580	0.15	0.13	0.00	0.00	78	80	-0.6	-2.6	107	0.044	97	97	15.2	-0.9	373	182	453	195	219		284.4	425	77	77			75	0.055
100	501.189	846.860	0.15	0.13	0.00	0.00	77	80	-0.6	-2.6	104	0.044	97	97	14.1	-1.1	392	180	455	199	225		290.2	429	77	77			73	0.055
110	502.661	848.142	0.15	0.13	0.00	0.00	77	77	-0.6	-2.6	104	0.042	100	100	13.3	-0.8	411	179	456	205	235		297.2	424	77	77			72	0.055
120	504.140	849.415	0.15	0.13	0.00	0.00	76	78	-0.6	-2.6	101	0.042	100	99	12.3	-1	412	176	454	206	243		298.2	423	76	76			72	0.055
130	505.618	850.720	0.15	0.13	0.00	0.00	76	78	-0.6	-2.6	101	0.044	98	99	11.4	-0.9	425	176	456	210	252		303.8	423	76	76			71	0.055
140	507.095	852.002	0.15	0.13	0.00	0.00	75	77	-0.6	-2.6	101	0.042	100	99	10.6	-0.8	440	174	451	215	264		308.8	403	75	75			71	0.055
150	508.560	853.290	0.15	0.13	0.00	0.00	77	77	-0.6	-2.6	100	0.042	99	100	9.7	-0.9	446	175	433	220	277		310.2	390	75	75			71	0.054
160	510.037	854.580	0.15	0.13	0.00	0.00	75	77	-0.6	-2.6	98	0.042	100	100	9.1	-0.6	442	177	422	227	288		311.2	383	75	75			71	0.054
170	511.522	855.875	0.15	0.13	0.00	0.00	74	77	-0.6	-2.6	98	0.042	101	100	8.4	-0.7	435	179	413	231	294		310.4	372	75	75			72	0.051
180	513.015	857.180	0.15	0.13	0.00	0.00	74	76	-0.6	-2.6	98	0.042	101	101	7.8	-0.6	435	181	402	233	300		310.2	367	74	72			70	0.051
190	514.493	858.460	0.15	0.13	0.00																									

Wood Heater Test Data - EPA Method 5G

Run:	15
Manufacturer:	Monessen
Model:	Defiant 2N1
Tracking No.:	1534
Project No.:	237-S-39-3
Test Date:	04-May-10
Beginning Clock Time:	03:15
Recording Interval:	10 min.
Total Sampling Time:	580 min.

Velocity Traverse Data							
	Pt.1	Pt.2	Pt.3	Pt.4	Pt.5	Pt.6	Pt.8
Initial dP	0.026	0.042	0.044	0.040	0.028	0.041	0.046
Initial Temp.	101	101	101	101	101	101	101

OMNI Equipment Numbers:

PM Control Module:					
Dilution Tunnel MW(dry):	29.00 lb/lb-mole				
Dilution Tunnel MW(wet):	28.56 lb/lb-mole				
Dilution Tunnel H2O:	4.00 percent				
Dilution Tunnel Static:	-0.140 "H2O				
Pitot Tube Cp:	0.99				
Meter Box Y Factor:	0.994 (1) 0.996 (2)				
Barometric Pressure:	Begin Middle End				
	Average				
29.72	29.76	29.8	29.76 "Hg	Total Particulate (1):	11.6
				Total Particulate (2):	11.5

Signature/Date: *GR 6/4/10*

Tunnel Velocity:	13.79 ft/sec.
Initial Tunnel Flow:	141.9 scfm
Average Tunnel Flow:	148.5 scfm
Tunnel Area:	0.1963 ft ²
Post-Test Leak Check (1):	001 @ 4.5" cfm@ "Hg
Post-Test Leak Check (2):	000 @ 7.5" cfm@ "Hg
(2) Fuel Moisture (dry basis %):	22.05

Elapsed Time	Particulate Sampling Data																Wood Heater Temperature Data, of													
	Gas Meter Cubic Feet (1)	Gas Meter Cubic Feet (2)	Sample Rate, cfm (1)	Sample Rate, cfm (2)	Orifice dH (1)	Orifice dH (2)	Meter of (1)	Meter of (2)	Meter Vac In. Hg.	Meter Vac In. Hg.	Dilution Tunnel Temp.	Dilution Tunnel dP	Pro. Rate (10%) (1)	Pro. Rate (10%) (2)	Fuel Weight, lb	Scale Reading	Weight Change	Firebox Top	Firebox Bottom	Firebox Back	Firebox Left	Firebox Right	Catalyst Exit	Average Surface	Stack	Filter (1)	Filter (2)	Impinger exit (1)	Impinger exit (2)	Ambient
430	549.905	889.465	0.15	0.13	0.00	0.00	76	76	-0.6	-2.6	85	0.040	101	102	2.0	-0.2	339	181	220	220	220	220	236.0	220	72	72			74	0.029
440	551.382	890.765	0.15	0.13	0.00	0.00	76	76	-0.6	-2.6	85	0.042	99	100	1.9	-0.1	343	183	220	220	222	222	237.6	218	72	72			74	0.029
450	552.854	892.069	0.15	0.13	0.00	0.00	76	76	-0.6	-2.6	84	0.040	101	102	1.7	-0.2	343	185	220	222	224	224	238.8	218	72	72			74	0.028
460	554.330	893.375	0.15	0.13	0.00	0.00	76	76	-0.6	-2.6	85	0.040	101	102	1.6	-0.1	341	187	218	222	226	226	238.8	215	72	72			74	0.028
470	555.809	894.670	0.15	0.13	0.00	0.00	76	76	-0.6	-2.6	84	0.040	101	102	1.4	-0.2	348	187	218	220	228	228	240.2	215	72	72			74	0.028
480	557.285	895.975	0.15	0.13	0.00	0.00	76	76	-0.6	-2.6	84	0.040	101	102	1.3	-0.1	352	187	217	219	232	232	241.4	215	72	72			74	0.028
490	558.750	897.275	0.15	0.13	0.00	0.00	76	76	-0.6	-2.6	84	0.040	100	102	1.2	-0.1	354	187	217	217	232	232	241.4	211	72	72			74	0.028
500	560.228	898.575	0.15	0.13	0.00	0.00	76	76	-0.6	-2.6	84	0.040	100	102	1.2	-0.1	354	187	217	217	232	232	241.4	211	72	72			74	0.028
510	561.705	899.872	0.15	0.13	0.00	0.00	76	76	-0.6	-2.6	84	0.038	103	104	1.0	-0.2	353	189	215	217	234	234	241.6	210	71	71			73	0.027
520	563.185	901.175	0.15	0.13	0.00	0.00	75	75	-0.6	-2.6	84	0.040	101	102	0.9	-0.1	358	189	215	215	236	236	242.6	206	71	71			74	0.027
530	564.650	902.450	0.15	0.13	0.00	0.00	75	75	-0.6	-2.6	84	0.040	102	102	0.7	-0.2	358	187	211	217	237	237	242.0	202	72	72			74	0.027
540	566.135	903.799	0.15	0.13	0.00	0.00	75	75	-0.6	-2.6	82	0.040	100	100	0.6	-0.1	358	189	209	215	237	237	241.6	198	72	72			72	0.026
550	567.570	905.030	0.14	0.12	0.00	0.00	75	75	-0.6	-2.6	82	0.040	102	106	0.4	-0.2	353	187	204	215	234	234	238.6	193	71	71			73	0.026
560	569.033	906.325	0.15	0.13	0.00	0.00	75	75	-0.6	-2.6	82	0.038	102	104	0.2	-0.1	347	187	200	215	232	232	236.2	187	71	69			73	0.026
570	570.492	907.610	0.15	0.13	0.00	0.00	75	75	-0.6	-2.6	81	0.040	100	101	0.1	-0.1	340	186	195	212	229	229	232.4	182	71	71			73	0.025
580	571.955	908.895	0.15	0.13	0.00	0.00	75	75	-0.6	-2.6	79	0.040	100	100	0.0	-0.1	331	184	188	210	225	225	230.6	180	69	69			73	0.025
Avg/Total	85.664	74.920	0.15	0.13	0.00	0.00	75.68	76.20			91.34	0.041	100.73	100.72								85		73.15	72.85	#DIV/0!	#DIV/0!		0.038	

Final Laboratory Report - Method 5G Dual Train
Dilution Tunnel Particulate Calculations

Client Name: Monssen
 Model: Defiant
 Project No.: 227-S-37-3
 Tracking No.: 1534

Equipment Numbers:

Run #: 15
 Train #: A
 Date: 05/04/10

Sample Component	Reagent	Filter # or Probe #	Weights		
			Final, mg	Tare, mg	Particulate, mg
A. Front filter catch	Filter	F524	135.9	125.4	10.5
B. Rear filter catch	Filter	F525	121.2	120.4	0.8
C. Probe catch	Probe	F	78331.2	78330.9	0.3

Total Particulate, mg :	11.6
-------------------------	------

Component	Equations:
A. Front filter catch	Final (mg) - Tare (mg) = Particulate, mg
B. Rear filter catch	Final (mg) - Tare (mg) = Particulate, mg
C. Probe catch	Final (mg) - Tare (mg) = Particulate, mg

Analyst: HRDate: 6/3/10

Final Laboratory Report - Method 5G Dual Train
Dilution Tunnel Particulate Calculations

Client Name: Monessen
 Model: Defiant
 Project No.: 227-S-37-3
 Tracking No.: 1534

Equipment Numbers: _____

Run #: 15
 Train #: B
 Date: 05/04/10

Sample Component	Reagent	Filter # or Probe #	Weights		
			Final, mg	Tare, mg	Particulate, mg
A. Front filter catch	Filter	F526	127.7	117.2	10.5
B. Rear filter catch	Filter	F527	126.6	125.8	0.8
C. Probe catch	Probe	A	76438.7	76438.5	0.2

Total Particulate, mg :	11.5
-------------------------	------

Component	Equations:
A. Front filter catch	Final (mg) - Tare (mg) = Particulate, mg
B. Rear filter catch	Final (mg) - Tare (mg) = Particulate, mg
C. Probe catch	Final (mg) - Tare (mg) = Particulate, mg

Analyst: JRDate: 6/13/10

STOVE TEMPERATURE TEST DATA - METHOD 5G

Client/Model: Hunessan

Date: 5/4/10 Project #: 227-5-39-3 Tracking #: 1534

Test Crew: S. Bottom

OMNI Equipment ID #:

Page 1 of 1

Coal Bed: 0 = Range: 4.5-5.6 (F)

Coal Bed: 5.6 (F) Run #: 15

Preburn Test	Coal Bed:						Actual: Coal Bed: 5.6 (F)					
	Fuel	Delta Weight	Stack Draft	Ambient	Top	Bottom	Back	Left	Right	Flue	Catalyst	
0	16.6	-	.055	73	433	243	48	260	268	388	348	-
10	16.0	0.6	-.050	71	381	244	446	251	272	346	348	-
20	15.5	0.5	-.052	71	357	244	413	240	266	337	337	-
30	14.7	0.8	-.050	71	348	242	383	229	261	320	320	-
40	14.2	0.5	-.050	71	344	246	359	225	261	309	309	-
50	13.1	0.9	-.050	70	335	235	350	218	261	361	361	-
60	12.2	0.9	-.050	70	317	231	361	216	261	346	346	-
70	11.2	1.0	-.050	72	319	228	389	213	261	408	413	-
80	10.4	0.8	-.050	72	332	236	415	213	263	413	413	-
90	9.4	1.0	-.050	72	352	232	449	219	274	471	471	-
100	8.7	0.7	-.050	70	376	232	471	224	278	477	477	-
110	7.7	1.0	-.055	72	404	230	467	250	296	391	391	-
120	6.9	0.3	-.050	71	432	245	477	247	301	456	456	-
130	6.4	0.5	-.060	71	432	243	488	258	306	408	408	-
140	6.2	0.2	-.050	74	443	245	465	269	310	360	360	-
150	5.9	0.3	-.045	74	456	244	430	276	309	328	328	-
160	5.8	0.1	-.045	75	448	240	394	281	305	303	303	-
170	5.7	0.1	-.040	75	429	236	362	284	297	284	284	-
180	5.6	0.1	-.040	76	419	234	336	284	295	293	293	-
90												
Avg												

Technician signature: J. J.

Date: 5/4/10

FUEL DATA

Client: Munesson (Vermont cuttings)

Model: DeLant 2N1

Project #: 247547 Tracking #: 1534

Date: 5/4/10 Test Crew: S. Button Run #: 15

OMNI Equipment ID #:

FUEL LOAD PREPARED BY: S. Button

FUEL: DOUGLAS-FIR SPECIES, UNTREATED, AIR-DRIED, STANDARD GRADE OR BETTER, DIMENSIONAL LUMBER.

PRE-BURN FUEL

MOISTURE CONTENT (METER -- DRY BASIS)

CALIBRATION: Cal Value (1) = 12% Actual Reading 12%
 Cal Value (2) = 22% Actual Reading 22%

Piece	Length		Readings	Type
1	15 ft	20.5	24.6 23.2	2x4
2	15 ft	21.3	24.5 23.4	2x4
3	8 ft	24.7	22.0 20.5	4x4 SB

Length of cut pieces: 8' 2 1/4 inches Pre-Burn Fuel Average Moisture: 22.9%

Time (clock): 9:00 AM Room Temperature (F): 73.4 Initials: SB

TEST FUEL

FUEL TYPE AND AMOUNT: 2 x 4 _____ 4 x 4 _____

CALCULATED LOAD WEIGHT: _____ ACTUAL LOAD WEIGHT: (2 x 4) _____


FUEL PIECE LENGTH: 21" (4 x 4) _____ Total: 22.5

MOISTURE CONTENT (METER -- DRY BASIS)

PIECE	READINGS	TYPE
1	20.2 21.4 21.5	4x4
2	21.7 20.3 20.3	4x4
3	22.2 22.1 22.0	4x4
4	24.4 24.2 23.3	4x4
5		
6		
7		
8		
9		
10		

OVERALL TEST FUEL LOAD MOISTURE AVERAGE: 22.05%

Time (clock): 9:30 AM Room Temperature (F): 73.4 Initials: SB

Technician signature: 

Date: 5/4/10


Run Notes

Client: Mannesen
 Model: Defiant 2M
 Project #: 227-5-39-3
 Tracking #: 1534
 Run #: 15
 Test Crew: J. Button
 OMNI Equipment ID #(s): _____

Date: 5/4/10PREBURN

DESCRIBE OR SKETCH AIR OR THERMOMSTAT SETTINGS BELOW:
 (SETTINGS MUST BE ACCURATE AND REPRODUCABLE)

PRIMARY:



SECONDARY:

Fixed

TERTIARY:

N/A


FAN:

OFFPREBURN SETTINGS AND ACTIVITIES

TIME	AIR (THERMO) CHANGES PRIMARY/SECONDARY/TERTIARY	FAN SETTING CHANGE	ADD FUEL + WT.	ADD FUEL - WT.	RAKE COAL	COMMENT
42 min	Stirred Coals					
119 min	Stirred Coals					

TEST

TEST FUEL CONFIGURATION SKETCH
 (INDICATE VIEW ANGLE)



START UP PROCEDURES

BYPASS: Closed @ 1 minFUEL LOADING Closed @ 1 min

DOOR:


PRIMARY AIR: Set @ 0 Sec

OTHER:

N/A

DESCRIBE OR SKETCH TEST SETTINGS BELOW:
 (SETTINGS MUST BE ACCURATE AND REPRODUCIBLE)

PRIMARY:



SECONDARY:

Fixed

TERTIARY:

N/A

FAN:

OFF

*Repositioned test fuel @ 347 min.

Technician signature:

Date: 5/4/10

4-7450F 4-155

Supplemental Data EPA 5G/5H

Client: MonessonModel: Deltat 2MProject #: 227-5-39-3 Tracking #: 1534Date: 5/4/10 Run #: 15 Booth: On-siteTest Crew: S. Button Start Time: 3:15 PM Stop Time: 12:45 AM

OMNI Equipment #(s): _____

Gas Analyzer Train Leak Check:

Stack:

Dilution Tunnel (Method 5G Only):

Initial: _____

Initial: _____

Final: _____

Final: _____

Calibrations: Span Gas CO₂: _____ O₂: _____ CO: _____ CO₂(DT): _____

Time	N ₂ Span							
O ₂								
CO ₂								
CO								
CO ₂ (DT)								

Stack Diameter (inches): 6"Air Velocity (ft/min): Initial: < 50 ft/min Final: < 50 ft/minScale Audit (lbs): Pretest: 10 165 Post Test: 10 163Induced Draft: 0 % Smoke Capture: 100%Pilot Tube Leak Test: Pre: φ Post: φFlue Pipe Cleaned Prior to First Test in Series: Date: 4/18/10 Initials: SB

	Initial	Middle	Ending
Pb (in/Hg)	29.72	29.76	29.80"
Room Temp (°F)	76	74	73

Technician signature: JLDate: 5/5/10

Model: Defiant
Monessen Hearth Systems
P.O. Box 501
Bethel, VT 05032

Run 16

Wood Heater Test Data - EPA Method 5G

Manufacturer: Monessen
 Model: Defiant
 Project No.: 227-S-37-3
 Tracking No.: 1534
 Run: 16
 Test Date: 05/09/10

Burn Rate	1.28 kg/hr dry
Average Tunnel Temperature Average Gas Velocity In Dilution Tunnel - vs Average Gas Flow Rate in Dilution Tunnel - Qsd	97 degrees Fahrenheit 14.1 feet/second 9078.8 dscf/hour
Average Delta p Average Delta H Total Time of Test	0.043 inches H2O 0.00 inches H2O 400 minutes

	AVERAGE	SAMPLE TRAIN 1	SAMPLE TRAIN 2
Total Sample Volume - Vm	58.37 cubic feet	80.58 cubic feet	52.16 cubic feet
Average Gas Meter Temperature	75 degrees Fahrenheit	75 degrees Fahrenheit	76 degrees Fahrenheit
Total Sample Volume (Standard Conditions) - Vmstd	55.2 dscf	59.3 dscf	51.1 dscf
Total Particulates - mn		7.3 mg	6.6 mg
Particulate Concentration (dry-standard)	0.00013 grams/dscf	0.00012 grams/dscf	0.00013 grams/dscf
Particulate Emission Rate	1.16 grams/hour	1.12 grams/hour	1.21 grams/hour
Adjusted Emissions	2.06 grams/hour	2.00 grams/hour	2.13 grams/hour
Difference from Average		0.07 grams/hour	0.07 grams/hour
7.5% of the average emission rate	0.15		
Weighted Average Emission Rate Limit	4.10 grams/hour		
7.5% of the weighted average emission rate limit	0.31		
Results Are Acceptable			

Run: 16

Manufacturer: Monessen
 Model: Defiant
 Tracking No.: 1534
 Project No.: 227-S-37-3
 Test Date: 09-May-10
 Beginning Clock Time: 13:32
 Recording Interval: 10 min.
 Total Sampling Time: 400 min.

Wood Heater Test Data - EPA Method 5G

Velocity Traverse Data								
	Pt.1	Pt.2	Pt.3	Pt.4	Pt.5	Pt.6	Pt.7	Pt.8
Initial dP	0.026	0.042	0.044	0.042	0.026	0.040	0.044	0.038
Initial Temp.	91	91	91	91	91	91	91	91

"H₂O of

OMNI Equipment Numbers: _____

PM Control Module:
 Tunnel Velocity: 14.15 ft/sec.
 Dilution Tunnel MW(dry): 29.00 lb/lb-mole
 Initial Tunnel Flow: 142.2 scfm
 Dilution Tunnel MW(wet): 28.56 lb/lb-mole
 Average Tunnel Flow: 151.3 scfm
 Dilution Tunnel H₂O: 4.00 percent
 Tunnel Area: 0.1963 ft²
 Dilution Tunnel Static: -0.142 "H₂O
 Pitot Tube Cp: 0.99
 Post-Test Leak Check (1): .001 @ -4 cfm @"Hg
 Meter Box Y Factor: 0.994 (1) 0.996 (2)
 Barometric Pressure: Begin Middle End Average
 Total Particulate (1): 7.3
 Total Particulate (2): 6.8

Elapsed Time	Particulate Sampling Data												Wood Heater Temperature Data, of												Stack				
	Gas Meter Cubic Feet (1)	Gas Meter Cubic Feet (2)	Sample Rate, cfm (1)	Sample Rate, cfm (2)	Orifice dH(1)	Orifice dH(2)	Meter oF (1)	Meter oF (2)	Meter Vac In, Hg. (1)	Meter Vac In, Hg. (2)	Dilution Tunnel Temp.	Dilution Tunnel dP	Pro. Rate (10%) (1)	Pro. Rate (10%) (2)	Scale Reading	Weight Change	Firebox Top	Firebox Bottom	Firebox Back	Firebox Left	Firebox Right	Catalyst Exit	Average Surface	Stack	Filter (1)	Filter (2)	Impinger exit (1)	Impinger exit (2)	Ambient
0	889.662	198.048			0.00	0.00	72	72	-0.5	-2.7	91	0.038			22.6		411	316	218	268	300		302.6	261	68	68		72	0.039
10	891.215	199.400	0.16	0.14	0.00	0.00	70	72	-0.5	-2.7	89	0.042	105	105	22.1	-0.5	324	303	216	248	272		272.6	274	68	68		72	0.039
20	892.760	200.730	0.15	0.13	0.00	0.00	72	72	-0.5	-2.7	89	0.042	104	104	21.6	-0.5	281	287	224	226	242		252.0	313	70	68		72	0.040
30	894.300	202.060	0.15	0.13	0.00	0.00	72	72	-0.5	-2.7	96	0.042	104	104	20.8	-0.8	257	272	244	214	218		241.0	374	71	68		71	0.046
40	895.805	203.360	0.15	0.13	0.00	0.00	73	73	-0.5	-2.7	101	0.042	102	102	19.8	-1	255	257	285	214	207		243.6	422	70	70		72	0.050
50	897.315	204.665	0.15	0.13	0.00	0.00	72	75	-0.5	-2.7	106	0.042	103	103	18.7	-1.1	270	244	325	214	201		250.8	442	71	71		73	0.059
60	898.830	205.970	0.15	0.13	0.00	0.00	73	75	-0.5	-2.7	109	0.044	101	101	17.5	-1.2	314	236	342	225	204		264.2	451	73	73		73	0.060
70	900.330	207.260	0.15	0.13	0.00	0.00	73	73	-0.5	-2.7	111	0.042	102	102	16.2	-1.3	366	229	349	229	208		276.2	457	73	73		73	0.060
80	901.840	208.585	0.15	0.13	0.00	0.00	75	75	-0.5	-2.7	113	0.044	101	103	15.0	-1.2	401	225	353	238	214		286.2	464	73	73		73	0.060
90	903.345	209.890	0.15	0.13	0.00	0.00	75	75	-0.5	-2.7	114	0.044	100	101	13.6	-1.4	442	221	362	251	225		300.2	468	75	73		75	0.060
100	904.850	211.200	0.15	0.13	0.00	0.00	75	75	-0.5	-2.7	116	0.044	101	101	12.3	-1.3	492	219	369	267	239		317.2	486	76	74		74	0.061
110	906.355	212.505	0.15	0.13	0.00	0.00	74	76	-0.5	-2.7	118	0.044	100	101	10.9	-1.4	512	219	384	278	250		328.6	493	76	74		76	0.065
120	907.865	213.810	0.15	0.13	0.00	0.00	74	76	-0.5	-2.7	119	0.044	101	101	9.6	-1.3	532	218	387	291	261		337.8	474	76	76		74	0.065
130	909.370	215.115	0.15	0.13	0.00	0.00	74	76	-0.5	-2.7	115	0.044	101	101	8.5	-1.1	551	220	391	300	272		346.8	454	77	74		77	0.061
140	910.875	216.400	0.15	0.13	0.00	0.00	77	77	-0.5	-2.7	113	0.044	100	99	7.4	-1.1	547	223	368	309	281		345.6	433	77	75		75	0.060
150	912.380	217.725	0.15	0.13	0.00	0.00	75	77	-0.5	-2.7	109	0.044	100	102	6.6	-0.8	547	220	346	320	285		343.6	416	75	75		75	0.059
160	913.890	219.030	0.15	0.13	0.00	0.00	75	77	-0.5	-2.7	107	0.042	102	102	5.9	-0.7	535	221	334	325	288		340.6	407	75	75		75	0.059
170	915.400	220.340	0.15	0.13	0.00	0.00	75	77	-0.5	-2.7	105	0.042	102	103	5.3	-0.6	524	221	316	327	288		335.2	394	75	75		75	0.055
180	916.915	221.640	0.15	0.13	0.00	0.00	75	80	-0.5	-2.7	101	0.044	100	99	4.8	-0.5	522	221	297	329	288		331.4	344	75	73		73	0.055
190	918.450	222.940	0.15	0.13	0.00	0.00	78	78	-0.5	-2.7	99	0.044	100	99	4.4	-0.4	503	219	271	319	286		319.6	325	75	73		75	0.050
200	919.940	224.235	0.15	0.13	0.00	0.00	78	76	-0.5	-2.7	97	0.044	97	99	4.1	-0.3	485	217	251	314	284		310.2	308	73	73		75	0.048
210	921.450	225.535	0.15	0.13	0.00	0.00	78	75	-0.5	-2.7	95	0.042	101	101	3.8	-0.3	472	214	234	308	282		302.0	295	73	71	</td		

**Final Laboratory Report - Method 5G Dual Train
Dilution Tunnel Particulate Calculations**

Client Name: Monessen
 Model: Defiant
 Project No.: 227-S-37-3
 Tracking No.: 1534

Equipment Numbers:

Run #: 16
 Train #: A
 Date: 03/09/10

Sample Component	Reagent	Filter # or Probe #	Weights		
			Final, mg	Tare, mg	Particulate, mg
A. Front filter catch	Filter	F596	125.2	119.3	5.9
B. Rear filter catch	Filter	F597	119.6	119.2	0.4
C. Probe catch	Probe	21	114386.9	114385.9	1.0

Total Particulate, mg :	7.3
-------------------------	-----

Component	Equations:
A. Front filter catch	Final (mg) - Tare (mg) = Particulate, mg
B. Rear filter catch	Final (mg) - Tare (mg) = Particulate, mg
C. Probe catch	Final (mg) - Tare (mg) = Particulate, mg

Analyst: GRDate: 6/3/10

**Final Laboratory Report - Method 5G Dual Train
Dilution Tunnel Particulate Calculations**

Client Name: Monessen
 Model: Defiant
 Project No.: 227-S-37-3
 Tracking No.: 1534

Equipment Numbers:

Run #: 16
 Train #: B
 Date: 05/09/10

Sample Component	Reagent	Filter # or Probe #	Weights		
			Final, mg	Tare, mg	Particulate, mg
A. Front filter catch	Filter	F599	124.8	119.3	5.5
B. Rear filter catch	Filter	F600	120.2	119.8	0.4
C. Probe catch	Probe	3	116006.5	116005.6	0.9

Total Particulate, mg :	6.8
-------------------------	-----

Component	Equations:
A. Front filter catch	Final (mg) - Tare (mg) = Particulate, mg
B. Rear filter catch	Final (mg) - Tare (mg) = Particulate, mg
C. Probe catch	Final (mg) - Tare (mg) = Particulate, mg

Analyst: HRDate: 6/3/10

STOVE TEMPERATURE TEST DATA - METHOD 5G

Client Model: Morsen

Date: 5/9/16 Test Crew: S. Baffon

OMNI Equipment ID #:

Project #: 227-5-37-3 Tracking #: 1534
Run #: 16

Page — of —

Preburn Test	Coal Bed:				Actual: 46 ~ 56				Coal Bed: 5.4			
	Time	Fuel Weight	Delta Weight	Stack Draft	Ambient	Top	Bottom	Back	Left	Right	Flue	Catalyst
0	16.7	-	.05	.69	422	362	299	307	288	321	-	-
10	16.0	0.3	.05	.70	359	315	271	292	281	305	-	-
20	15.5	0.5	.045	.70	332	311	243	272	278	282	-	-
30	14.9	0.6	.042	.70	313	307	236	255	276	287	-	-
40	14.2	0.7	.044	.73	309	305	220	240	270	283	-	-
50	13.2	1.0	.046	.71	314	299	227	279	272	313	-	-
60	12.5	0.7	.051	.71	314	294	232	275	271	314	-	-
70	11.1	1.4	.056	.71	329	292	251	274	277	312	-	-
80	10.1	1.0	.056	.71	349	293	267	274	277	312	-	-
90	9.4	0.7	.056	.71	366	293	314	236	288	392	-	-
00	8.5	0.9	.056	.71	382	299	327	243	295	406	-	-
10	7.5	1.0	.060	.72	417	360	347	249	265	401	-	-
20	6.9	0.6	.050	.72	421	309	349	261	317	403	-	-
30	6.5	0.4	.050	.72	429	311	349	269	319	367	-	-
40	6.3	0.2	.045	.72	428	317	349	276	319	363	-	-
50	6.1	0.2	.045	.72	424	317	278	276	317	360	-	-
60	5.6	0.5	.046	.73	422	317	249	274	311	285	-	-
70	5.5	0.1	.039	.73	418	316	223	273	305	266	-	-
80	—	—	—	—	—	—	—	—	—	—	—	—
90	—	—	—	—	—	—	—	—	—	—	—	—
Avg	—	—	—	—	—	—	—	—	—	—	—	—

Technician signature: h

Date: 5/9/16

FUEL DATA

Client: MonsenModel: Def.AProject #: 207-S-#-5 Tracking #: 1534Date: 5/9/10 Test Crew: S. Button Run #: 16

OMNI Equipment ID #: _____

FUEL LOAD PREPARED BY: S. Button

FUEL: DOUGLAS-FIR SPECIES, UNTREATED, AIR-DRIED, STANDARD GRADE OR BETTER, DIMENSIONAL LUMBER.

PRE-BURN FUEL

MOISTURE CONTENT (METER -- DRY BASIS)

CALIBRATION: Cal Value (1) = 12% Actual Reading 12%
 Cal Value (2) = 22% Actual Reading 22%

Piece	Length	Readings	Type
1	10 ft	2d.6	2x4
2	10 ft	20.8	2x4
3	10 ft	25.2	2x4

Length of cut pieces: 8" inches Pre-Burn Fuel Average Moisture: 23.1%Time (clock): 8:15 AM Room Temperature (F): 70 Initials: SB

TEST FUEL

FUEL TYPE AND AMOUNT: 2 x 4 4CALCULATED LOAD WEIGHT: _____ ACTUAL LOAD WEIGHT: 4 (2 x 4)FUEL PIECE LENGTH: 21" 22.6 (4 x 4)
22.6 Total

MOISTURE CONTENT (METER -- DRY BASIS)

PIECE	READINGS	TYPE
1	18.9	4x4
2	20.1	4x4
3	20.6	4x4
4	21.1	4x4
5		
6		
7		
8		
9		
10		

OVERALL TEST FUEL LOAD MOISTURE AVERAGE: 20.45%Time (clock): 9:00 AM Room Temperature (F): 70 Initials: SBTechnician signature: SB Date: 5/9/10

Run Notes


Client: MagnesiaModel: RefractProject #: 223-S-54-5Tracking #: 1534Run #: 16Date: 5/9/10Test Crew: S. Button

OMNI Equipment ID #(s): _____

PREBURN


DESCRIBE OR SKETCH AIR OR THERMOMSTAT SETTINGS BELOW:
 (SETTINGS MUST BE ACCURATE AND REPRODUCABLE)

PRIMARY:

SECONDARY: FixedTERTIARY: N/AFAN: ON LowPREBURN SETTINGS AND ACTIVITIES

TIME	AIR (THERMO) CHANGES PRIMARY/SECONDARY/TERTIARY	FAN SETTING CHANGE	ADD FUEL + WT.	ADD FUEL - WT.	RAKE COAL	COMMENT
10 min	Stirred coals					
60 min	Stirred coals					
120 min	Stirred coals					
150	Removed • 3 lbs of coals					


TEST FUEL CONFIGURATION SKETCH
 (INDICATE VIEW ANGLE)

TEST

BYPASS: Closed @ 50 sec
 FUEL LOADING: Closed @ 50 sec
 DOOR: Set @ 0 sec
 PRIMARY AIR: N/A
 OTHER: N/A

DESCRIBE OR SKETCH TEST SETTINGS BELOW:
 (SETTINGS MUST BE ACCURATE AND REPRODUCIBLE)

PRIMARY:

SECONDARY: FixedTERTIARY: N/A

FAN:

ON LowTechnician signature: KLDate: 5/9/10

Supplemental Data EPA 5G/5H

Client: MonesenModel: DefinitProject #: 227-5-34-3 Tracking #: 1534Date: 5/9/10 Run #: 16 Booth: On-SiteTest Crew: J. Button Start Time: 1:32 PM Stop Time: 8:12 PM

OMNI Equipment #(s): _____

Gas Analyzer Train Leak Check:

Stack:

Dilution Tunnel (Method 5G Only):

Initial: _____

Initial: _____

Final: _____

Final: _____

Calibrations: Span Gas CO₂: _____O₂: _____

CO: _____

CO₂(DT): _____

Time	N ₂ Span						
O ₂							
CO ₂							
CO							
CO ₂ (DT)							

Stack Diameter (inches): 6"Air Velocity (ft/min): Initial: < 50 ft/min Final: < 50 ft/minScale Audit (lbs): Pretest: 10 lbs Post Test: 10 lbsInduced Draft: 0 %Smoke Capture: 160%Pilot Tube Leak Test: Pre: 0 Post: 0Flue Pipe Cleaned Prior to First Test in Series: Date: 5/5/10 Initials: JB

	Initial	Middle	Ending
Pb (in/Hg)	<u>29.77"</u>	<u>29.85"</u>	<u>29.91"</u>
Room Temp (°F)	<u>73 72 °F</u>	<u>73</u>	<u>72 70 °F</u>

Technician signature: J. Button Date: 5/9/10

Model: Defiant
Monessen Hearth Systems
P.O. Box 501
Bethel, VT 05032

Section 5

Sampling Procedures and Test Results

Model: Defiant
Monessen Hearth Systems
P.O. Box 501
Bethel, VT 05032

INTRODUCTION

Monessen Hearth Systems retained *OMNI* to perform U.S. Environmental Protection Agency (EPA) certification testing on the Defiant wood stove. The Defiant wood stove is a non-catalytic, freestanding, radiant-type room heater. The firebox is constructed of cast iron. Usable firebox volume was measured to be 3.3 cubic feet and the stove is vented through a 5.375" x 10.188" oval diameter flue collar located at the top of the unit.

The testing was performed at Monessen's facility in Bethel, Vermont. The unit was observed to be in good condition, then assigned and labeled with *OMNI* ID #1534. *OMNI* representative Thomas Christensen conducted the certification testing and completed all testing by May 9, 2010. The EPA was notified of the testing dates in a letter dated April 15, 2010. A testing contract, including provisions for Random Compliance Audit (RCA) testing, has been signed by Doug Fongeallaz of Monessen Hearth Systems and is on file at *OMNI*'s testing facility.

The Defiant wood stove was tested in accordance with the U.S. EPA 40 CFR Part 60, Subpart AAA – Standard of Performance for Residential Wood Heaters (Appendix A, Methods 28 and 5G). Particulate emissions were measured using a Method 5G sampling train consisting of two filters (front and back). The weighted average emissions of the nine test runs included in the results indicate a particulate emission level of 2.3 grams per hour. The Run Summary sheet included in Section 4 details which runs were used in the weighted average emissions, which were fan confirmation runs, and which were unacceptable and why. Test runs were conducted in each of four burn rate categories (<0.80 kg/hr; 0.80-1.25 kg/hr, 1.25-1.90 kg/hr, and maximum). Emissions for each of their individual test runs did not exceed the cap. The Defiant results are within the emission limit of 7.5 grams per hour for non-catalytic affected facilities manufactured on or after July 1, 1990, or sold at retail on or after July 1, 1992.

The wood heater was sealed after completion of testing in compliance with the EPA regulation as follows:

- "DO NOT TAMPER" labels were placed on the door and on all other openings.
- Plastic material sealed with "DO NOT TAMPER" labels and tape was wrapped around the unit.
- The unit was sealed in a wood box constructed for the unit and secured with steel banding.
- "DO NOT TAMPER" labels were placed on all outer surfaces of the box.

This report is organized in accordance with the EPA-recommended outline and is summarized in the Table of Contents immediately preceding this report. The results in this report are limited to the item submitted.

Model: Defiant
Monessen Hearth Systems
P.O. Box 501
Bethel, VT 05032

Table 1.1 – Particulate Emissions

Run	Burn Rate (kg/hr dry)	Method 5G Emissions (g/hr)
2	0.69	1.06
3	2.78	2.04
5	1.44	1.65
8	0.95	4.49
11	0.89	5.91
12	2.81	6.49
14	1.51	0.75
15	0.87	2.29
16	1.28	2.06

Weighted particulate emission average of nine test runs: 2.3 grams per hour.

Table 1.2 – Test Facility Conditions

Run	Room Temperature (°F)		Barometric Pressure (Hg)		Air Velocity (ft/min)	
	Before	After	Before	After	Before	After
2	75	84	29.60	29.55	<50	<50
3	75	73	29.47	29.47	<50	<50
5	72	71	29.32	29.32	<50	<50
8	71	79	29.30	29.10	<50	<50
11	69	75	28.88	28.92	<50	<50
12	73	75	28.95	29.10	<50	<50
14	76	76	29.35	29.37	<50	<50
15	76	73	29.72	29.80	<50	<50
16	72	70	29.77	29.91	<50	<50

Model: Defiant
Monessen Hearth Systems
P.O. Box 501
Bethel, VT 05032

Table 1.3.1 – Fuel Measurement and Crib Description Summary – PRETEST

Run	Pretest Fuel Weight (Starting weight in lbs)	Pretest Moisture (Dry basis - %)	Coal Bed Weight (lbs)
2	16.0	19.2	5.1
3	22.5	19.3	5.6
5	15.5	19.7	5.5
8	7.0	20.5	2.5
11	15.6	20.7	5.4
12	31.8	20.0	5.6
14	16.6	22.1	5.8
15	16.6	22.9	5.6
16	16.7	23.1	5.4

Table 1.3.2 – Fuel Measurement and Crib Description Summary – TEST

Run	Test Fuel Wet Basis (lbs)	Firebox Volume (ft ³)	Fuel Loading Density Wet Basis (lbs/ft ³)	Fuel Moisture Content Dry (%)	Piece Length (in)	2x4s Used	4x4s Used
2	22.2	3.3	6.73	20.2	21	0	4
3	23.6	3.3	7.15	21.3	21	0	4
5	22.2	3.3	6.73	20.0	21	0	4
8	22.3	3.3	6.76	20.7	21	0	4
11	22.4	3.3	6.79	20.4	21	0	4
12	22.4	3.3	6.79	20.2	21	0	4
14	22.7	3.3	6.88	19.9	21	0	4
15	22.5	3.3	6.82	22.1	21	0	4
16	22.6	3.3	6.85	20.5	21	0	4

Model: Dfiant
Monessen Hearth Systems
P.O. Box 501
Bethel, VT 05032

Table 1.4 – Dilution Tunnel Gas Measurements and Sampling Data Summary

Run	Length of Test (min)	Average Dilution Tunnel Gas Measurements		
		Velocity (ft/sec)	Flow Rate (dscf/min)	Temperature (°F)
2	730	12.14	129.9	91.3
3	190	14.72	145.7	133.9
5	350	13.27	138.4	100.7
8	530	13.06	137.0	94.4
11	570	13.64	143.1	90.0
12	180	14.21	137.0	140.5
14	340	13.53	139.3	108.5
15	580	13.79	148.5	91.3
16	400	14.15	151.3	96.5

Table 1.5 - Heater Operation Data (Average Temperature Data)

Run	Beginning Surface Temperature Average ^a	Ending Surface Temperature Average ^a	Surface Delta T ^b
2	291.0	184.2	107
3	385.0	314.6	70
5	306.0	229.8	76
8	318.0	212.4	106
11	323.0	204.6	118
12	421.8	393.2	29
14	331.0	284.6	46
15	313.0	227.6	85
16	302.6	244.8	58

a. All temperatures are in degrees F.
b. Represents the difference between beginning and ending average surface temperatures.

Model: Defiant
Monessen Hearth Systems
P.O. Box 501
Bethel, VT 05032

Table 1.6 – Pretest Configuration

Run	Combustion Air (in)	Fuel Added	Fuel Removed	Time (min)
2	Fully Closed	16.0 lbs at start; no addition; coal bed 5.1 lbs	0.7	110
3	Fully Open	22.5 lbs at start; 14.8 lbs added; coal bed 5.6 lbs	0.0	150
5	Test Setting 3	15.5 lbs at start; no addition; coal bed 5.5 lbs	0.0	70
8	Test Setting 2	7.0 lbs at start; no addition; coal bed 2.5 lbs	0.5	110
11	Test Setting 2	15.6 lbs at start; no addition; coal bed 5.4 lbs	0.0	160
12	Test Setting 4	31.8 lbs at start; no addition; coal bed 5.6 lbs	0.0	120
14	Test Setting 3	16.6 lbs at start; 13.1 lbs added; coal bed 5.8 lbs	0.0	280
15	Fully Closed	16.6 lbs at start; no addition; coal bed 5.6 lbs	0.0	180
16	Dial Up 1-1/8" from Fully Closed	16.7 lbs at start; no addition; coal bed 5.4 lbs	0.0	175

Table 1.7 – Run Data

Run	Average Dry Burn Rate (kg/hr)	Initial (Induced) Draft (H ₂ O)	Primary Air Setting (in)	Run Time (min)	Average Draft (H ₂ O)
2	0.69	0	Fully Closed	730	-0.029
3	2.78	0	Fully Open	190	-0.065
5	1.44	0	Test Setting 3	350	-0.049
8	0.95	0	Test Setting 2	530	-0.036
11	0.89	0	Test Setting 2	570	-0.035
12	2.81	0	Test Setting 4	180	-0.068
14	1.51	0	Test Setting 3	340	-0.051
15	0.87	0	Fully Closed	580	-0.038
16	1.28	0	Dial Up 1-1/8" from Fully Closed	400	-0.046

Model: Defiant
Monessen Hearth Systems
P.O. Box 501
Bethel, VT 05032

Table 1.8 – Test Configurations

Run	Five-Minute Startup	Combustion Air
2	<u>Bypass</u> : Open for 1 minute. <u>Fuel Loading</u> : Completed by 1 minute. <u>Door</u> : Closed at 1 minute. <u>Primary Air</u> : Fully closed. <u>Other</u> : Test fuel poked at 406 minutes after 0.05 lb change over 10 minutes. <u>Secondary</u> : N/A. <u>Tertiary</u> : N/A. <u>Fan</u> : On low.	Fully Closed
3	<u>Bypass</u> : Open for 1 minute. <u>Fuel Loading</u> : Completed by 1 minute. <u>Door</u> : Closed at 1 minute. <u>Primary Air</u> : Fully Open. <u>Other</u> : N/A. <u>Secondary</u> : N/A. <u>Tertiary</u> : N/A. <u>Fan</u> : On high.	Fully Open
5	<u>Bypass</u> : Open for 50 seconds. <u>Fuel Loading</u> : Completed by 50 seconds. <u>Door</u> : Closed at 50 seconds. <u>Primary Air</u> : At test setting for duration of test. <u>Other</u> : N/A. <u>Secondary</u> : N/A. <u>Tertiary</u> : N/A. <u>Fan</u> : On high.	Test Setting 3
8	<u>Bypass</u> : Open for 90 seconds. <u>Fuel Loading</u> : Completed by 90 seconds. <u>Door</u> : Closed at 90 seconds. <u>Primary Air</u> : At test setting for duration of test. <u>Other</u> : N/A. <u>Secondary</u> : N/A. <u>Tertiary</u> : N/A. <u>Fan</u> : On low.	Test Setting 2
11	<u>Bypass</u> : Open for 75 seconds. <u>Fuel Loading</u> : Completed by 1 minute. <u>Door</u> : Closed at 75 seconds. <u>Primary Air</u> : At test setting for duration of test. <u>Other</u> : N/A. <u>Secondary</u> : N/A. <u>Tertiary</u> : N/A. <u>Fan</u> : Off.	Test Setting 2

Model: Defiant
Monessen Hearth Systems
P.O. Box 501
Bethel, VT 05032

Run	Five-Minute Startup	Combustion Air
12	<u>Bypass</u> : Open for 1 minute. <u>Fuel Loading</u> : Completed by 1 minute. <u>Door</u> : Closed at 1 minute. <u>Primary Air</u> : At test setting for duration of test. <u>Other</u> : N/A. <u>Secondary</u> : N/A. <u>Tertiary</u> : N/A. <u>Fan</u> : Off.	Test Setting 4
14	<u>Bypass</u> : Open for 50 seconds. <u>Fuel Loading</u> : Completed by 50 seconds. <u>Door</u> : Closed at 50 seconds. <u>Primary Air</u> : At test setting for duration of test. <u>Other</u> : N/A. <u>Secondary</u> : N/A. <u>Tertiary</u> : N/A. <u>Fan</u> : Off.	Test Setting 3
15	<u>Bypass</u> : Open for 1 minute. <u>Fuel Loading</u> : Completed by 1 minute. <u>Door</u> : Closed at 1 minute. <u>Primary Air</u> : At test setting for duration of test. <u>Other</u> : N/A. <u>Secondary</u> : Fixed. <u>Tertiary</u> : N/A. <u>Fan</u> : Off.	Fully Closed
16	<u>Bypass</u> : Open for 50 seconds. <u>Fuel Loading</u> : Completed by 50 seconds. <u>Door</u> : Closed at 50 seconds. <u>Primary Air</u> : At test setting for duration of test. <u>Other</u> : N/A. <u>Secondary</u> : Fixed. <u>Tertiary</u> : N/A. <u>Fan</u> : On low.	Dial Up 1-1/8" from Fully Closed

Model: Defiant
Monessen Hearth Systems
P.O. Box 501
Bethel, VT 05032

TEST RESULTS AND DISCUSSION

A total of 16 test runs were performed on the Defiant wood stove. Nine test runs were conducted in the following categories and included in the weighted average emission level results: one in the <0.80 kg/hr dry category; three in the 0.80 to 1.25 kg/hr dry category; three in the 1.25 to 1.90 kg/hr dry category; and two at maximum.

The weighted particulate emission level was measured to be 2.3 g/hr.

The proportionality results for all 16 test runs were acceptable. Quality check results for each test run are presented in Section 2 of this report.